

# Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Member State of OIML  
Germany



OIML Certificate No.  
**R49/2006-DE1-10.03**  
Revision 2

## OIML CERTIFICATE OF CONFORMITY

### Issuing Authority

Name: Physikalisch-Technische Bundesanstalt  
Address: Bundesallee 100, 38116 Braunschweig  
Person responsible: Dr. Gudrun Wendt

### Applicant

Name: ELSTER Messtechnik GmbH  
Address: Otto-Hahn-Straße 25  
68623 Lampertheim  
Germany

Manufacturer of the certified type is the applicant.

### Identification of the certified type

Water meter intended for the metering of cold potable water  
Combination meter with mechanical register  
Type: C4000

Further characteristics see page 3

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 49-1 (Edition 2006) Metrological and technical requirements  
R 49-2 (Edition 2006) Test methods  
R 49-3 (Edition 2006) Test report format

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-10.03**  
**Revision 2**

The conformity was established by the results of tests and examinations provided in the associated Test Reports PTB-1.5-4046578 (127 pages) and PTB-1.5-4051570 (35 pages).

## The Issuing Authority

Dr. G. Wendt  
Head of Department

09.01.2013

## The OIML Member

Dr. R. Schwartz  
Head of Division

09.01.2013

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report(s) is not permitted, although either may be reproduced in full.

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-10.03**  
**Revision 2**

Identification of the certified type - page 1 continued

Type details C4000

Nominal diameter	$Q_3$ [m <sup>3</sup> /h]	$Q_4$ [m <sup>3</sup> /h]	$Q_{x1}$ [m <sup>3</sup> /h]	$Q_{x2}$ [m <sup>3</sup> /h]	$Q_3/Q_1$	$Q_2/Q_1$
DN 50	25	31,25	0,8 - 1,25	1,6 - 2,0	630; 800; 1000; 1250; 1600	1,6
DN 65						
DN 80	63	78,75	1,1 – 2,0	2,1 – 3,0	1250; 1600; 2000; 2500; 3150; 4000	
DN 100	100	125			1250; 1600; 2000; 2500; 3150; 4000; 5000; 6300	

The measuring system consists of a large meter of the Woltman parallel type and a small meter of the piston type ( $Q_3$  4 m<sup>3</sup>/h) in conjunction with change over valve and three mechanical versions of dry running registers for the large meter and one version of dry running register for the small meter:

- dry register large meter (Woltman):
  - Multipulse-copper can counter (inductive, 6 rollers and 3 pointers, verification scale interval 0,5 ℓ),
  - Multipulse-copper can counter (magnetic, 6 rollers and 2 pointers, verification scale interval 1 ℓ) or
  - Multipulse-copper can counter (magnetic, 6 rollers and 3 pointers, verification scale interval 0,5 ℓ).
- dry register small meter (Piston):
  - copper can counter (inductive, 7 rollers and 2 pointers, verification scale interval 0,02 ℓ).

The dry running registers can be combined with two types of retrofittable pulse generators:

- inductive pulse generator Falcon PR7, Falcon PR7M and Falcon TPR7 (dry register large meter) and / or Falcon PR6, Falcon PR6M and Falcon TPR6 (dry register small meter) respectively
- magnetic reed contact pulse generator T160 (dry register large meter).

Accuracy class: 2  
 Temperature class: T30  
 Environmental class: B (M1)  
 Electromagnetic environment: not applicable (n/a)  
 Climatic environment: +5 °C to 55 °C  
 Maximum admissible temperature: +30 °C  
 Pressure loss class  $\Delta P$ : 0,063 MPa (0,63 bar)  
 Maximum admissible pressure: 1,6 MPa (16 bar)  
 Orientation: All orientations except upside down (no overhead installation with register up side down)

Installation details:

Connection type: Flange (partially with screw thread)  
 Minimum straight length of inlet pipe: 150 mm [3 x DN] (DN 50) and 0 mm [0 x DN] (DN 80 and DN 100)  
 Minimum straight length of outlet pipe: 0 mm [0 x DN] (DN 50, DN 80 and DN 100)  
 Flow conditioner: n/a  
 Mounting: Flange connection with suitable gaskets  
 Minimal body length: 270 mm (DN 50), 300 mm (DN 80) and 350 mm (DN 100)