

# Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Member State of OIML  
Germany



OIML Certificate No.  
**R49/2006-DE1-14.01**

## OIML CERTIFICATE OF CONFORMITY

### Issuing Authority

Name: Physikalisch-Technische Bundesanstalt  
Address: Bundesallee 100, 38116 Braunschweig  
Person responsible: Dr. G. Wendt

### Applicant

Name: Diehl Metering GmbH  
Address: Industriestraße 13, 91522 Ansbach  
GERMANY

Manufacturer of the certified type is the applicant.

### Identification of the certified type

Water meter with mechanical indicating device  
Type: ET1, ET2, ET3, ET4

Further characteristics see page 3

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 49-1 (Edition 2006) Metrological and technical requirements  
R 49-2 (Edition 2006) Test methods  
R 49-3 (Edition 2006) Test report format

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-14.01**

The conformity was established by the results of tests and examinations provided in the associated Test Reports

No. PTB-1.5-4071210 that includes 2164 pages

## The Issuing Authority

Dr. G. Wendt  
Head of Department

08.10.2014

## The OIML Member

Dr. R. Schwartz  
Vice-President

08.10.2014

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report(s) is not permitted, although either may be reproduced in full.

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-14.01**

Identification of the certified type - page 1 continued

Type details ET1, ET2, ET3, ET4

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079	0,063	0,050	0,040	0,031	0,025	0,020
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127	0,100	0,080	0,063	0,050	0,040	0,032
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50	63	80	100	125

Accuracy class:                   ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
  ± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: H

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079	0,063	0,050
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127	0,100	0,080
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50

Accuracy class:                   ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
  ± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-14.01**

## ET2, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079	0,063	0,050	0,040	0,031	0,025
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127	0,100	0,080	0,063	0,050	0,040
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50	63	80	100

Accuracy class:                   ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
  ± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: H

## ET2, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5

Accuracy class:                   ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
  ± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 1,6 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,080	0,064	0,051	0,040	0,032	0,025	0,020
Q <sub>2</sub> [m <sup>3</sup> /h]	0,128	0,102	0,081	0,064	0,051	0,041	0,032
Q <sub>3</sub> [m <sup>3</sup> /h]	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>4</sub> [m <sup>3</sup> /h]	2,00	2,00	2,00	2,00	2,00	2,00	2,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	20	25	31,5	40	50	63	80

Accuracy class:                   ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
  ± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: H

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-14.01**

## ET1, ET3, ET4, DN15, $Q_3$ 1,6 m<sup>3</sup>/h

Flow range:

$Q_1$ [m <sup>3</sup> /h]	0,080	0,064	0,051
$Q_2$ [m <sup>3</sup> /h]	0,128	0,102	0,081
$Q_3$ [m <sup>3</sup> /h]	1,6	1,6	1,6
$Q_4$ [m <sup>3</sup> /h]	2,00	2,00	2,00
$Q_2 / Q_1$	1,6	1,6	1,6
$Q_3 / Q_1$	20	25	31,5

Accuracy class:  $\pm 2\%$  ( $Q_2 \leq Q \leq Q_4$ )  
 $\pm 5\%$  ( $Q_1 \leq Q < Q_2$ )  
Water temperature range: 0,1 °C to 30 °C  
Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET2, DN15, $Q_3$ 1,6 m<sup>3</sup>/h

Flow range:

$Q_1$ [m <sup>3</sup> /h]	0,100	0,080	0,064	0,051	0,040	0,032	0,025
$Q_2$ [m <sup>3</sup> /h]	0,160	0,128	0,102	0,081	0,064	0,051	0,041
$Q_3$ [m <sup>3</sup> /h]	1,6	1,6	1,6	1,6	1,6	1,6	1,6
$Q_4$ [m <sup>3</sup> /h]	2,00	2,00	2,00	2,00	2,00	2,00	2,00
$Q_2 / Q_1$	1,6	1,6	1,6	1,6	1,6	1,6	1,6
$Q_3 / Q_1$	16	20	25	31,5	40	50	63

Accuracy class:  $\pm 2\%$  ( $Q_2 \leq Q \leq Q_4$ )  
 $\pm 5\%$  ( $Q_1 \leq Q < Q_2$ )  
Water temperature range: 0,1 °C to 30 °C  
Orientation: H

## ET2, DN15, $Q_3$ 1,6 m<sup>3</sup>/h

Flow range:

$Q_1$ [m <sup>3</sup> /h]	0,100	0,080
$Q_2$ [m <sup>3</sup> /h]	0,160	0,128
$Q_3$ [m <sup>3</sup> /h]	1,6	1,6
$Q_4$ [m <sup>3</sup> /h]	2,00	2,00
$Q_2 / Q_1$	1,6	1,6
$Q_3 / Q_1$	16	20

Accuracy class:  $\pm 2\%$  ( $Q_2 \leq Q \leq Q_4$ )  
 $\pm 5\%$  ( $Q_1 \leq Q < Q_2$ )  
Water temperature range: 0,1 °C to 30 °C  
Orientation: rising pipe and falling pipe / V 90° und V 45°

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
**R49/2006-DE1-14.01**

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10	0,08	0,06	0,050
Q <sub>2</sub> [m <sup>3</sup> /h]	0,25	0,20	0,16	0,13	0,10	0,080
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	16	20	25	31,5	40	50

Accuracy class: ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: H

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10
Q <sub>2</sub> [m <sup>3</sup> /h]	0,25	0,20	0,16
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	16	20	25

Accuracy class: ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 4,0 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10	0,08	0,06	0,05
Q <sub>2</sub> [m <sup>3</sup> /h]	0,26	0,20	0,16	0,13	0,10	0,08
Q <sub>3</sub> [m <sup>3</sup> /h]	4,0	4,0	4,0	4,0	4,0	4,0
Q <sub>4</sub> [m <sup>3</sup> /h]	5,00	5,00	5,00	5,00	5,00	5,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50	63	80

Accuracy class: ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: H

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
R49/2006-DE1-14.01

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 4,0 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10
Q <sub>2</sub> [m <sup>3</sup> /h]	0,26	0,20	0,16
Q <sub>3</sub> [m <sup>3</sup> /h]	4,0	4,0	4,0
Q <sub>4</sub> [m <sup>3</sup> /h]	5,00	5,00	5,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40

Accuracy class: ± 2 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 0,1 °C to 30 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079	0,063	0,050	0,040	0,031	0,025
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127	0,100	0,080	0,063	0,050	0,040
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50	63	80	100

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: H

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079	0,063	0,050
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127	0,100	0,080
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
R49/2006-DE1-14.01

## ET2, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079	0,063	0,050	0,040	0,031
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127	0,100	0,080	0,063	0,050
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50	63	80

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)  
Water temperature range: 30 °C to 90 °C  
Orientation: H

## ET2, DN15, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,079
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,127
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)  
Water temperature range: 30 °C to 90 °C  
Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 1,6 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,080	0,064	0,051	0,040	0,032	0,025	0,020
Q <sub>2</sub> [m <sup>3</sup> /h]	0,128	0,102	0,081	0,064	0,051	0,041	0,032
Q <sub>3</sub> [m <sup>3</sup> /h]	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>4</sub> [m <sup>3</sup> /h]	2,00	2,00	2,00	2,00	2,00	2,00	2,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	20	25	31,5	40	50	63	80

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)  
Water temperature range: 30 °C to 90 °C  
Orientation: H



# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
R49/2006-DE1-14.01

## ET1, ET3, ET4, DN15, Q<sub>3</sub> 1,6 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,08	0,06	0,05
Q <sub>2</sub> [m <sup>3</sup> /h]	0,13	0,10	0,08
Q <sub>3</sub> [m <sup>3</sup> /h]	1,6	1,6	1,6
Q <sub>4</sub> [m <sup>3</sup> /h]	2,00	2,00	2,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	20	25	31,5

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET2, DN15, Q<sub>3</sub> 1,6 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,080	0,064	0,051	0,040	0,032	0,025
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,128	0,102	0,081	0,064	0,051	0,041
Q <sub>3</sub> [m <sup>3</sup> /h]	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>4</sub> [m <sup>3</sup> /h]	2,00	2,00	2,00	2,00	2,00	2,00	2,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	16	20	25	31,5	40	50	63

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: H

## ET2, DN15, Q<sub>3</sub> 1,6 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,100	0,080
Q <sub>2</sub> [m <sup>3</sup> /h]	0,160	0,128
Q <sub>3</sub> [m <sup>3</sup> /h]	1,6	1,6
Q <sub>4</sub> [m <sup>3</sup> /h]	2,00	2,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	16	20

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)  
± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
R49/2006-DE1-14.01

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10	0,08	0,06	0,050
Q <sub>2</sub> [m <sup>3</sup> /h]	0,25	0,20	0,16	0,13	0,10	0,080
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	16	20	25	31,5	40	50

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: H

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 2,5 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10
Q <sub>2</sub> [m <sup>3</sup> /h]	0,25	0,20	0,16
Q <sub>3</sub> [m <sup>3</sup> /h]	2,5	2,5	2,5
Q <sub>4</sub> [m <sup>3</sup> /h]	3,13	3,13	3,13
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	16	20	25

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 4,0 m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10	0,08	0,06	0,05
Q <sub>2</sub> [m <sup>3</sup> /h]	0,26	0,20	0,16	0,13	0,10	0,08
Q <sub>3</sub> [m <sup>3</sup> /h]	4,0	4,0	4,0	4,0	4,0	4,0
Q <sub>4</sub> [m <sup>3</sup> /h]	5,00	5,00	5,00	5,00	5,00	5,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40	50	63	80

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: H

# Physikalisch-Technische Bundesanstalt

OIML Certificate No.  
R49/2006-DE1-14.01

## ET1, ET2, ET3, ET4, DN20, Q<sub>3</sub> 4,0m<sup>3</sup>/h

Flow range:

Q <sub>1</sub> [m <sup>3</sup> /h]	0,16	0,13	0,10
Q <sub>2</sub> [m <sup>3</sup> /h]	0,26	0,20	0,16
Q <sub>3</sub> [m <sup>3</sup> /h]	4,0	4,0	4,0
Q <sub>4</sub> [m <sup>3</sup> /h]	5,00	5,00	5,00
Q <sub>2</sub> / Q <sub>1</sub>	1,6	1,6	1,6
Q <sub>3</sub> / Q <sub>1</sub>	25	31,5	40

Accuracy class: ± 3 % (Q<sub>2</sub> ≤ Q ≤ Q<sub>4</sub>)

± 5 % (Q<sub>1</sub> ≤ Q < Q<sub>2</sub>)

Water temperature range: 30 °C to 90 °C

Orientation: rising pipe and falling pipe / V 90° und V 45°

## Pressure range and pressure loss, environmental conditions

P <sub>min</sub>	P <sub>max</sub>	Type (DN, Q <sub>3</sub> )	ΔP
0,3 bar (0,03MPa)	10 bar (1,0 MPa)	DN15, Q <sub>3</sub> : 1,6 m <sup>3</sup> /h	ΔP 25
		DN15, Q <sub>3</sub> : 2,5 m <sup>3</sup> /h	ΔP 63
		DN20, Q <sub>3</sub> : 2,5 m <sup>3</sup> /h	ΔP 40
		DN20, Q <sub>3</sub> : 4,0 m <sup>3</sup> /h	ΔP 63

Minimum straight length of inlet / outlet pipe:

0 mm / 0 mm