

Member State of OIML
United Kingdom of Great Britain
and Northern Ireland

OIML Certificate No
R49/2006/GB1-10.01
Revision 2

OIML CERTIFICATE OF CONFORMITY

Issuing authority: **National Measurement Office**

Person responsible: **Paul Dixon – Product Certification Manager**

Applicant: **ABB Limited
Oldends Lane
Stonehouse
Gloucestershire, GL10 3TA
United Kingdom**

Manufacturer: **The applicant**

Identification of the certified pattern: **FEV1 & FET1. A family of cold-water meters named WaterMaster, utilising a common, electromagnetic principle. Further characteristics see page 2.**

This certificate attests the conformity of the above-mentioned pattern (represented by the samples identified in the associated test report) with the requirements of the following Recommendation of the International Organisation of Legal Metrology (OIML):

OIML R 49 - Edition 2006(E) for accuracy class: 1 & 2

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation.

This certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the certificates reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or of the associated test report is not permitted, though they may be reproduced in full.

Issue Date: 15 May 2012
Reference No: T23/0017

Signatory: P R Dixon



The conformity was established by tests described in the associated test report WMFEV1 having 51 pages, test report TR0550 having 26 pages and the associated pattern evaluation checklist included in report WMFEV1.

This revision replaces previous versions of the certificate.

Characteristics:

| | | | WaterMaster OIML R49 Class 2 | | | |
|-----|--------|--------|------------------------------|--------|--------|-----|
| DN | Q4 | Q3 | Q0.4% | Q2 | Q1 | R |
| | (m3/h) | (m3/h) | (m3/h) | (m3/h) | (m3/h) | |
| 40 | 50 | 40 | 4.2 | 0.2 | 0.13 | 315 |
| 50 | 79 | 63 | 4.2 | 0.32 | 0.20 | 315 |
| 65 | 125 | 100 | 6.7 | 0.50 | 0.32 | 315 |
| 80 | 200 | 160 | 10.7 | 0.81 | 0.51 | 315 |
| 100 | 313 | 250 | 16.7 | 1.3 | 0.79 | 315 |
| 125 | 313 | 250 | 16.7 | 1.3 | 0.79 | 315 |
| 150 | 788 | 630 | 42 | 3.2 | 2.0 | 315 |
| 200 | 1,250 | 1,000 | 67 | 5.1 | 3.2 | 315 |
| 250 | 2,000 | 1,600 | 107 | 8.1 | 5.1 | 315 |
| 300 | 3,125 | 2,500 | 167 | 12.7 | 7.9 | 315 |

| | | | WaterMaster OIML R49 Class 1 | | | |
|------|--------|--------|------------------------------|--------|--------|-----|
| DN | Q4 | Q3 | Q0.2% | Q2 | Q1 | R |
| | (m3/h) | (m3/h) | (m3/h) | (m3/h) | (m3/h) | |
| * 40 | 50 | 40 | 6 | 0.32 | 0.2 | 200 |
| * 50 | 79 | 63 | 7.9 | 0.5 | 0.32 | 200 |
| 65 | 125 | 100 | 12.5 | 0.8 | 0.50 | 200 |
| 80 | 200 | 160 | 16 | 1.3 | 0.8 | 200 |
| 100 | 200 | 250 | 25 | 2 | 1.25 | 200 |
| 125 | 313 | 250 | 25 | 2 | 1.25 | 200 |
| 150 | 788 | 630 | 63 | 5 | 3.2 | 200 |
| 200 | 1,250 | 1,000 | 100 | 8 | 5 | 200 |
| 250 | 2,000 | 1,600 | 160 | 13 | 8 | 200 |
| 300 | 3,125 | 2,500 | 250 | 20 | 12.5 | 200 |

Note: * OIML R49-1 allows Class 1 only for meters with Q3 >= 100m3/h, although the meters were tested to class 1 accuracy and passed the requirements.

| | |
|---------------------------------|-----------------------------|
| Measuring principle: | Electromagnetic |
| Accuracy Class: | 1 & 2 |
| Q ₂ /Q ₁ | 1.6 |
| Q ₃ /Q ₁ | Class 1 = 200, Class 2= 315 |
| Environmental class: | T50 (0.1C to 50C) |
| Environmental class: | C |
| Electromagnetic environment: | E2 |
| Maximum admissible temperature: | 50 °C |
| Maximum admissible pressure: | 1.6 Mpa (16 bar) |
| Pressure Loss Class | 0.25 bar |

Installation details

| | |
|---|--------------------|
| Connection type | Flange |
| Minimum straight length of inlet pipe: | 5D (DN x 5) |
| Minimum straight length of outlet pipe: | 0D (0) |
| Flow conditioner (details if required): | None |
| Transmitter FET 1 location | Integral or Remote |

Mounting

| | |
|--------------|----------------------------------|
| Orientation: | Can be installed in any position |
|--------------|----------------------------------|

Functionality

| | |
|-----------------------------|--|
| Checking Facilities : | Measurement transducer, Calculator & Indicator |
| Checking Facilities Type: | P |
| Flow Measurement Direction: | Bi Directional |

Power Supply

| | |
|--------------------|---|
| Type: | Mains or DC (85 to 265V AC or 24V AC +10%-30% / 24V DC +/-30%) |
| U _{max} : | 265V AC or 26.4VAC or 31.2V DC |
| U _{min} : | 85V AC or 18.46V AC or 18.46V DC |
| Frequency: | 50-60Hz |

Alternative Manufacturing Sites:

ABB Inc.
125 East County Line Road
Warminster
18974-4995
Pennsylvania
United States

ABB Engineering (Shanghai) Ltd.
No.5, Lane 369,
Chuangye Rd.,
Pudong District,
Shanghai 201319
P.R. China

OIML Certificate No
R49/2006/GB1-10.01
Revision 2

Certificate History:

| ISSUE No.. | DATE | DESCRIPTION |
|-------------------------------|------------------|---|
| R49/2006-GB1-10.01 | 24 February 2010 | Type approval first issued. |
| R49/2006-GB1-10.01 Revision 1 | 6 October 2011 | Revision 1 issued. Addition of Meter sizes DN65 and DN125 to Characteristics Transmitter FET 1 location added to installation details Certificate history added. |
| R49/2006-GB1-10.01 Revision 2 | 15 May 2012 | Revision 2 issued. Alternative manufacturing sites added |