

OIML Member State
The Netherlands

Number R49-1/2006-NL1-13.01 revision 1
Project number 13200194
Page 1 of 5

Issuing authority: NMI Certin B.V.
Person responsible: C. Oosterman

Applicant: KROHNE Altometer
Kerkeplaat 12, 3313 LC Dordrecht, The Netherlands

Manufacturer: KROHNE Altometer
Kerkeplaat 12, 3313 LC Dordrecht, The Netherlands

Identification of the certified type: **A water meter**
Type: OPTIFLUX x300C; OPTIFLUX x000F + IFC300y *

Water meter intended for the metering of cold potable water, model "OPTIFLUX x300C; OPTIFLUX x000F + IFC300y*", class 1 and 2.

Characteristics: See page 2 and further

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

- R49-1/2006 (E):** Metrological and technical requirements
- R49-2/2006 (E):** Test methods
- R49-3/2006 (E):** Test Report format

Remarks: *) With x being 1, 2, 4, 5 or 6 and with y being F or W.

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above.
This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority: **NMI Certin B.V., OIML Issuing Authority NL1**
8 November 2013



C. Oosterman
Head Certification Board

NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
the Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMI Certin B.V. as Issuing Authority can be verified at www.oiml.org

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMI (see www.nmi.nl).





OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R49-1/2006-NL1-13.01 revision 1
Project number 13200194
Page 2 of 5

The conformity was established by the results of tests and examinations provided in the associated OIML Test Reports:

- No. R49-1/2003-NL1-06.01 that includes 193 pages (including Annexes)
- No. NMI-12200395-01 that includes 9 pages (including Annexes)
- No. NMI-12200544-01 that includes 9 pages (including Annexes)
- No. NMI-12200544-02 that includes 9 pages (including Annexes)
- No. NMI-13200264-02 that includes 50 pages (including Annexes)

Identification of the certified pattern

Water meter intended for metering cold potable water, based on an electromagnetic principle, designed to measure reverse flow, with straight inlet and outlet length, with no flow conditioner and equipped with an electronic calculating/indicating device.

Metrological characteristics:

Type	:	OPTIFLUX x300C ^[1] , complete water meter OPTIFLUX x000F ^[1] + IFC300y ^[1] , combined water meter		
Maximum admissible pressure (bar)	:	16		
Min/max admissible temperature (°C)	:	0,1/50		
Orientation	:	All positions		
Environmental class	:	C		
Power supply	:			
Type		AC	DC	AC/DC
U _{max}		230 V	24 V	24 V
U _{min}		100 V	12 V	24 V
Frequency		50 – 60 Hz	-	AC: 50 - 60 Hz

^[1] With x being 1, 2, 4, 5 or 6 and with y being F or W.



OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R49-1/2006-NL1-13.01 revision 1
Project number 13200194
Page 3 of 5

Meter size	DN25	DN32	DN40	DN50	DN65	DN80	DN100
Minimum flow rate Q1 (m ³ /h)	0,040	0,0625	0,0625	0,10	0,1587	0,254	0,3968
Transitional flow rate Q2 (m ³ /h)	0,064	0,10	0,10	0,16	0,25	0,40	0,6
Permanent flow rate Q3 (m ³ /h)	16	25	25	40	100	160	250
Overload flow rate Q4 (m ³ /h)	20	31,3	31,3	50	125	200	312,5
Nominal diameter (mm)	25	32	40	50	65	80	100
Accuracy Class	2				1		
Indicating range (m ³) ^{[2][4]}	99.999				999.999		
Verification scale interval (m ³) ^{[3][4]}	0,0001						0,001

Meter size	DN125	DN150	DN200	DN250
Minimum flow rate Q1 (m ³ /h)	0,6349	0,6349	1,0	1,6
Transitional flow rate Q2 (m ³ /h)	1,0	1,0	1,6	2,6
Permanent flow rate Q3 (m ³ /h)	400	400	1000	1600
Overload flow rate Q4 (m ³ /h)	500	500	1250	2000
Nominal diameter (mm)	125	150	200	250
Accuracy Class	1			
Indicating range (m ³)	999.999		9.999.999	
Verification scale interval (m ³)	0,001			

^[2] The indicating range is programmable, stated here is the minimum indicating range.

^[3] The verification scale interval is programmable, stated here is the maximum value.

^[4] The display of the totalizer has 11 digits (including 1 digit for the decimal sign). The format of the totalizer must be such that demands of the indicating range and the verification scale interval are met.



OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R49-1/2006-NL1-13.01 revision 1
Project number 13200194
Page 4 of 5

Meter size	DN300	DN350	DN400	DN450	DN500
Minimum flow rate Q1 (m ³ /h)	2,5	5,0	8,0	8,0	12,6
Transitional flow rate Q2 (m ³ /h)	4,0	8,0	12,8	12,8	20,2
Permanent flow rate Q3 (m ³ /h)	2500	2500	4000	4000	6300
Overload flow rate Q4 (m ³ /h)	3125	3125	5000	5000	7875
Nominal diameter (mm)	300	350	400	450	500
Accuracy Class	1				
Indicating range (m ³)	9.999.999				
Verification scale interval (m ³)	0,001	0,01			

Meter size	DN600	DN800	DN900	DN1000	DN1200
Minimum flow rate Q1 (m ³ /h)	39,375	125	200	200	200
Transitional flow rate Q2 (m ³ /h)	63	200	320	320	320
Permanent flow rate Q3 (m ³ /h)	6300	10000	16000	16000	16000
Overload flow rate Q4 (m ³ /h)	7875	12500	20000	20000	20000
Nominal diameter (mm)	600	800	900	1000	1200
Accuracy Class	1				
Indicating range (m ³)	9.999.999	99.999.999			
Verification scale interval (m ³)	0,1				

Electronic revision number

The electronic revision number is used to lay down the software version and the hardware of the instrument. If either changes, the number is updated.

- Approved electronic revision numbers: 3.2.4_ ; 3.2.6_ ; 3.2.7_ ; 3.3.0_ ; 3.3.1_ ; 3.3.2_ ; 3.3.3_ and 3.3.5_.

The electronic revision number is stored under menu items B3.6 and C5.1.6. See the manual in how to access the parameters.

Software specification:

The first approved version of the water meter didn't have an electronic revision number. The approved software version is identified as:

- Main software: 2.2.1. Menu items B3.3 and C5.1.5
- User interface: 3.1.0. Menu item B3.4 and C5.2.5

See the manual in how to access the parameters.



OIML Certificate of Conformity

OIML Member State
The Netherlands

Number R49-1/2006-NL1-13.01 revision 1
Project number 13200194
Page 5 of 5

Revision History

Revision	Date	Change(s)
Initial	24 May 2013	-
1	8 November 2013	Addition of several meter sizes