



Member State of OIML  
United Kingdom of Great Britain  
and Northern Ireland

OIML Certificate No  
R51/2006-GB1-09.02

## OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: **National Weights and Measures Laboratory**  
Address: **Stanton Avenue**  
**Teddington**  
**Middlesex**  
**TW11 0JZ**  
**United Kingdom**

Person responsible:

**Gavin Stones**  
**Deputy Product Certification Manager**

Applicant

Name: **Sparc Systems Ltd**  
Address: **Merebrook Industrial Estate**  
**Hanley Road**  
**Malvern**  
**Worcestershire**  
**WR13 6NP**

Manufacturer of the certified pattern is the Applicant.

Identification of the certified pattern:

**TS 310 checkweigher**  
**Further characteristics see page 2**

This certificate attests the conformity of the above-mentioned pattern (represented by the samples identified in the associated test report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

<b>OIML:</b>	<b>R51</b>
<b>Edition:</b>	<b>2006 (E)</b>
<b>Accuracy class:</b>	<b>XIII(1)</b>

OIML Certificate No  
R51/2006-GB1-09.02

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation.

This certificate does not bestow any form of legal international approval.

The conformity was established by tests described in the associated:

Test report: TR 545 having 39 pages  
Pattern evaluation checklist: P00086 (T1108/0051/0075) having 11 pages

The issuing authority



Mr G Stones

The CIML member



Mr P Mason

Date: 08 April 2009

Ref: T1108/0051

Characteristics: Mains-powered automatic checkweighing instrument designated the TS310.

Designation	TS310 – 3 kg	TS310 – 6 kg	TS310 – 15 kg
Maximum capacity:	3000 g	6000 g	15000 g
Minimum capacity (Min):	50 g	100 g	250 g
Scale interval:	1 g	2 g	5 g
Maximum number of scale intervals:	3000		
Load cell excitation voltage	4.7 Vdc		
Tare:	- 500 g	- 1000 g	- 2500 g
Accuracy class	XIII(1)		
Maximum rate operation	50-150 g: 104 packs/min 151 – 3000 g: 132 packs/min	100-300 g: 104 packs/min 302 – 6000 g: 132 packs/min	250-750 g: 104 packs/min 755 – 15000 g: 132 packs/min
Maximum belt speed:	50-150 g: 26 m/min 151 – 3000 g: 33 m/min	100-300 g: 26 m/min 302 – 6000 g: 33 m/min	250-750 g: 26 m/min 755 – 15000 g: 33 m/min
Climatic environment	0°C to +40 °C		
	Non-condensing (closed)		
Electromagnetic environments	E1 and E2		
Power supply	230 Va.c. - 50 Hz		
Pneumatic pressure	6 bar		

Load cell:

The load cell may be one of the following:

Designation	TS310 – 3 kg	TS310 – 6 kg		TS310 – 15 kg
Load cell	HBM PW22C3	HBM PW22C3	HBM PW16AC3	HBM PW16AC3
E <sub>max</sub>	20 kg	30 kg	30 kg	50 kg

Any compatible load cell(s) may be used providing the following conditions are met:

- There is a respective OIML Certificate of Conformity (R60) issued for the load cell.
- The certificate contains the load cell types and the necessary load cell data required for the manufacturer's declaration of compatibility of modules and any particular installation requirements. A load cell marked NH is allowed only if humidity testing to R76 has been conducted on this load cell.
- It is not a load cell with digital output
- The characteristics of the replacement load cell such as n<sub>lc</sub>, Y, Z are the same or better than the load cell tested dynamically (HBM PW22 C3, capacity 20 kg)
- The design of the load cells and the material are the same
- No oil damper is used

Devices:

- Automatic zero setting device active during automatic operation (at least every 7 min if no zero-tracking can take place) ( $\leq 4\%$  max)
- Semi-automatic zero-setting ( $\leq 4\%$  max)
- Initial zero-setting ( $\leq 4\%$  max)
- Zero tracking ( $\leq 4\%$  max)
- Pre-set tare device (subtractive)
- Static calibration, not accessible to the user
- Belt speed setting, accessible to the user (access password protected)
- Internal memory for storage of batch data
- Screen check at power-up
- High resolution mode (0.1e) for testing purposes, not accessible to the user

Interfaces:

- Ethernet

Important note: Apart from the mention of the certificate's reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or of the associated test report is not permitted, though they may be reproduced in full.