

**Member State of OIML  
United Kingdom of Great Britain  
and Northern Ireland**

**OIML Certificate No  
R60/2000-GB1-10.08**

Issuing authority

Name: **National Weights and Measures Laboratory  
(Part of the National Measurement Office)**  
Address: **Stanton Avenue  
Teddington  
Middlesex, TW11 0JZ  
United Kingdom**

Person responsible: **Paul Dixon – Product Certification Manager**

Applicant

Name: **Danlesco Gulf LLC**  
Address: **P.O.Box: 50468  
Dubai  
U.A.E**

Manufacturer of the certified pattern is:

**The applicant**

Identification of the certified pattern:

**Stainless steel compression strain gauge load cell**

Model Designation	DGCP					
Maximum capacity, $E_{\max}$ (t)	18	20	25	30	35	50
Accuracy class	C4					
Maximum number of load cell intervals, $n_{\max}$	4000					
Minimum verification interval, $V_{\min}$	$E_{\max} / 15000$					
Apportionment factor; $p_{LC}$	0.70					

This certificate attests the conformity of the above-mentioned pattern (represented by the samples identified in the associated test report) with the requirements of the following Recommendation of the International Organisation of Legal Metrology -OIML):

**R 60 Metrological regulation for load cells Edition: 2000 (E) for accuracy class : C4**

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation.

# OIML Certificate No R60/2000-GB1-10.08

This certificate does not bestow any form of legal international approval.

The conformity was established by tests described in the associated:

Test report: 08/34505217/L having 29 pages (issued by LGAI)

Note: Model DGCP is compatible with the CP8 model as detailed in the test report.

Issuing authority



Mr P Dixon  
for NWML

CIML member



Mr P Mason

Date 21 December 2010

Ref: TS13/0003

### Essential technical data

<i>Model designation</i>	<i>Designation</i>	<i>Value</i>	<i>Units</i>
Classification		C4	
Additional marking		CH	
Maximum number of load cell verification intervals	$n_{LC}$	4000	
Maximum capacity	$E_{max}$	18, 20, 25, 30, 35, 50	t
Minimum dead load, relative	$E_{min}/E_{max}$	0	t
Relative $V_{min}$ (ratio to minimum LC verification interval)	$Y = E_{max}/V_{min}$	15000	
Relative DR (ratio to minimum dead load output return)	$Z = E_{max}/(2*DR)$	4000	
Rated output		2	mV/V
Maximum excitation voltage		18	V DC
Input impedance (for strain gauge LCs)	$R_{LC}$	800	$\Omega$
Temperature rating		-10/+40	$^{\circ}C$
Safe overload, relative	$E_{lim}/E_{max}$	125	% F.S
Cable length (maximum)		15	m
Additional characteristics		4 or 6 wire (plus screen)	

### Certificate History

ISSUE NO.	DATE	DESCRIPTION
R60/2000-GB1-10.08	21 December 2010	Type approval first issued
-	-	No revisions have been issued

Important note: Apart from the mention of the certificate's reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or of the associated test report is not permitted, though they may be reproduced in full.