



Member State of OIML  
Japan



OIML Certificate No.  
R60/2000-JP1-11.01  
Revision 1

## OIML CERTIFICATE OF CONFORMITY

### Issuing authority

Name: National Metrology Institute of Japan / National Institute of  
Advanced Industrial Science and Technology (NMIJ / AIST)  
Address: AIST Tsukuba Central 3-9, Tsukuba Ibaraki 305-8563, Japan  
Person responsible: Dr. Tamotsu Nomakuchi, President of AIST

### Applicant

Name: YAMATO SCALE CO., LTD.  
Address: 5-22, Saenba-cho, Akashi, Hyogo, 673-8688, Japan

### Manufacturer of the certified pattern

Name: YAMATO SCALE CO., LTD.  
Address: 5-22, Saenba-cho, Akashi, Hyogo, 673-8688, Japan

### Identification of the certified pattern:

Compression load cell  
Type: DCC1-20T, DCC1-24T, DCC1-36T  
Fraction:  $\pi=0.7$   
Temperature range:  $-10\text{ }^{\circ}\text{C} / 40\text{ }^{\circ}\text{C}$



Member State of OIML  
Japan

OIML Certificate No.  
R60/2000-JP1-11.01  
Revision 1

Characteristics:

Model designation			DCC1-20T	DCC1-24T	DCC1-36T
Accuracy class	Class	-	C		
Maximum number of load cell verification intervals	$n_{max}$	-	6000		
			5000		
			4000		
			3000		
Humidity symbol			CH		
Minimum dead load	$E_{min}$	kg	0		
Maximum capacity	$E_{max}$	kg	20000	24000	36000
Safe load limit	$E_{lim}$	kg	1.5* $E_{max}$		
Minimum verification interval	$v_{min}$	kg	$E_{max}/12000$		
Apportionment factor	$p_{LC}$		0.7		
Ratio of minimum LC Verification interval $Y=E_{max} / v_{min}$	$Y$	-	12000		
Ratio of minimum dead load output return $Z=E_{max}/(2*DR)$	$Z$	-	6000 in the case of $n_{max}=6000$		
Maximum excitation voltage		V DC	15		
Cable detail		-	20m (maximum) 4 wire		

This certificate attests the conformity of the above-mentioned pattern (represented by the samples identified in the associated test report(s) with the requirements of the following Recommendation of the International Organization of Legal Metrology - OIML):

R60, edition 2000 (E)  
For accuracy class C

This certificate relates only to the metrological and technical characteristics of the pattern of the instrument concerned, as covered by the relevant OIML International Recommendation.

This certificate does not bestow any form of legal international approval.

The conformity was established by tests described in the associated test report no. 11-09/R60:2000, that includes 26 pages.



Member State of OIML  
Japan



OIML Certificate No.  
R60/2000-JP1-11.01  
Revision 1

The Issuing Authority  
NMIJ/AIST



Dr. T. Nomakuchi  
President of AIST  
2011-11-09

The OIML member

Dr. Y. Miki  
2011-11-09

Important note: Apart from the mention of certificate's reference number and the name of the OIML Member State in which the certificate was issued, partial quotation of the certificate or the associated test report is not permitted, though they may be reproduced in full.



# Evaluation Report

Load cells

## Issuing Authority

Name : National Metrology Institute of Japan /National Institute  
of Advanced Industrial Science and Technology (NMIJ/AIST)

Address : AIST Tsukuba Central 3, Tsukuba Ibaraki 305-8563, Japan

Applicant : YAMATO SCALE CO., LTD.

Manufacturer : YAMATO SCALE CO., LTD.

Applied Type : DCC1-20T, DCC1-24T, DCC1-36T

Evaluation Report Number : 23-006

This report ensures the conformity of the applied type with the requirements of the OIML R60 (edition 2000), on the basis of evaluation of the attached test report (N° 11-09/R60:2000).

Evaluator :

Wataru Kaminaga  
Legal Metrology Division  
NMIJ/AIST

Signature :

*W. Kaminaga*

Date:

*2011. 11. 07*

Supervisor :

Shigeki Yamaguchi  
Head of Legal Metrology Division  
NMIJ/AIST

Signature :

*Shigeki Yamaguchi*

Date:



*2011. 11. 07*

# Description

## Technical data

Model designation			DCC1-20T	DCC1-24T	DCC1-36T
Accuracy class	Class	-	C		
Maximum number of load cell verification intervals	$n_{max}$	-	6000		
			5000		
			4000		
			3000		
Humidity symbol			CH		
Minimum dead load	$E_{min}$	kg	0		
Maximum capacity	$E_{max}$	kg	20000	24000	36000
Safe load limit	$E_{lim}$	kg	$1.5 * E_{max}$		
Minimum verification interval	$v_{min}$	kg	$E_{max}/12000$		
Apportionment factor	$p_{LC}$		0.7		
Ratio of minimum LC Verification interval $Y = E_{max} / v_{min}$	Y	-	12000		
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	Z	-	6000 in the case of $n_{max}=6000$		
Maximum excitation voltage		V DC	15		
Cable detail		-	20m (maximum) 4 wire		

Type	DCC1 Series
------	-------------





	A	B	C
DCC1-20T	100	82	135.5
DCC1-24T	100	82	135.5
DCC1-36T	120	82	135.5


Unit:mm

Type	DCC1 Series
------	-------------

Inside Structure




material : stainless steel




Control Board  
A/D Converter Circuit




Central Board  
 CPU Circuit



Control Board  
Power supply Circuit



Type	DCC1 Series
------	-------------



Type	DCC1 Series
------	-------------

Name Plate

Yamato LOAD CELL	
MODEL NO.	
SERIAL NO.	
CAP.	† DATE
YAMATO SCALE CO., LTD. AKASHI, JAPAN	

Emax



National Metrology Institute of Japan



Metrological regulation for load cells :  
Test report

Project number : LC-OIML-11-010  
Test report number : 11-09 / R60:2000  
Issuing authority : National Metrology Institute of Japan /National Institute of  
Advanced Industrial Science and Technology (NMIJ/AIST)  
AIST Tsukuba Central 3 Tsukuba Ibaraki 305-8563, Japan  
Applicant : YAMATO SCALE CO.,LTD.  
Manufacturer : YAMATO SCALE CO.,LTD.  
Date of application : 2011.9.13  
End of evaluation : 2011.10.27  
Date of issue : *2011.10.31*  
Signature : *Y. Koyano*

Yasuhiro Koyano  
Chief of Legal Weighing Metrology Section  
Mechanical Metrology Division

**OIML R60**  
Edition 2000(E)

**Testing authority**

Name: National Metrology Institute of Japan  
 Address: Central 3-1, 1-1-1 Umezono, Tsukuba, Ibaraki, 305-8563, Japan  
 Contact information: Telephone: +81 29 861 4389 Fax: +81 29 861 4341

**Applicant/Manufacturer information**

Application no.: 23-006  
 Application date: 2011.9.13  
 Model designation: DCC1-\*\*T

Manufacturer: YAMATO SCALE CO.,LTD.  
 Address: 5-22 SAENBA-CHO, AKASHI, 673-8688 JAPAN

Applicant: YAMATO SCALE CO.,LTD.  
 Address: 5-22 SAENBA-CHO, AKASHI, 673-8688 JAPAN

Representative: AKIO HIROSE  
 (name, telephone) +81 78 918 5542

Instrument category: Load cell:      Strain guage      Documentation no.:                     

**Information concerning the pattern**

Accuracy class:  A  B  C  D

Maximum number of load cell verification intervals ( $n_{max}$ ): 6000

Direction of loading: (for load cell characterization, see 4.6.3)

Tension  Beam (shear)  Compression  
 Universal  Beam (bending)

Safe load limit (Lim): 30 t Apportionment factor,  $p_{LC}$  (see Note) 0.7

Limits of working temperature: (only if other than  $-10^{\circ}\text{C}$  to  $+40^{\circ}\text{C}$ , see 5.5.1.1)

Upper:       $^{\circ}\text{C}$  Lower:       $^{\circ}\text{C}$

Power voltage:  $V_{min}$  8 V  $V_{max}$  15 V

or V:      V  AC  DC Recommended:  AC  DC

Humidity evaluation symbol: NH  Yes  No  
 SH  Yes  No  
 CH or no markings  Yes  No

Electronic load cell:  Yes  No

Note: This value of  $p_{LC}$  is assumed to be 0.7 unless otherwise declared by the manufacturer.

**Information concerning the pattern (continued)**

Application No: 23-006

Specify other conditions that must be observed to obtain the specified performance  
(for example, electrical characteristics of the load cell):

Various designs within model range:

Maximum capacity $E_{max}$ (kg)	Minimum load cell verification $V_{min}$ (kg)	Minimum dead load $E_{min}$ (kg)	Maximum number of load cell intervals $n_{max}$	Minimum dead load output return DR (kg)
20000	1.666	0	6000	1.666
24000	2	0	6000	2
36000	3	0	6000	3

All values in this table are taken from documentation pages \_\_\_\_\_.

DR information required only when applicable.

Load cell(s) submitted:

Model designation	Serial number	$E_{max}$ (kg)
DCC1-20T	24071009	20000

Secondary equipment (specify load adapters, etc.):

Remarks:

**General information concerning test conditions**

Ref.:A3

Application no.: 23-006Load cell model: DCC1-20T Serial no.: 24071009  $E_{max}$ : 20000 kg  
 $n_{max}$ : 6000  $v_{min}$ : 1.666 kg DR (if applicable): 1.666 kgForce-generating system - description: Load cell performance testing device  
(see Note)Minimum test load: 0 kgIndicating instrument - description: YAMATO EDI-901Environmental equipment - description: Walk-in type temperature & humidity chamber EBL-1Temperature: 19.9 °CRelative humidity: 42.7 ~ 43.0 %Barometric pressure: 100.54 ~ 102.04 kPaTest location: East 3B 01112Acceleration of gravity at test location: 9.79949 m/sec<sup>2</sup>Evaluator: Fukuda*Note* : Include information concerning accuracy (for example, accredited laboratory).



**Summary of the test**

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 $E_{max}$ : 20000 kg  
 $v_{min}$ : 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

$n_{max}$ : 6000  
 DR: 1.666 kg  
 $p_{LC}$ : 0.7

No.	Test description	Passed	Failed	Report page	Remarks
D.2	Load cell errors ( $E_L$ )	×		10	
D.3	Repeatability errors ( $E_R$ )	×		11	
D.4	Temperature effects on MDLO ( $C_M$ )	×		12	
D.5	Creep ( $C_C$ )	×		13-16	
D.5	DR( $C_{DR}$ )	×		13-16	(see Note 2) DR: 1.50 kg
D.6	Barometric pressure effects ( $C_p$ )	×		17	
D.7	Humidity effects (CH or no mark) ( $C_{Hmin}$ )	×		18	
D.7	Humidity effects (CH or no mark) ( $C_{Hmax}$ )	×		18	
D.8	Humidity effects (SH)				NA
D.9	Marking requirements	See Page 19, Check that marked values are correct.			
D.10	Load cells equipped with electronics	×		20	
D.11	Warm-up time	×		21	
D.12	Power voltage variations	×		22	
D.13	Short time power reductions				NA
D.14	Bursts (electrical fast transients)				NA
D.15	Electrostatic discharge				NA
D.16	Electromagnetic susceptibility				NA
D.17	Span stability	×		23-26	

The following table checks the required calculations as per the General notes provisions of C.4:

Paragraph No.	Description	$n_{max}$		$n_{max}-500$		$n_{max}-1000$	
		Pass	Fail	Pass	Fail	Pass	Fail
C.4.2, C.4.3, C.4.5	Check all calculations using values of $n$ at $n_{max}$ and at lower than $n_{max}$	×		×		×	
C.4.4	Check that $v_{min} \leq \frac{D_{max}-D_{min}}{n_{max}}$	Pass		Fail			
		×					

Worst case figure for minimum dead load output return error (in mass units) = DR = 1.50 kg see Note 3

- Notes:
- 1 Enter "NA" for "the test is not applicable".
  - 2 Record error to accommodate OIML R76.
  - 3 This DR value is used in association with OIML R 76.

**Form D.1 (3 runs) Load test data ( $E_L$ )**

Ref.: A.4.1.1 to A.4.1.11. Complete one sheet for each test temperature, one for each humidity (SH) test in A.4.6, and when applicable, one for each electronics power voltage in A.4.7.3.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 $E_{max}$ : 20000 kg  
 $n_{max}$ : 6000  
 $V_{min}$ : 1.666 kg  
 PLC: 0.7 DR: 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

	At start	At end	
Date:	2011/9/20	2011/9/20	
Temperature:	19.9	19.9	°C
Relative humidity:	42.9	43.0	%
Barometric pressure:	100.54	100.54	kPa
Indicator temperature:	27.0	27.0	°C

Electronics power voltage  
 (when applicable): \_\_\_\_\_ V

**Table D.1 (3 runs)**

Test load (kg)	Run no. 1		Run no. 2		Run no. 3		Average indication (count)	Repeatability error (count)
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-3.0	14:21:17						
20000	19988.8	14:22:07						
0	-2.5	14:22:57						
20000	19989.0	14:23:48						
0	-2.5	14:24:38						
20000	19989.0	14:25:28						
0	-2.6	14:26:18						
0	-3.0	14:31:17	-3.0	14:44:56	-3.0	14:58:36	-3.00	0.00
1000	996.1	14:31:47	996.1	14:45:26	996.2	14:59:06	996.13	0.10
2000	1995.6	14:32:17	1995.6	14:45:56	1995.7	14:59:36	1995.63	0.10
4000	3994.8	14:32:57	3994.7	14:46:36	3994.8	15:00:16	3994.77	0.10
6000	5993.0	14:33:37	5993.0	14:47:16	5993.1	15:00:56	5993.03	0.10
8000	7992.7	14:34:17	7992.8	14:47:56	7992.9	15:01:36	7992.80	0.20
10000	9991.9	14:34:57	9992.0	14:48:36	9992.1	15:02:16	9992.00	0.20
12000	11991.1	14:35:37	11991.2	14:49:16	11991.3	15:02:56	11991.20	0.20
14000	13990.3	14:36:17	13990.2	14:49:56	13990.4	15:03:36	13990.30	0.20
16000	15989.3	14:36:57	15989.3	14:50:36	15989.5	15:04:16	15989.37	0.20
20000	19987.1	14:37:37	19987.1	14:51:16	19987.3	15:04:56	19987.17	0.20
16000	15989.2	14:38:17	15989.2	14:51:56	15989.4	15:05:36	15989.27	0.20
14000	13989.8	14:38:57	13989.8	14:52:36	13989.9	15:06:16	13989.83	0.10
12000	11990.5	14:39:37	11990.5	14:53:16	11990.6	15:06:56	11990.53	0.10
10000	9991.4	14:40:17	9991.4	14:53:56	9991.5	15:07:36	9991.43	0.10
8000	7992.3	14:40:57	7992.3	14:54:36	7992.4	15:08:16	7992.33	0.10
6000	5993.3	14:41:37	5993.3	14:55:16	5993.4	15:08:56	5993.33	0.10
4000	3994.4	14:42:17	3994.5	14:55:56	3994.5	15:09:36	3994.47	0.10
2000	1995.7	14:42:57	1995.7	14:56:36	1995.8	15:10:16	1995.73	0.10
1000	996.2	14:43:27	996.3	14:57:06	996.3	15:10:46	996.27	0.10
0	-2.9	14:43:57	-2.9	14:57:36	-2.8	15:11:16	-2.87	0.10

Notes: 1 \* = Average initial minimum test load indication.  
 2 Absolute (not relative) time shall be recorded.

**Form D.1 (3 runs) Load test data (E<sub>L</sub>)**

Ref.: A.4.1.1 to A.4.1.11. Complete one sheet for each test temperature, one for each humidity (SH) test in A.4.6, and when applicable, one for each electronics power voltage in A.4.7.3.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 p<sub>Lc</sub>: 0.7 DR: 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

	At start	At end	
Date:	2011/9/21	2011/9/21	
Temperature:	40.1	40.1	°C
Relative humidity:	33.4	33.8	%
Barometric pressure:	99.87	99.82	kPa
Indicator temperature:	27.2	27.2	°C

Electronics power voltage  
 (when applicable): \_\_\_\_\_ V

**Table D.1 (3 runs)**

Test load (kg)	Run no. 1		Run no. 2		Run no. 3		Average indication (count)	Repeatability error (count)
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-2.3	9:11:00						
20000	19989.4	9:11:51						
0	-1.6	9:12:41						
20000	19989.9	9:13:30						
0	-1.6	9:14:20						
20000	19990.1	9:15:10						
0	-1.6	9:16:01						
0	-1.9	9:21:00	-1.7	9:34:40	-1.6	9:48:20	-1.73 *	0.30
1000	997.4	9:21:30	997.5	9:35:10	997.6	9:48:50	997.50	0.20
2000	1996.8	9:22:00	1997.0	9:35:40	1997.0	9:49:20	1996.93	0.20
4000	3996.1	9:22:40	3996.2	9:36:20	3996.3	9:50:00	3996.20	0.20
6000	5994.5	9:23:20	5994.5	9:37:00	5994.7	9:50:40	5994.57	0.20
8000	7994.3	9:24:00	7994.3	9:37:40	7994.6	9:51:20	7994.40	0.30
10000	9993.6	9:24:40	9993.5	9:38:20	9993.8	9:52:00	9993.63	0.30
12000	11992.7	9:25:20	11992.7	9:39:00	11992.9	9:52:40	11992.77	0.20
14000	13991.8	9:26:00	13991.8	9:39:40	13992.0	9:53:20	13991.87	0.20
16000	15990.8	9:26:40	15990.8	9:40:20	15991.0	9:54:00	15990.87	0.20
20000	19988.3	9:27:20	19988.2	9:41:00	19988.5	9:54:40	19988.33	0.30
16000	15990.5	9:28:00	15990.5	9:41:40	15990.7	9:55:20	15990.57	0.20
14000	13991.1	9:28:40	13991.1	9:42:20	13991.3	9:56:00	13991.17	0.20
12000	11991.9	9:29:20	11991.9	9:43:00	11992.1	9:56:40	11991.97	0.20
10000	9992.8	9:30:00	9992.8	9:43:40	9993.0	9:57:20	9992.87	0.20
8000	7993.7	9:30:40	7993.7	9:44:20	7993.9	9:58:00	7993.77	0.20
6000	5994.6	9:31:20	5994.7	9:45:00	5994.8	9:58:40	5994.70	0.20
4000	3995.8	9:32:00	3995.8	9:45:40	3995.9	9:59:20	3995.83	0.10
2000	1997.0	9:32:40	1997.1	9:46:20	1997.1	10:00:00	1997.07	0.10
1000	997.5	9:33:10	997.5	9:46:50	997.6	10:00:30	997.53	0.10
0	-1.7	9:33:40	-1.6	9:47:20	-1.5	10:01:00	-1.60	0.20

Notes: 1 \* = Average initial minimum test load indication.  
 2 Absolute (not relative) time shall be recorded.

**Form D.1 (3 runs) Load test data (E<sub>L</sub>)**

Ref.: A.4.1.1 to A.4.1.11. Complete one sheet for each test temperature, one for each humidity (SH) test in A.4.6, and when applicable, one for each electronics power voltage in A.4.7.3.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 P<sub>L</sub>: 0.7 DR: 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

	At start	At end	
Date:	2011/9/22	2011/9/22	
Temperature:	-10.4	-10.3	°C
Relative humidity:	52.1	53.0	%
Barometric pressure:	99.31	99.39	kPa
Indicator temperature:	26.1	26.1	°C

Electronics power voltage (when applicable): \_\_\_\_\_ V

**Table D.1 (3 runs)**

Test load (kg)	Run no. 1		Run no. 2		Run no. 3		Average indication (count)	Repeatability error (count)
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-1.3	9:15:00						
20000	19991.2	9:15:50						
0	0.1	9:16:41						
20000	19991.8	9:17:31						
0	0.1	9:18:22						
20000	19991.5	9:19:12						
0	0.2	9:20:02						
0	-0.6	9:25:03	-0.2	9:38:42	-0.1	9:52:21	-0.30	0.50
1000	998.8	9:25:33	999.2	9:39:12	999.3	9:52:51	999.10	0.50
2000	1998.1	9:26:03	1998.5	9:39:42	1998.6	9:53:21	1998.40	0.50
4000	3997.2	9:26:43	3997.5	9:40:22	3997.6	9:54:01	3997.43	0.40
6000	5995.5	9:27:23	5995.8	9:41:02	5995.9	9:54:41	5995.73	0.40
8000	7995.3	9:28:03	7995.6	9:41:42	7995.8	9:55:21	7995.57	0.50
10000	9994.6	9:28:43	9994.9	9:42:22	9995.0	9:56:01	9994.83	0.40
12000	11993.8	9:29:23	11994.2	9:43:02	11994.2	9:56:41	11994.07	0.40
14000	13993.2	9:30:03	13993.5	9:43:42	13993.5	9:57:21	13993.40	0.30
16000	15992.6	9:30:43	15992.8	9:44:22	15992.9	9:58:01	15992.77	0.30
20000	19991.0	9:31:23	19991.2	9:45:02	19991.2	9:58:41	19991.13	0.20
16000	15992.9	9:32:03	15993.0	9:45:42	15993.1	9:59:21	15993.00	0.20
14000	13993.3	9:32:43	13993.5	9:46:22	13993.6	10:00:01	13993.47	0.30
12000	11994.0	9:33:23	11994.2	9:47:02	11994.3	10:00:41	11994.17	0.30
10000	9994.9	9:34:03	9995.1	9:47:42	9995.1	10:01:21	9995.03	0.20
8000	7995.8	9:34:43	7995.9	9:48:22	7996.0	10:02:01	7995.90	0.20
6000	5996.7	9:35:23	5996.8	9:49:02	5996.9	10:02:41	5996.80	0.20
4000	3997.8	9:36:03	3998.0	9:49:42	3998.1	10:03:21	3997.97	0.30
2000	1999.1	9:36:43	1999.2	9:50:22	1999.3	10:04:01	1999.20	0.20
1000	999.6	9:37:13	999.7	9:50:52	999.8	10:04:31	999.70	0.20
0	0.0	9:37:43	0.1	9:51:22	0.1	10:05:01	0.07	0.10

Notes: 1 \* = Average initial minimum test load indication.  
 2 Absolute (not relative) time shall be recorded.

**Form D.1 (3 runs) Load test data (E<sub>L</sub>)**

Ref.: A.4.1.1 to A.4.1.11. Complete one sheet for each test temperature, one for each humidity (SH) test in A.4.6, and when applicable, one for each electronics power voltage in A.4.7.3.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 PLC: 0.7 DR: 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

	At start	At end	
Date:	2011/9/26	2011/9/26	
Temperature:	19.9	19.9	°C
Relative humidity:	42.9	42.7	%
Barometric pressure:	102.04	102.01	kPa
Indicator temperature:	26.2	26.1	°C

Electronics power voltage (when applicable): \_\_\_\_\_ V

**Table D.1 (3 runs)**

Test load (kg)	Run no. 1		Run no. 2		Run no. 3		Average indication (count)	Repeatability error (count)
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-4.1	9:11:38						
20000	19987.9	9:12:28						
0	-3.3	9:13:18						
20000	19987.8	9:14:08						
0	-3.3	9:14:58						
20000	19987.6	9:15:48						
0	-3.3	9:16:38						
0	-3.7	9:21:37	-3.5	9:35:16	-3.5	9:48:56	-3.57	0.20
1000	995.5	9:22:07	995.5	9:35:46	995.6	9:49:26	995.53	0.10
2000	1994.9	9:22:37	1995.0	9:36:16	1995.1	9:49:56	1995.00	0.20
4000	3994.1	9:23:17	3994.1	9:36:56	3994.2	9:50:36	3994.13	0.10
6000	5992.9	9:23:57	5993.0	9:37:36	5993.0	9:51:16	5992.97	0.10
8000	7992.1	9:24:37	7992.2	9:38:16	7992.3	9:51:56	7992.20	0.20
10000	9991.4	9:25:17	9991.4	9:38:56	9991.4	9:52:36	9991.40	0.00
12000	11990.5	9:25:57	11990.5	9:39:36	11990.7	9:53:16	11990.57	0.20
14000	13989.7	9:26:37	13989.7	9:40:16	13989.8	9:53:56	13989.73	0.10
16000	15988.8	9:27:17	15988.8	9:40:56	15988.9	9:54:36	15988.83	0.10
20000	19986.6	9:27:57	19986.6	9:41:36	19986.6	9:55:16	19986.60	0.00
16000	15988.7	9:28:37	15988.7	9:42:16	15988.8	9:55:56	15988.73	0.10
14000	13989.2	9:29:17	13989.2	9:42:56	13989.3	9:56:36	13989.23	0.10
12000	11990.0	9:29:57	11990.0	9:43:36	11990.0	9:57:16	11990.00	0.00
10000	9990.8	9:30:37	9990.9	9:44:16	9990.9	9:57:56	9990.87	0.10
8000	7991.7	9:31:17	7991.8	9:44:56	7991.8	9:58:36	7991.77	0.10
6000	5992.7	9:31:57	5992.7	9:45:36	5992.7	9:59:16	5992.70	0.00
4000	3993.8	9:32:37	3993.9	9:46:16	3994.0	9:59:56	3993.90	0.20
2000	1995.1	9:33:17	1995.2	9:46:56	1995.2	10:00:36	1995.17	0.10
1000	995.6	9:33:47	995.7	9:47:26	995.7	10:01:06	995.67	0.10
0	-3.5	9:34:17	-3.4	9:47:56	-3.4	10:01:36	-3.43	0.10

Notes: 1 \* = Average initial minimum test load indication.  
 2 Absolute (not relative) time shall be recorded.

**Form D.2 Load cell errors (E<sub>L</sub>) calculation**

Ref.: 5.1.1; A.4.1.12 to A.4.1.14; C.2.2.

Application no.:	23-006		At start	At end		
Load cell model:	DCC1-20T		Date:	2011/9/20	2011/9/26	
Serial no.:	24071009		Test temperature:	19.9	19.9	°C
E <sub>max</sub> :	20000 kg		Relative humidity:	42.9	42.7	%
π <sub>max</sub> :	6000		Barometric pressure:	100.54	102.01	kPa
V <sub>min</sub> :	1.666 kg		Indicator temperature:	27.0	26.1	°C
P <sub>Lc</sub> :	0.7	DR: 1.666 kg				
Force-generating system:	Load cell performance testing device	Conversion factor, f:	3.33			
Indicating instrument:	YAMATO EDI-901	75% test load (g, kg or t):	15000 kg			
Evaluator:	Fukuda	Reference indication at 75% test load:	14992.63			

**Table D.2**

Test load (kg)	Reference indication (count)	19.9 °C (20°C)		40.1 °C(40°C)		-10.3 °C(-10°C)		19.9 °C(20°C)		mpe (V)
		Indication (count)	Error(E <sub>L</sub> ) (V)	Indication (count)	Error(E <sub>L</sub> ) (V)	Indication (count)	Error(E <sub>L</sub> ) (V)	Indication (count)	Error(E <sub>L</sub> ) (V)	
0	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.35
1000	999.52	999.13	-0.12	999.23	-0.09	999.40	-0.04	999.10	-0.13	0.35
2000	1999.04	1998.63	-0.12	1998.67	-0.11	1998.70	-0.10	1998.57	-0.14	0.70
4000	3998.09	3997.77	-0.10	3997.93	-0.05	3997.73	-0.11	3997.70	-0.12	0.70
6000	5997.13	5996.03	-0.33	5996.30	-0.25	5996.03	-0.33	5996.53	-0.18	0.70
8000	7996.18	7995.80	-0.11	7996.13	-0.01	7995.87	-0.09	7995.77	-0.12	0.70
10000	9995.22	9995.00	-0.07	9995.37	0.04	9995.13	-0.03	9994.97	-0.08	0.70
12000	11994.27	11994.20	-0.02	11994.50	0.07	11994.37	0.03	11994.13	-0.04	1.05
14000	13993.31	13993.30	0.00	13993.60	0.09	13993.70	0.12	13993.30	0.00	1.05
16000	15992.36	15992.37	0.00	15992.60	0.07	15993.07	0.21	15992.40	0.01	1.05
20000	19990.44	19990.17	-0.08	19990.07	-0.11	19991.43	0.30	19990.17	-0.08	1.05
16000	15992.36	15992.27	-0.03	15992.30	-0.02	15993.30	0.28	15992.30	-0.02	1.05
14000	13993.31	13992.83	-0.14	13992.90	-0.12	13993.77	0.14	13992.80	-0.15	1.05
12000	11994.27	11993.53	-0.22	11993.70	-0.17	11994.47	0.06	11993.57	-0.21	1.05
10000	9995.22	9994.43	-0.24	9994.60	-0.19	9995.33	0.03	9994.43	-0.24	0.70
8000	7996.18	7995.33	-0.25	7995.50	-0.20	7996.20	0.01	7995.33	-0.25	0.70
6000	5997.13	5996.33	-0.24	5996.43	-0.21	5997.10	-0.01	5996.27	-0.26	0.70
4000	3998.09	3997.47	-0.19	3997.57	-0.16	3998.27	0.05	3997.47	-0.19	0.70
2000	1999.04	1998.73	-0.09	1998.80	-0.07	1999.50	0.14	1998.73	-0.09	0.70
1000	999.52	999.27	-0.08	999.27	-0.08	1000.00	0.14	999.23	-0.09	0.35
0	0.00	0.13	0.04	0.13	0.04	0.37	0.11	0.13	0.04	0.35

Minimum test load, D<sub>min</sub>: 0 kgPASS: FAIL: **Notes:**

- 1 Load/reference indications: if a 75% load point was not obtained, a straight line interpolation between the adjacent higher and lower load point indications is used (see 5.2.2 and calculation procedures in C.2.2).
- 2 Error, E<sub>L</sub>: the difference between the test indication and the reference indication divided by the conversion factor, f.
- 3 Test load values are values above minimum test load, D<sub>min</sub>.

**Form D.3 Repeatability errors ( $E_r$ ) calculation**

Ref.: 5.4; A.4.1.13; C.2.3.

Application no.: 23-006

Load cell model: DCC1-20T

Serial no.: 24071009

$E_{max}$ : 20000 kg

$n_{max}$ : 6000

$V_{min}$ : 1.666 kg

$P_{Lo}$ : 0.7                      DR: 1.666 kg

Force-generating system: Load cell performance testing device

Conversion factor, f: 3.33

Indicating instrument: YAMATO EDI-901

Evaluator: Fukuda

**Table D.3**

Test load (kg)	19.9 °C (20°C)		40.1 °C(40°C)		-10.3 °C(-10°C)		19.9 °C(20°C)		mpe (V)
	Repeatability error (count)	Repeatability error (V)	Repeatability error (count)	Repeatability error (V)	Repeatability error (count)	Repeatability error (V)	Repeatability error (count)	Repeatability error (V)	
	0	0.00	0.00	0.30	0.09	0.50	0.15	0.20	
1000	0.10	0.03	0.20	0.06	0.50	0.15	0.10	0.03	0.35
2000	0.10	0.03	0.20	0.06	0.50	0.15	0.20	0.06	0.70
4000	0.10	0.03	0.20	0.06	0.40	0.12	0.10	0.03	0.70
6000	0.10	0.03	0.20	0.06	0.40	0.12	0.10	0.03	0.70
8000	0.20	0.06	0.30	0.09	0.50	0.15	0.20	0.06	0.70
10000	0.20	0.06	0.30	0.09	0.40	0.12	0.00	0.00	0.70
12000	0.20	0.06	0.20	0.06	0.40	0.12	0.20	0.06	1.05
14000	0.20	0.06	0.20	0.06	0.30	0.09	0.10	0.03	1.05
16000	0.20	0.06	0.20	0.06	0.30	0.09	0.10	0.03	1.05
20000	0.20	0.06	0.30	0.09	0.20	0.06	0.00	0.00	1.05
16000	0.20	0.06	0.20	0.06	0.20	0.06	0.10	0.03	1.05
14000	0.10	0.03	0.20	0.06	0.30	0.09	0.10	0.03	1.05
12000	0.10	0.03	0.20	0.06	0.30	0.09	0.00	0.00	1.05
10000	0.10	0.03	0.20	0.06	0.20	0.06	0.10	0.03	0.70
8000	0.10	0.03	0.20	0.06	0.20	0.06	0.10	0.03	0.70
6000	0.10	0.03	0.20	0.06	0.20	0.06	0.00	0.00	0.70
4000	0.10	0.03	0.10	0.03	0.30	0.09	0.20	0.06	0.70
2000	0.10	0.03	0.10	0.03	0.20	0.06	0.10	0.03	0.70
1000	0.10	0.03	0.10	0.03	0.20	0.06	0.10	0.03	0.35
0	0.10	0.03	0.20	0.06	0.10	0.03	0.10	0.03	0.35

PASS:  \*

FAIL:

Note: Error,  $E_r$ : the maximum difference between the three test indications divided by the conversion factor, f (classes C and D) or the maximum difference between the five test indications divided by the conversion factor, f (classes A and B).

**D.4 Temperature effects on MDLO (C<sub>M</sub>) calculation**

Ref.: 5.5.1.3; A.4.1.14; C.2.4.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 PLC: 0.7 DR: 1.666 kg

Force-generating system: Load cell performance testing device Conversion factor, f: 3.33

Indicating instrument: YAMATO EDI-901

Evaluator: Fukuda

**Table D.4**

Temperature °C	Indication (count)	Change (C <sub>M</sub> ) (V)	Change (v <sub>min</sub> /5 °C)	mpc (v <sub>min</sub> /5 °C)
19.9	-3.00			
40.1	-1.73	0.38	0.19	0.70
-10.3	-0.30	0.43	-0.09	0.70
19.9	-3.57	-0.98	-0.32	0.70

PASS:  FAIL:

- Notes:
- 1 MDLO: minimum dead load output.
  - 2 Indication: the average initial minimum test load indication obtained from Table D.1.
  - 3 The maximum permissible change(mpc) allowed is: (v<sub>min</sub>/5°C) for classesB, C, and D; (v<sub>min</sub>/2°C) for class A.
  - 4 Change, C<sub>M</sub>(v): the difference between the observed indications, and the indications at the prior temperature, divided by the conversion factor, f.



**Form D.5 Creep (Cc) and DR (CDR)**

Ref.: 5.3.1, 5.3.2; A.4.2, A.4.3 Complete one sheet for each test temperature.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 $E_{max}$ : 20000 kg  
 $n_{max}$ : 6000  
 $v_{min}$ : 1.666 kg  
 PLC: 0.7 DR: 1.666 kg

	At start	At end	
Date:	2011/9/20	2011/9/20	
Temperature:	19.9	19.9	°C
Relative humidity:	42.9	43.0	%
Barometric pressure:	100.53	100.54	kPa
Indicator temperature:	27.0	27.1	°C

Force generating system: Load cell performance testing device Conversion factor, f: 3.33  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

**Table D.5**

Test load (kg)	Indication (count)	Barometric pressure (kPa)	Time	Change (v)	mpc (v)
0					
0					
0					
0					
(*) → 0	-3.1	100.53	16:11:06		
Fill in time →	Record time of initial loading →		16:11:06		
(**) → 20000	19988.8	100.54	16:11:56	0.00	0.735
20000	19989.1	100.54	16:12:56	0.09	0.735
20000	19989.1	100.54	16:13:56	0.09	0.735
20000	19989.0	100.54	16:14:56	0.06	0.735
20000	19989.1	100.54	16:15:56	0.09	0.735
20000	19989.1	100.54	16:16:56	0.09	0.735
20000	19989.1	100.54	16:17:56	0.09	0.735
20000	19989.1	100.53	16:18:56	0.09	0.735
20000	19989.2	100.53	16:19:56	0.12	0.735
20000	19989.3	100.53	16:20:56	0.15	0.735
20000	19989.3	100.53	16:21:56	0.15	0.735
20000	19989.4	100.54	16:26:56	0.18	0.735
20000	19989.4	100.54	16:31:56	0.18	0.735
20000	19989.5	100.55	16:36:56	0.21	0.735
20000	19989.5	100.54	16:41:56	0.21	0.735
Fill in time →	Record time of initial unloading →		16:41:56		
(***) → 0	-2.6	100.54	16:42:47	0.15	0.500
0	-2.8	100.53	16:43:07	0.09	0.500
0	-2.9	100.54	16:43:27	0.06	0.500
0	-3.0	100.54	16:43:47	0.03	0.500
0	-3.0	100.54	16:44:07	0.03	0.500
0	-3.0	100.54	16:44:27	0.03	0.500
30-20 minute creep difference in units:				0.03	0.1575

DR (v):	0.15	30 minute creep:	PASS:	x	FAIL:	
actual time (s):	51	30-20 minute creep difference:	PASS:	x	FAIL:	
specified time (s):	50	DR ≤ 0.5v:	PASS:	x	FAIL:	
mpc for DR (v):	0.49	DR within manufacturer specified DR requirements:	PASS:	x	FAIL:	

- Notes: 1 Change (v) for creep: the observed indication minus the initial "load" indication (\*\*) divided by the conversion factor, f.  
 2 Determine the difference between the reading obtained at 20 minutes and the reading obtained at 30 minutes (see 5.3.1).  
 3 Change (v) for DR: the initial indication (\*\*\*) minus the initial "no load" indication (\*) divided by the conversion factor, f.  
 4 Absolute (not relative) time shall be recorded.

**Form D.5 Creep (Cc) and DR (CDR)**

Ref.: 5.3.1, 5.3.2; A.4.2, A.4.3 Complete one sheet for each test temperature.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 P<sub>LC</sub>: 0.7 DR: 1.666 kg  
 Force generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

	At start	At end	
Date:	2011/9/21	2011/9/21	
Temperature:	40.1	40.1	°C
Relative humidity:	34.1	33.9	%
Barometric pressure:	99.59	99.50	kPa
Indicator temperature:	27.1	27.1	°C

Conversion factor, f: 3.33

**Table D.5**

Test load (kg)	Indication (count)	Barometric pressure (kPa)	Time	Change (v)	mpc (v)	
0						
0						
0						
0						
(*) →	0	-1.8	99.59	11:00:49		←initial "no load" indication
Fill in time →	Record time of initial loading →			11:00:49		
(**) →	20000	19989.5	99.58	11:01:39	0.00	←initial "load" indication
Constant maximum test load, Dmax	20000	19989.7	99.57	11:02:39	0.06	
	20000	19989.7	99.57	11:03:39	0.06	
	20000	19989.6	99.58	11:04:39	0.03	
	20000	19989.8	99.58	11:05:39	0.09	
	20000	19989.7	99.57	11:06:39	0.06	
	20000	19989.7	99.57	11:07:39	0.06	
	20000	19989.8	99.57	11:08:39	0.09	
	20000	19989.9	99.56	11:09:39	0.12	
	20000	19989.8	99.56	11:10:39	0.09	
	20000	19989.9	99.57	11:11:39	0.12	
	20000	19990.1	99.54	11:16:39	0.18	
	20000	19990.1	99.51	11:21:39	0.18	
20000	19990.2	99.52	11:26:39	0.21		
20000	19990.2	99.52	11:31:39	0.21		
Fill in time →	Record time of initial unloading →			11:31:39		
(***) →	0	-1.2	99.52	11:32:31	0.18	←initial indication
These rows are for reference purposes only	0	-1.4	99.51	11:32:51	0.12	
	0	-1.5	99.51	11:33:11	0.09	
	0	-1.5	99.52	11:33:31	0.09	
	0	-1.5	99.51	11:33:51	0.09	
	0	-1.5	99.51	11:34:11	0.09	
30-20 minute creep difference in units:					0.03	0.1575

DR (v):	0.18	30 minute creep:	PASS:	x	FAIL:	
actual time (s):	52	30-20 minute creep difference:	PASS:	x	FAIL:	
specified time (s):	50	DR ≤ 0.5v:	PASS:	x	FAIL:	
mpc for DR (v):	0.48	DR within manufacturer specified DR requirements:	PASS:	x	FAIL:	

- Notes:
- 1 Change (v) for creep: the observed indication minus the initial "load" indication (\*\*) divided by the conversion factor, f.
  - 2 Determine the difference between the reading obtained at 20 minutes and the reading obtained at 30 minutes (see 5.3.1).
  - 3 Change (v) for DR: the initial indication (\*\*\*) minus the initial "no load" indication (\*) divided by the conversion factor, f.
  - 4 Absolute (not relative) time shall be recorded.

**Form D.5 Creep (Cc) and DR (CDR)**

Ref.: 5.3.1, 5.3.2; A.4.2, A.4.3 Complete one sheet for each test temperature.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 v<sub>min</sub>: 1.666 kg  
 p<sub>LC</sub>: 0.7 DR: 1.666 kg

	At start	At end	
Date:	2011/9/22	2011/9/22	
Temperature:	-10.3	-10.3	°C
Relative humidity:	53.7	54.2	%
Barometric pressure:	99.44	99.43	kPa
Indicator temperature:	26.1	26.1	°C

Force generating system: Load cell performance testing device Conversion factor, f: 3.33  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

**Table D.5**

Test load (kg)	Indication (count)	Barometric pressure (kPa)	Time	Change (v)	mpc (v)	
0						
0						
0						
0						
(*) →	0	-0.8	99.44	11:04:50		←initial "no load" indication
Fill in time →	Record time of initial loading →			11:04:50		
(**) →	20000	19991.3	99.44	11:05:40	0.00	0.735 ←initial "load" indication
Constant maximum test load, Dmax	20000	19992.2	99.44	11:06:40	0.27	0.735
	20000	19992.4	99.44	11:07:40	0.33	0.735
	20000	19992.6	99.44	11:08:40	0.39	0.735
	20000	19992.7	99.44	11:09:40	0.42	0.735
	20000	19992.8	99.44	11:10:40	0.45	0.735
	20000	19992.9	99.44	11:11:40	0.48	0.735
	20000	19992.9	99.44	11:12:40	0.48	0.735
	20000	19993.1	99.43	11:13:40	0.54	0.735
	20000	19993.1	99.43	11:14:40	0.54	0.735
	20000	19993.1	99.43	11:15:40	0.54	0.735
	20000	19993.3	99.42	11:20:40	0.60	0.735
	20000	19993.4	99.42	11:25:40	0.63	0.735
	20000	19993.5	99.42	11:30:40	0.66	0.735
	20000	19993.5	99.42	11:35:40	0.66	0.735
Fill in time →	Record time of initial unloading →			11:35:40		
(***) →	0	0.7	99.43	11:36:32	0.45	0.500 ←initial indication
These rows are for reference purposes only	0	0.5	99.43	11:36:52	0.39	0.500
	0	0.3	99.43	11:37:12	0.33	0.500
	0	0.1	99.43	11:37:32	0.27	0.500
	0	0.1	99.43	11:37:52	0.27	0.500
	0	0.0	99.43	11:38:12	0.24	0.500
30-20 minute creep difference in units:					0.03	0.1575

DR (v):	0.45	30 minute creep:	PASS:	x	FAIL:	
actual time (s):	52	30-20 minute creep difference:	PASS:	x	FAIL:	
specified time (s):	50	DR ≤ 0.5v:	PASS:	x	FAIL:	
mpc for DR (v):	0.48	DR within manufacturer specified DR requirements:	PASS:	x	FAIL:	

- Notes: 1 Change (v) for creep: the observed indication minus the initial "load" indication (\*\*) divided by the conversion factor, f.  
 2 Determine the difference between the reading obtained at 20 minutes and the reading obtained at 30 minutes (see 5.3.1).  
 3 Change (v) for DR: the initial indication (\*\*\*) minus the initial "no load" indication (\*) divided by the conversion factor, f.  
 4 Absolute (not relative) time shall be recorded.

**Form D.5 Creep (Cc) and DR (CDR)**

Ref.: 5.3.1, 5.3.2; A.4.2, A.4.3 Complete one sheet for each test temperature.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 v<sub>min</sub>: 1.666 kg  
 p<sub>LC</sub>: 0.7 DR: 1.666 kg

	At start	At end	
Date:	2011/9/26	2011/9/26	
Temperature:	19.9	19.9	°C
Relative humidity:	42.7	42.9	%
Barometric pressure:	101.96	101.89	kPa
Indicator temperature:	26.1	26.2	°C

Force generating system: Load cell performance testing device Conversion factor, f: 3.33  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

**Table D.5**

Test load (kg)	Indication (count)	Barometric pressure (kPa)	Time	Change (v)	mpc (v)	
0						
0						
0						
0						
(*) →	0	-3.7	101.96	11:01:26		←initial "no load" indication
Fill in time →	Record time of initial loading →			11:01:26		
(**) →	20000	19988.1	101.95	11:02:17	0.00	←initial "load" indication
Constant maximum test load. Dmax	20000	19988.3	101.94	11:03:17	0.06	
	20000	19988.3	101.93	11:04:17	0.06	
	20000	19988.3	101.92	11:05:17	0.06	
	20000	19988.3	101.91	11:06:17	0.06	
	20000	19988.4	101.91	11:07:17	0.09	
	20000	19988.4	101.92	11:08:17	0.09	
	20000	19988.5	101.93	11:09:17	0.12	
	20000	19988.5	101.93	11:10:17	0.12	
	20000	19988.5	101.94	11:11:17	0.12	
	20000	19988.6	101.94	11:12:17	0.15	
	20000	19988.6	101.93	11:17:17	0.15	
	20000	19988.7	101.91	11:22:17	0.18	
20000	19988.8	101.89	11:27:18	0.21		
20000	19988.8	101.90	11:32:18	0.21		
Fill in time →	Record time of initial unloading →			11:32:18		
(***) →	0	-3.1	101.90	11:33:10	0.18	←initial indication
These rows are for reference purposes only	0	-3.4	101.90	11:33:30	0.09	
	0	-3.4	101.90	11:33:50	0.09	
	0	-3.5	101.90	11:34:10	0.06	
	0	-3.5	101.90	11:34:30	0.06	
	0	-3.5	101.90	11:34:50	0.06	
30-20 minute creep difference in units:					0.03	0.1575

DR (v):	0.18	30 minute creep:	PASS:	x	FAIL:	
actual time (s):	51	30-20 minute creep difference:	PASS:	x	FAIL:	
specified time (s):	50	DR ≤ 0.5v:	PASS:	x	FAIL:	
mpc for DR (v):	0.49	DR within manufacturer specified DR requirements:	PASS:	x	FAIL:	

Notes: 1 Change (v) for creep: the observed indication minus the initial "load" indication (\*\*) divided by the conversion factor, f.  
 2 Determine the difference between the reading obtained at 20 minutes and the reading obtained at 30 minutes (see 5.3.1).  
 3 Change (v) for DR: the initial indication (\*\*\*) minus the initial "no load" indication (\*) divided by the conversion factor, f.  
 4 Absolute (not relative) time shall be recorded.

**Form D.6 Barometric pressure effects (Cp)**

Ref.: 5.5.2; A.4.4.

Application no.:	<u>23-006</u>				
Load cell model:	<u>DCC1-20T</u>	Date:	<u>2011/10/26</u>	<u>2011/10/26</u>	
Serial no.:	<u>24071009</u>	Test temperature:	<u>23.4</u>	<u>23.4</u>	°C
E <sub>max</sub> :	<u>20000 kg</u>	Relative humidity:	<u>45.7</u>	<u>44.8</u>	%
n <sub>max</sub> :	<u>6000</u>	Barometric pressure:	<u>101.41</u>	<u>101.41</u>	kPa
V <sub>min</sub> :	<u>1.666 kg</u>	Indicator temperature:	<u>23</u>	<u>23.4</u>	°C
P <sub>LC</sub> :	<u>0.7</u>	DR:	<u>1.666 kg</u>		
Force-generating system:	<u>—</u>	Conversion factor, f:	<u>3.33</u>		
Indicating instrument:	<u>YAMATO EDI-901</u>				
Evaluator:	<u>Fukuda</u>				

**Table D.6**

Pressure (kPa)	Indication (count)	Time	Change (V)	Change (v <sub>min</sub> /kPa)	mpc (v <sub>min</sub> /kPa)
101.41	-4.3	11:00	0.00	0.00	0
102.41	-4.0	11:01	0.09	0.18	1
101.41	-4.3	11:02	-0.09	0.18	1
100.41	-4.8	11:03	-0.15	0.30	1
101.41	-4.3	11:04	0.15	0.30	1

PASS:  FAIL: 

Remarks:

- Notes: 1 Change (v): the difference between the observed indication and the initial indication divided by the conversion factor, f.  
 2 Although A.4.4 specifies a change of only 1 kPa for this test, additional measurements may be taken.  
 3 Absolute (not relative) time shall be recorded.

**Form D.7 Humidity effects (CH or no mark)**

Ref.: 5.5.3.1;A.4.5.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 $E_{max}$ : 20000 kg  
 $n_{max}$ : 6000  
 $V_{min}$ : 1.666 kg  
 $p_{LC}$ : 0.7 DR: 1.666 kg  
 Force generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

	At start	At end	
Date:	2011/10/7	2011/10/24	
Temperature:	20.0	19.9	°C
Relative humidity:	43.1	43.1	%
Barometric pressure:	100.88	101.13	kPa
Indicator temperature:	23.1	20.8	°C
Conversion factor, f:	3.33		

Conditions during damp heat cyclic test:  
 Chamber temp.(high): 40.3 °C Relative humidity: 95.2 %  
 Chamber temp.(low): 24.9 °C Relative humidity: 95.8 %

**Table D.7**

Test load (kg)	Before humidity test		After humidity test		Change (v)	mpc (v)
	Indication (count)	Time	Indication (count)	Time		
0	-4.2	16:08:32	-2.4	9:20:13		
20000	19987.7	16:09:22	19991.3	9:21:03		
0	-3.6	16:10:13	-1.8	9:21:54		
20000	19988.0	16:11:03	19991.7	9:22:44		
0	-3.6	16:11:54	-1.8	9:23:34		
20000	19988.0	16:12:44	19991.8	9:24:25		
0	-3.7	16:13:35	-1.8	9:25:15		
0	-4.0	16:18:39	-2.3	9:30:19		
20000	19988.1	16:19:30	19991.9	9:31:09		
0	-3.6	16:20:20	-1.7	9:32:00		
20000	19988.1	16:21:10	19992.0	9:32:50		
0	-3.6	16:22:01	-1.8	9:33:41		
20000	19988.1	16:22:51	19992.0	9:34:31		
0	-3.6	16:23:42	-1.8	9:35:22		
0						
0						
Average(±)	-3.70		-1.90		0.54	240 ← ≤ 4% $n_{max}$
Average(±)	19988.10		19991.97			
Averages difference(*)	19991.80		19993.87		0.62	1.0

(±) Indications at minimum test load

Change (±), CHmin:

PASS:

PASS:

FAIL:

FAIL:

(±) Indications at maximum test load (see Note 3)

Change (\*), CHmax:

(\*) Average, see 5.5.3.1 and C.2.7

- Notes:
- 1 This test is not necessary if the load cell is marked NH or SH.
  - 2 Change(v): the difference between the after indication and the before indication divided by the conversion factor, f.
  - 3 Use five test runs for classes A and B; use three test runs for classes C and D.
  - 4 Absolute (not relative) time shall be recorded.

**Form D.9 Marking requirements**

Ref.: 4.6, 4.7.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 $E_{max}$ : 20000 kg  
 $n_{max}$ : 6000  
 $v_{min}$ : 1.666 kg  
 $P_{LC}$ : 0.7 DR: 1.666 kg  
 Force-generating system: —  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

**Table D.9.1**

R 60 reference	Mandatory information	On load cell	In document
4.6.1	Accuracy class designation	-	+
4.6.2	Maximum number of load cell verification intervals, $n_{max}$	-	+
4.6.3	Loading designation (if necessary)	-	+
4.6.4	Working temperature designation	-	-
4.6.5.1	Humidity symbol "NH"	/	/
4.6.5.3	Humidity symbol "SH"	/	/
4.6.6.1, 4.7.1	Name or trademark of manufacturer (see Note 1)	+	+
4.6.6.1, 4.7.1	Manufacturer's own designation or load cell model (see Note 1)	+	+
4.6.6.1, 4.7.1	Serial number (see Note 1)	+	+
4.6.6.1	Year of manufacture	+	-
4.6.6.1	Minimum dead load, $E_{min}$	-	+
4.6.6.1, 4.7.1	Maximum capacity, $E_{max}$ (see Note 1)	+	+
4.6.6.1	Safe load limit, $E_{lim}$	-	+
4.6.6.1	Minimum load cell verification interval ( $v_{min}$ )	-	+
4.6.6.1	Other pertinent conditions	-	-
4.6.6.1	Apportionment factor, $P_{LC}$ (if not equal to 0.7)	-	+
4.6.7	Standard classification	-	-
4.6.8	Multiple classifications	-	-

**Table D.9.2**

R 60 reference	Non-mandatory additional information	On load cell	In document
4.6.5.2	Humidity symbol "CH"	/	+
4.6.6.2	Relative $v_{min}$ , Y	-	-
4.6.6.2	Relative DR, Z	-	-

Include references to the following:

Documents supplied with load cells: \_\_\_\_\_

Diagrams showing markings on load cells: \_\_\_\_\_

- Notes:
- 1 Required both on load cell and in document.
  - 2 Indicate that the marking is present with a "+".
  - 3 Indicate that the marking is not present with a "-".
  - 4 Indicate that the marking is not applicable with a "/".

**Form D.10 Summary of results - Load cells equipped with electronics**

Ref.: Clause 6.

Application no.: 23-006

Load cell model: DCC1-20T

Serial no.: 24071009

E<sub>max</sub>: 20000 kgn<sub>max</sub>: 6000V<sub>min</sub>: 1.666 kg

PLC: 1.0 DR: 1.666 kg

Force-generating system: Load cell performance testing device

Indicating instrument: YAMATO EDI-901

Evaluator: Fukuda

**Table D.10 Summary of results**

Test description	Test procedure	Test report form no.	Passed	Failed	Remarks
Warm-up time	A.4.7.2	D11	×		
Power voltage variations	A.4.7.3	D.12	×		
Short time power reductions	A.4.7.4				NA
Bursts(electrical fast transients)	A.4.7.5				NA
Electrostatic discharge	A.4.7.6				NA
Electromagnetic susceptibility	A.4.7.7				NA
Span stability test	A.4.7.8	D.17.1.1,D.17.2	×		

Additional remarks:



**Form D.11 Warm-up time**

Ref.: 6.3.2; A.4.7.2

Application no.:	23-006		At start	At end
Load cell model:	DCC1-20T	Date:	2011/9/28	2011/9/28
Serial no.:	24071009	Time:	6:57:26	7:38:36
E <sub>max</sub> :	20000 kg	Temperature:	20.3	20.3 °C
ρ <sub>max</sub> :	6000	Relative humidity:	43.1	43.0 %
V <sub>min</sub> :	1.666 kg	Barometric pressure:	101.72	101.71 kPa
PLC:	1.0	DR:	1.666 kg	Conversion factor, f:
Force-generating system:	Load cell performance testing device	Minimum test load, D <sub>min</sub> :	0 kg	3.33
Indicating instrument:	YAMATO EDI-901	Maximum test load, D <sub>max</sub> :	20000 kg	
Evaluator:	Fukuda	Duration of disconnection before test:	62 hour	

Table D.2

	Initial run		After 5 min		After 15 min		After 30 min		mpc (V)
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time	
Minimum test load	-2.90	7:07:47	-3.70	7:12:47	-4.00	7:22:46	-4.00	7:37:47	
Maximum test load	19988.80	7:08:37	19988.10	7:13:36	19987.90	7:23:36	19988.00	7:38:36	
Span(count)	19991.70		19991.80		19991.90		19992.00		
Span(v)	6000.38		6000.41		6000.44		6000.47		
Change(v)	0.00		0.03		0.06		0.06		1.50

PASS: FAIL: 

- Notes:
- 1 Absolute (not relative) time shall be recorded.
  - 2 Span: the result of subtracting the indication at minimum test load from the indication at maximum test load. All span errors (error at maximum test load minus the error at minimum test load) shall be within the maximum permissible error during the 30 minute test.
  - 3 Change: the difference between the span and the initial run span.
  - 4 Maximum permissible change, mpc: the absolute value of the maximum permissible error for the maximum test load applied.

**Form D.12 Power voltage variations**

Ref.: 6.3.3, 6.3.4; A.4.7.3.

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 PL<sub>c</sub>: 1.0 DR: 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

Date:	2011/9/29	
Time:	13:34	
Temperature:	20.0	°C
Relative humidity:	42.8	%
Barometric pressure:	101.08	kPa

Conversion factor, f: 3.33  
 Minimum test load, D<sub>min</sub>: 0 kg  
 Maximum test load, D<sub>max</sub>: 20000 kg

Power voltage(A.4.7.3): Mains: 12 V Battery: -

Reference voltage or range(see Note 5): - V  
 Upper limit: 15 V  
 Lower limit: 8 V

**Table D.12**

Test load (kg)	Reference indication (count)	Upper limit		Lower limit		mpe (v)
		Indication (count)	Error (v)	Indication (count)	Error (v)	
0	0.00	0.00	0.00	0.00	0.00	0.50
1000	999.52	999.17	-0.11	999.07	-0.14	0.50
2000	1999.04	1998.57	-0.14	1998.57	-0.14	1.00
4000	3998.09	3997.73	-0.11	3997.70	-0.12	1.00
6000	5997.13	5996.43	-0.21	5996.23	-0.27	1.00
8000	7996.18	7995.83	-0.10	7995.87	-0.09	1.00
10000	9995.22	9995.00	-0.07	9995.00	-0.07	1.00
12000	11994.27	11994.17	-0.03	11993.87	-0.12	1.50
14000	13993.31	13993.37	0.02	13993.33	0.01	1.50
16000	15992.36	15992.37	0.00	15992.40	0.01	1.50
20000	19990.44	19990.13	-0.09	19990.17	-0.08	1.50
16000	15992.36	15992.20	-0.05	15992.23	-0.04	1.50
14000	13993.31	13992.80	-0.15	13992.80	-0.15	1.50
12000	11994.27	11993.50	-0.23	11993.50	-0.23	1.50
10000	9995.22	9994.43	-0.24	9994.43	-0.24	1.00
8000	7996.18	7995.33	-0.25	7995.33	-0.25	1.00
6000	5997.13	5996.33	-0.24	5996.23	-0.27	1.00
4000	3998.09	3997.50	-0.18	3997.43	-0.20	1.00
2000	1999.04	1998.70	-0.10	1998.67	-0.11	1.00
1000	999.52	999.20	-0.10	999.20	-0.10	0.50
0	0.00	0.10	0.03	0.07	0.02	0.50

PASS:  FAIL:

Equipment used (supply sketch if necessary) :

- Notes:
- 1 Upper limit not applicable to battery powered load cells.
  - 2 At lower limit, battery powered load cells shall function and be within mpe, or cease to function.
  - 3 Reference indications: if a 75% load point was not obtained, a straight line interpolation between the adjacent higher and lower load point indications is used (see 5.2.2 and calculation procedures in C.2.2).
  - 4 Error: the difference between the test indication and the reference indication divided by the conversion factor, f
  - 5 When a voltage range is marked, use the average value as the reference value and determine the upper and lower values of applied voltage according to A.4.7.3.

**Form D.17.1.1(3 runs) Span stability-measurement data for classes C and D**

Ref.: 6.3.6:A.4.7.8

Application no.: 23-006

Force-generating system: Load cell performance testing device

Load cell model: DCC1-20T

Indicating instrument: YAMATO EDI-901

Serial no: 24071009

PLC: 1.0 DR: 1.666 kg

 $E_{max}$ : 20000 kg

Conversion factor, f: 3.33

 $n_{max}$ : 6000Minimum test load,  $D_{min}$ : 0 kg $V_{min}$ : 1.666 kgMaximum test load,  $D_{max}$ : 20000 kg**Table D.17.1.1(3 runs)  
Measurement no. 1:**

Test load ( kg )	Run no.1		Run no.2		Run no.3		Average indication ( count )
	Indication ( count )	Time	Indication ( count )	Time	Indication ( count )	Time	
0	-2.7	7:12:29	-2.1	7:14:10	-2.1	7:15:51	-2.30
20000	19989	7:13:19	19989	7:15:00	19988.9	7:16:41	19988.97
						Span	19991.27

Date: 2011/9/20

Time: 7:02:23

Temperature: 20.0 °C

Relative humidity: 42.9 %

Barometric pressure: 100.82 kPa

Evaluator: Fukuda Remarks:

**Measurement no. 2:**

Test load ( kg )	Run no.1		Run no.2		Run no.3		Average indication ( count )
	Indication ( count )	Time	Indication ( count )	Time	Indication ( count )	Time	
0	-3.9	7:19:40	-3.5	7:21:21	-3.5	7:23:02	-3.63
20000	19987.9	7:20:30	19987.7	7:22:11	19987.8	7:23:52	19987.80
						Span	19991.43

Date: 2011/9/27

Time: 7:09:34

Temperature: 20.0 °C

Relative humidity: 42.8 %

Barometric pressure: 101.58 kPa

Evaluator: Fukuda Remarks:

**Form D.17.1.1(3 runs) Span stability-measurement data for classes C and D (continued)****Measurement no. 3:**

Test load ( kg )	Run no.1		Run no.2		Run no.3		Average indication ( count )
	Indication ( count )	Time	Indication ( count )	Time	Indication ( count )	Time	
0	-4	15:54:32	-3.6	15:56:13	-3.6	15:57:54	-3.73
20000	19988.2	15:55:22	19988.2	15:57:03	19988	15:58:44	19988.13
Span							19991.87

Evaluator: Fukuda Remarks:

Date:	2011/9/28
Time:	15:44:25
Temperature:	20.0 °C
Relative humidity:	42.9 %
Barometric pressure:	101.35 kPa

**Measurement no. 4:**

Test load ( kg )	Run no.1		Run no.2		Run no.3		Average indication ( count )
	Indication ( count )	Time	Indication ( count )	Time	Indication ( count )	Time	
0	-4.1	13:14:32	-3.6	13:16:13	-3.7	13:17:54	-3.80
20000	19988	13:15:22	19988.1	13:17:03	19988	13:18:44	19988.03
Span							19991.83

Evaluator: Fukuda Remarks:

Date:	2011/9/29
Time:	13:04:26
Temperature:	20.0 °C
Relative humidity:	42.8 %
Barometric pressure:	101.11 kPa

**Measurement no. 5:**

Test load ( kg )	Run no.1		Run no.2		Run no.3		Average indication ( count )
	Indication ( count )	Time	Indication ( count )	Time	Indication ( count )	Time	
0	-3.2	16:24:44	-2.8	16:26:25	-2.8	16:28:06	-2.93
20000	19988.9	16:25:35	19988.9	16:27:15	19988.9	16:28:56	19988.90
Span							19991.83

Evaluator: Fukuda Remarks:

Date:	2011/10/3
Time:	16:14:38
Temperature:	20.2 °C
Relative humidity:	43.0 %
Barometric pressure:	101.40 kPa

**Form D.17.1.1(3 runs) Span stability-measurement data for classes C and D (continued)****Measurement no. 6:**

Test load (kg)	Run no.1		Run no.2		Run no.3		Average indication (count)	
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-3.2	16:33:56	-2.8	16:35:37	-2.8	16:37:18	-2.93	
20000	19988.8	16:34:47	19988.9	16:36:27	19988.8	16:38:08	19988.83	
							Span	19991.77

Evaluator: \_\_\_\_\_

Fukuda

Remarks:

Date: 2011/10/4  
 Time: 16:24:39  
 Temperature: 20.1 °C  
 Relative humidity: 42.7 %  
 Barometric pressure: 101.94 kPa

**Measurement no. 7:**

Test load (g,kg or t)	Run no.1		Run no.2		Run no.3		Average indication (count)	
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-3.6	16:37:00	-3.2	16:38:41	-3.2	16:40:21	-3.33	
20000	19988.5	16:37:50	19988.5	16:39:31	19988.4	16:41:12	19988.47	
							Span	19991.80

Evaluator: \_\_\_\_\_

Fukuda

Remarks:

Date: 2011/10/5  
 Time: 16:26:54  
 Temperature: 20.0 °C  
 Relative humidity: 42.8 %  
 Barometric pressure: 101.31 kPa

**Measurement no. 8:**

Test load (kg)	Run no.1		Run no.2		Run no.3		Average indication (count)	
	Indication (count)	Time	Indication (count)	Time	Indication (count)	Time		
0	-4.2	16:38:31	-3.7	16:40:12	-3.7	16:41:53	-3.87	
20000	19988	16:39:21	19988.1	16:41:02	19988	16:42:43	19988.03	
							Span	19991.90

Evaluator: \_\_\_\_\_

Fukuda

Remarks:

Date: 2011/10/6  
 Time: 16:28:24  
 Temperature: 20.0 °C  
 Relative humidity: 43.1 %  
 Barometric pressure: 100.15 kPa

**Form D.17.2 Span stability-summary of test results**

Ref.: 6.3.2;A.4.7.8;D.17.1.1(3runs)

Application no.: 23-006  
 Load cell model: DCC1-20T  
 Serial no.: 24071009  
 E<sub>max</sub>: 20000 kg  
 n<sub>max</sub>: 6000  
 V<sub>min</sub>: 1.666 kg  
 P<sub>LC</sub>: 1.0 DR: 1.666 kg  
 Force-generating system: Load cell performance testing device  
 Indicating instrument: YAMATO EDI-901  
 Evaluator: Fukuda

**Table D.17.2**

Measurement no. (see Note 3)	Span		Variation (v)	Maximum allowable variation(v)
	( count )	(v)		
1	19991.27	6000.25	0.00	
2	19991.43	6000.30	0.05	0.75
3	19991.87	6000.43	0.18	0.75
4	19991.83	6000.42	0.17	0.75
5	19991.83	6000.42	0.17	0.75
6	19991.77	6000.40	0.15	0.75
7	19991.80	6000.41	0.16	0.75
8	19991.90	6000.44	0.19	0.75

PASS:  x

FAIL:

Remarks:

- Notes: 1 Variation: the difference in the span value from the span value of run no.1.  
 2 Maximum allowable variation: half the load cell verification interval or half the absolute value of the maximum test load applied.  
 3 Use the results from measurements nos. 1-8 on Form D17.1.1(3 runs) or From D17.1.