



OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: NMI Certin B.V.
Address: Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
Person responsible: Ing. C. Oosterman

Applicant

Name: Vishay Transducers
Address: 5a Hatzoran St.
Netanya, 42506
Israel


Manufacturer of the certified type

Name: Tedeo-Huntleigh and Vishay Transducers
Address: 5a Hatzoran St.
Netanya, 42506
Israel

Identification of certified type

A bending beam load cell
Type : 1510
Fraction : $P_i = 0.7$
Temperature range -10 °C / 40 °C

Maximum capacity (E_{max})	100 kg up to and including 500 kg			
Accuracy Class	C			
Maximum number of load cell intervals (n)	1000	2000	3000	4000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	4000	8000	12500	12500



Nederlands Meetinstituut

OIML Member state
The Netherlands

OIML Certificate N° R60/2000-NL1-06.10
Project number 606274
Page 2 of 2

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report, the test certificate and the description with number TC5623 and the appertaining documentation folder) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R60
Edition 2000 (E)
for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated Test Reports:

N° R60/1991-NL-99.17, that includes 38 pages;
N° R60/2000-NL1-06.10, that includes 38 pages.

The Issuing Authority
Ing. C. Oosterman
Manager Product Certification

bla

H.S. Schep

~~4 July 2006~~

*
* *

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report is not permitted, although either may be reproduced in full.