



OIML Member state
The Netherlands

OIML CERTIFICATE OF CONFORMITY

Issuing authority

Name: NMI Certin B.V.
Address: Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
Person responsible: Ing. C. Oosterman

Applicant

Name: Hope Technologic (Xiamen) Co. Ltd.
Address: 3FL Heng Sheng Building, Yue Hua E. RD.
CN 361006 Hu-Li Xiamen
P.R. of CHINA

Manufacturer of the certified type

Name: Hope Technologic (Xiamen) Co. Ltd.
Address: 3FL Heng Sheng Building, Yue Hua E. RD.
CN 361006 Hu-Li Xiamen
P.R. of CHINA

Identification of certified type

A bending beam load cell
Type : NA... and NA... M
Fraction : $P_i = 0.7$
Temperature range -10 °C / +40 °C
Further characteristics are described on page 2

This Certificate attests the conformity of the above identified type (represented by the sample or samples identified in the associated Test Report, the test certificate and the description with number TC7326 and the appertaining documentation folder) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R60
Edition 2000 (E)
for accuracy class C



OIML Member state
The Netherlands

Project number 701273
Page 2 of 2

This Certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation identified above.

This Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated Test Reports:
N° R60/2000-NL1-07.18 that includes 40 pages.

This revision replaces the earlier version.

The Issuing Authority
Ing. C. Oosterman
Manager Product Certification

11 December 2007

*
* *

Maximum capacity (E_{max})	20 kg up to and including 100 kg				
Accuracy class	C				
Maximum number of load cell verification intervals (n_{max})	1000	2000	3000	4000	5000
Ratio of minimum LC verification interval $Y = E_{max} / V_{min}$	3333	6666	10000	10000	10000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	1000	2000	3000	4000	5000

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated Test Report is not permitted, although either may be reproduced in full.