



# OIML Certificate of Conformity

**OIML Member State**  
The Netherlands

Number R60/2000-NL1-13.02 revision 1  
Project number 1900963  
Page 1 of 3

Issuing authority	NMi Certin B.V. Person responsible: C. Oosterman
Applicant and Manufacturer	Aerospace South-Ocean (Zhejiang) Science and Technology Co., Ltd. NO.58 Nanyang Road, Qianyuan Town Deqing County, Zhejiang Province China.
Identification of the certified type	A <b>compression load cell</b> , with strain gauges. Type : CP-11
Characteristics	See next page

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**OIML R60** - Edition 2000 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified.  
This Certificate does not bestow any form of legal international approval.

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMi Certin B.V., OIML Issuing Authority NL1**  
4 May 2017



C. Oosterman  
Head Certification Board

NMi Certin B.V.  
Hugo de Grootplein 1  
3314 EG Dordrecht  
the Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)



The conformity was established by the results of tests and examinations provided in the associated OIML Test Report(s):

- No. NMI-12200513-02 dated 10 January 2013 that includes 51 pages.

**Characteristics of the load cell:**

Maximum capacity ( $E_{max}$ )	10000 kg up to and including 50000 kg
Minimum dead load	2 kg
Accuracy Class	C
Rated Output	2 mV/V
Maximum number of load cell intervals (n)	5000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	11000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	5128
Input impedance	$700 \Omega \pm 10 \Omega$
Temperature range	-10 °C / +40 °C
Fraction $p_{LC}$	0,7
Humidity Class	CH
Safe overload	120% of $E_{max}$
Output impedance	$700 \Omega \pm 5 \Omega$
Recommended excitation	10 V DC
Excitation maximum	15 V DC
Transducer material	stainless steel
Atmospheric protection	IP68, hermetical sealed

The characteristics for  $n_{max}$  and Y can be reduced separately. Z is proportional or equal to  $n_{max}$ .

Each produced load cell is provided with an accompanying document with information about its characteristics.



# OIML Certificate of Conformity

**OIML Member State**  
The Netherlands

Number R60-2000-NL1-13.02 Revision 1  
Project number 1900963  
Page 3 of 3

## Revision History

This revision replaces the previous version(s).

Revision	Date	Change(s)
Initial	24 January 2013	Original
1	4 May 2017	Name change