

OIML Member State
The Netherlands

Number R60/2000-NL1-13.06
Project number SO13201012
Page 1 of 2

Issuing authority	NMi Certin B.V. Person responsible: C. Oosterman
Applicant	Curiotec Co., LTD. 581-1, Yougmi-ri, Goangtan-mueon, Paju-si, Cyenoggi-do, 413-855 South Korea
Manufacturer	Curiotec Co., LTD. 581-1, Yougmi-ri, Goangtan-mueon, Paju-si, Cyenoggi-do, 413-855 South Korea
Identification of the certified type	A tension load cell Type : SS300
Characteristics	See next page

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R60 - Edition 2000 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMi Certin B.V., OIML Issuing Authority NL1**
19 April 2013

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
the Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).



The conformity was established by the results of tests and examinations provided in the associated OIML Test Report(s):

- No. NMI-12200198-01 dated 13 September 2012 that includes 27 pages.

Characteristics of the load cell:

Maximum capacity (E_{max})	1 t up to and including 5 t
Minimum dead load	0 kg
Accuracy Class	C
Rated Output	2,0 mV/V \pm 0,005 mV/V
Maximum number of load cell intervals (n)	3000
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	6000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	3000
Input impedance	400 $\Omega \pm$ 30 Ω
Temperature range	-10 $^{\circ}$ C / +40 $^{\circ}$ C
Fraction p_{LC}	0,7
Humidity Class	CH
Safe overload	150% of E_{max}
Output impedance	350 $\Omega \pm$ 3,5 Ω
Recommended excitation	10 V DC
Excitation maximum	15 V DC
Transducer material	Nickel plated steel
Atmospheric protection	Silicon rubber

The characteristics for n_{max} and Y can be reduced separately. Z is proportional or equal to n_{max} .

Each produced load cell is supplied with information about its characteristics.