

**OIML Member State**  
The Netherlands

Number R60/2000-A-NL1-19.08  
Project number 1902215  
Page 1 of 2

Issuing authority NMI Certin B.V.  
Person responsible: C. Oosterman

Applicant and Manufacturer Flintec UK Ltd  
W4/5 Capital Point, Capital Business Park  
Wentloog Avenue,  
Cardiff, CF3 2PW  
United Kingdom

Identification of the certified type A **single point load cell**, with strain gauges  
Type : PC12

Characteristics See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**OIML R 60** - Edition 2000 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMI Certin B.V., OIML Issuing Authority NL1**  
3 May 2019

  
C. Oosterman  
Head Certification Board

NMI Certin B.V.  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 6362332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMI Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)

**OIML Member State**  
The Netherlands

Number R60/2000-A-NL1-19.08  
Project number 1902215  
Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated OIML Type Evaluation Report:

- No. NMI-1902215-01 dated 1 May 2019 that includes 51 pages.

## Characteristics of the load cell:

Maximum capacity ( $E_{max}$ )	20 kg up to and including 100 kg
Minimum dead load	0 kg
Accuracy Class	C
Rated Output	2,0 mV/V $\pm$ 0,1 mV/V
Maximum number of load cell intervals (n) <sup>(1)</sup>	3000
Ratio of minimum LC Verification interval <sup>(1)</sup> $Y = E_{max} / V_{min}$	20000
Ratio of minimum dead load output return <sup>(1)</sup> $Z = E_{max} / (2 * DR)$	3000
Input impedance	1100 $\Omega$ $\pm$ 50 $\Omega$
Temperature range	-10 $^{\circ}$ C / + 40 $^{\circ}$ C
Fraction $p_{LC}$	0,7
Humidity Class	CH
Safe overload	200 % of $E_{max}$
Output impedance	960 $\Omega$ $\pm$ 50 $\Omega$
Recommended excitation	5 V AC / DC
Excitation maximum	15 V AC / DC
Transducer material	Stainless steel
Atmospheric protection	Hermetically sealed

Remark:

1. The characteristics for  $n_{max}$ , Y and Z can be reduced separately.

Each load cell produced is provided with an accompanying document with information about its characteristics.

The above identified Type (represented by the sample(s) identified in the OIML Test Report) have been found to comply with the additional national requirements established by the United States of America (NIST Handbook 44 and NCWM Publication 14), included in the Utilizer Declaration:

- R 60 OIML-CS rev.2 Additional requirements from the United States Accuracy class III L;
- R 60 OIML-CS rev.2 Additional requirements from the United States Marking requirements.