



# OIML Certificate

**OIML Member State**  
The Netherlands

Number R60/2017-A-NL1-20.02  
Project number 2454540  
Page 1 of 2

Issuing authority NMI Certin B.V.  
Person responsible: M. Boudewijns

Applicant and Manufacturer Thames Side Sensors Ltd.  
Unit 10, lo Trade Centre, Deacon Way  
Reading, RG30 6AZ  
United Kingdom

Identification of the certified type A **compression load cell**, with strain gauges.  
Type : T34

Characteristics See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**OIML R 60** - Edition 2017 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

**NMI Certin B.V., OIML Issuing Authority NL1**  
24 March 2020

Certification Board

NMI Certin B.V.  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 6362332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMI Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



The conformity was established by the results of tests and examinations provided in the associated OIML Type Evaluation Report:

- No. NMI-2224556-01 revision 1 dated 16 December 2019 that includes 28 pages.

## Characteristics of the load cell:

Characterization of load cell capabilities	Analog-passive load cell
Maximum capacity ( $E_{\max}$ )	15 t up to and including 75 t
Minimum dead load	0 kg
Accuracy Class	C
Rated Output	2,0 mV/V
Maximum number of load cell intervals (n) <sup>(1)</sup>	4000
Ratio of minimum LC Verification interval <sup>(1)</sup> $Y = E_{\max} / V_{\min}$	10000
Ratio of minimum dead load output return <sup>(1)</sup> $Z = E_{\max} / (2 * DR)$	12000
Input impedance	800 $\Omega \pm 5 \Omega$
Temperature range	-10 °C / + 40 °C
Fraction $p_{LC}$	0,7
Humidity Class	CH
Safe overload	150 % of $E_{\max}$
Output impedance	705 $\Omega \pm 5 \Omega$
Recommended excitation	10 V AC / DC
Excitation maximum	15 V AC / DC
Transducer material	Stainless steel
Atmospheric protection	Hermetically welded

Remark:

1. The characteristics for  $n_{\max}$ , Y and Z can be reduced separately.

Each load cell produced is provided with an accompanying document with information about its characteristics.