



OIML Certificate

OIML Member State
The Netherlands

Number R60/2017-A-NL1-20.26
Project number 2504084
Page 1 of 2

Issuing authority

NMi Certin B.V.
Person responsible: M. Boudewijns

Applicant and
Manufacturer

METTLER-TOLEDO (Changzhou) Precision Instrument Ltd.
No.22 Zhengqiang Road
Changzhou, Jiangsu, 213125
P.R. CHINA

Identification of the
certified type

A **bending beam load cell**, with strain gauges.
Type : 0795

Characteristics

See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R 60 - Edition 2017 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1
27 August 2020

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 6362332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon on top of the electronic version of this certificate.



OIML Member State
The Netherlands

Number R60/2017-A-NL1-20.26
Project number 2504084
Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated OIML Test Report:

- Number R60/2000-NL-01.03 dated 19 January 2001, that includes 40 pages.

Characteristics of the load cell:

Characterization of load cell capabilities	Analog-passive load cell		
Maximum capacity (E_{max})	100 kg up to and including 300 kg		
Minimum dead load	0 kg		
Accuracy Class	C		
Rated Output	2 mV/V		
Maximum number of load cell intervals (n) ⁽¹⁾	1000	3000	6000
Ratio of minimum LC Verification interval ⁽¹⁾ $Y = E_{max} / V_{min}$	1700	10000	
Ratio of minimum dead load output return ⁽¹⁾ $Z = E_{max} / (2 * DR)$	12000		
Input impedance	415 $\Omega \pm 15 \Omega$		
Temperature range	-10 °C / +40 °C		
Fraction p_{LC}	0.7		
Humidity Class	CH		
Safe overload	150 % of E_{max}		
Output impedance	350 $\Omega \pm 3 \Omega$		
Recommended excitation	10 V DC/AC		
Excitation maximum	15 V DC/AC		
Transducer material	Aluminium		
Atmospheric protection	potted		

Remark:

1. The characteristics for n_{max} , Y and Z can be reduced separately.

Each load cell produced is provided with an accompanying document with information about its characteristics.