OIML REALINGATION SUSSE	FORCE			
Denmark	OIML Certificate No. R76/2006-A-DK2-2019.01			
OIML CERTIFICATE ISSUED UNDER SCHEME A				
OIML Issuing Authority				
Name:FORCE Certification A/SAddress:Park Allé 345, 2605 Brøndby, DenmarkPerson responsible:Leif Madsen				
Applicant				
Name: Flintec UK Ltd. Address: W4/5 Capital Point Capital Business Park Wentloog, Cardiff CF3 2PW UNITED KINGDOM With the second se				
commercial characterisation of the instrument.				
Designation of the module (<i>if applicable</i>)				
Analog data processing device				
This OIML Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML type evaluation report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):				
OIML R 76-1, Edition (year): 2006				
For accuracy class (if applicable) : II, III and IIII				

This OIML Certificate relates only to metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML Recommendation identified above.

This OIML Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated OIML reports:

Type examination report: No. 118-36272.10, dated 13 May 2019 that includes 144 pages Type evaluation report: No. 118-36272.90, dated 13 May 2019 that includes 3 pages

The technical documentation relating to the identified type is contained in documentation file:

No. 118-36272

OIML Certificate History

Revision	No.	Date	Description of the modification
First issuance		12 June 2019	
	2		
	Cer		J E
		Atio	n 32
Identification, sig	gnature and st	amp	
FORCE Cortifica	ing Authority	y	
FORCE CEITING	uoli A/S		
Date: 12 June 20	19		
Jens Hovgård Jer	isen		
Certification Mar	nager		
Important note:	Apart from	the mention of the Certif	icate's reference number and the name of the
-	OIML Mem	ber State in which the Co	ertificate is issued, partial quotation of the
	Certificate a	and of the associated OIM	IL type evaluation report(s) is not permitted,
	although eit	her may be reproduced in	n full.

Descriptive annex

Characteristics	
Accuracy class:	II, III or IIII
Weighing range:	Single-interval, multi-range or multi-interval
Maximum number of verification scale intervals (n):	≤ 3×20000 (class II) ≤ 3×10000 (class III) ≤ 3×1000 (class III)
Minimum input voltage per VSI (ei):	0.1 µV
Maximum capacity of interval (Maxi):	$n_i imes e_i$
Initial zero-setting range:	20 % of Max
Maximum tare effect:	100 % of Max
Fractional factor (p _i):	0.5
Excitation voltage:	5 VAC
Minimum input voltage from load cell:	0 mV
Maximum input voltage from load cell:	15 mV
Circuit for remote sense:	Active (see below)
Minimum input impedance:	58 Ohm
Maximum input impedance:	1100 Ohm
Load cell linearization feature:	None
Maximum cable length between	
instrument and junction box:	33035 m/mm ²
Supply voltage:	9 - 32 VDC, not to be supplied from DC Mains
Operating temperature range:	$Min / Max = -15 \ ^{\circ}C / +55 \ ^{\circ}C$
Software	
The model number (returned by command FPN) sha	all be 'EM100-A'.
The software version (returned by command FFV) s	shall be 01.xx, where $xx \ge 60$.
Interfaces	n^{2}

Interfaces

- Load cell input
- RS485
- RS232
- USB
- CAN open
- two logic level inputs and two open-drain outputs

Devices

- Initial zero setting device
- Semi-automatic zero setting device
- Zero tracking device
- Semi-automatic tare device
- Preset tare device
- Data storage device for setup and calibration data
- Stable indication device
- Stable equilibrium device
- Zero, Net and active range indication (in transmitted record).

