

Czech Metrology Institute



Member state
Czech Republic

OIML Certificate No.
R85/2008-CZ-14.01

OIML CERTIFICATE OF CONFORMITY

Issuing Authority

Name: Czech Metrology Institute
Address: Okružní 31,
638 00 Brno, CZ
Person responsible: Jan Kalandra

Applicant

Name: START ITALIANA srl.
Address: via Pola 6
20030 Bovisio Masciago (MB)
Italy

Manufacturer of the certified type

Name: START ITALIANA srl.
Address: via Pola 6
20813 Bovisio Masciago (MB)
Italy

Identification of the certified type

Magnetostrictive level gauge
Type: XMT-SI-485

Further characteristics see page 2

This certificate attests the conformity of above identified type (represented by the sample or samples identified in the associated test report) with the requirements of the following Recommendation(s) of the International Organization of Legal Metrology (OIML):

R 85, edition 2008

Member state
Czech Republic

OIML Certificate No.
R85/2008-CZ-14.01

This certificate relates only to the metrological and technical characteristics of the type of instrument covered by the relevant OIML Recommendation(s) identified above.

This certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated Test report: No. 6015-PT-P3004-14 that includes 29 pages.

Characteristics:

Probes	Type	XMT-SI-485
	Measuring principle	Magnetostrictive
	Probe's body material	Stainless steel
	Floats	Stainless steel or expanded PVC
	Length	up to 7000 mm
	Accuracy	better than ± 1 mm
	Temperature	- 25 °C to + 55 °C

Measuring system description:

The level sensor XMT-SI-485 is done by a shaft in stainless steel, by a head in stainless steel IP68, a circular connection M12 and fuel resistant cable, floats in Stainless Steel or in special expanded cell close PVC.


The Issuing Authority
Jan Kalandra




The OIML Member
Pavel Klenovský

11 February 2014

11 February 2014

Important note: Apart from the mention of the certificate's reference number and the name of the OIML Member State in which the certificate is issued, partial quotation of the certificate and the associated test report is not permitted although either may be reproduced in full.