

Issuing authority NMI Certin B.V.  
Person responsible: M.Ph.D. Schmidt

Applicant and Manufacturer Euromisure S.a.s. di WIKA Italia S.r.l.  
Via G. Borghisani, 4  
26035 Pieve S. Giacomo (CR)  
Italy

Identification of the certified type An **ultrasonic gas meter**  
Type: FLC-UFL-4F

Characteristics See page 2 and further

This OIML Certificate is issued under scheme A

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**R 137-1 (2012) "Gas meters"**

Accuracy class 0,5

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMI Certin B.V., OIML Issuing Authority NL1**  
10 November 2022

Certification Board

**NMI Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMI Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



The conformity was established by the results of tests and examinations provided in the associated reports:

- No. NMI-16200107-01R1 dated 15 December 2016 that includes 52 pages.
- No. NMI-1901574-01 dated 2 November 2017 that includes 13 pages.
- No. NMI-2258343-01 dated 20 September 2019 that includes 17 pages.
- No. NMI-2258343-02 dated 23 April 2020 that includes 11 pages.

### Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented. Table 2 gives an overview of the general characteristics of the family of instruments.

**Table 1 General characteristics**

Destined for the measurement of	Gas volume	
Environmental classes	M1 / E2	
Accuracy class	0.5	
Maximum pressure	153 bar a	
Ambient temperature range	-25 ... +55 °C	
Gas temperature range	-25 ... +55 °C	
Designed for	Condensing humidity	
Orientation	All orientations	
Power supply voltage	18..28 V DC	
Software identification	Main version: 1.0.3 FPGA version: 1.0.0	Checksum: E9B0C4B7
	Main version: 1.0.4 FPGA version: 1.0.1	Checksum: 77A54A9D
	Main version: 1.0.6 FPGA version: 1.0.4	Checksum: 43F6D289
	Main version: 1.0.7 FPGA version: 1.0.4	Checksum: 544882BB
	Main version: 2.0.1 FPGA version: 2.0.1	Checksum: 67D31506
	Main version 2.3.1 FPGA version 2.3.0	Checksum: 3C12C30A
	Main version: 2.4.1 FPGA version: 2.3.0	Checksum: B87E9BB9
	Main version: 2.5.0 FPGA version: 2.3.0	Checksum: 94AC0AE9

The meter consists of a cylindrical spool piece with 4 horizontal paths. Multiple configurations can be combined in a single housing:

- 4 paths configuration Single meter;
- 4+1 configuration 4 pay and 1 check;
- 4+2 configuration 4 pay and 2 check;
- 4+3 configuration 4 pay and 3 check;
- 4+4 configuration Either as Pay and check or as 2 separate meters.

When the meter is equipped with a double meter configuration, the pay and check meter shall have a different indicator. A clear distinction between Pay and check indicator shall be present, both meters must have their own nameplate with unique serial number.

**Table 2 General characteristics of the family of instruments**

Diameter		V <sub>max</sub> [m/s]	V <sub>min</sub> [m/s]	V <sub>t</sub> [m/s]
Nominal size [-]	Inner diameter [mm]			
3" / DN80	70 ~ 80	35,00	0,51	1/10 V <sub>max</sub>
4" / DN100	80 ~ 105	33,50	0,51	
6" / DN150	130 ~ 155	30,00	0,40	
8" / DN200	180 ~ 210	30,00	0,30	
10" / DN250	230 ~ 260	30,00		
12" / DN300	270 ~ 320	30,00		
14" / DN350	300 ~ 345	30,00		
16" / DN400	350 ~ 390	30,00		
18" / DN400	380 ~ 440	30,00		
20" / DN450	450 ~ 490	30,00		
24" / DN550	520 ~ 590	29,00		
30" / DN700	680 ~ 730	28,00		

The corresponding flow rates can be calculated as follows:

$$Q = v \cdot \frac{1}{4} \cdot \pi \cdot D^2 \cdot 3600$$

Where:

Q = flow rate [m<sup>3</sup>/h]

v = velocity [m/s]

D = internal diameter [m]

**OIML Member State**  
The Netherlands

Number R137/2012-A-NL1-20.15 Revision 1  
Project number 3465237  
Page 4 of 4

Higher values of  $Q_{min}$  and lower values of  $Q_{max}$  are allowed on condition that  $Q_{min} \leq 0,05 Q_{max}$  and  $Q_{max} / Q_t \geq 5$ .

## + Installation conditions:

### *Installation of the gas meter*

The meter needs to be installed according one of the following configurations:

- Upstream: a minimum of 5D + NOVA 50E + 10D of straight pipe  
Downstream: a minimum of 4D straight pipe.  
The flow conditioner shall be a NOVA 50E compliant design.
- Upstream: a minimum of 5D + PTB Flow conditioner + 5D of straight inlet pipe  
Downstream: a minimum of 3D straight pipe.  
The flow conditioner shall be a PTB compliant design.

A thermowell may be mounted at 2D - 5D from the outlet of the meter.

### *Bi-directional flow measurement*

During conformity assessment it is sufficient to verify a bi-directional meter in one direction only. For bi-directional flow measurement the outlet pipe and flow conditioner shall be identical to the inlet. The installation of a temperature sensor is at 2–5D from the outlet of the meter. For bi-directional applications an additional temperature sensor can be installed 2–5D upstream of the meter. For bi-directional applications the meter and pipe spools including the thermo well(s), shall be calibrated as a meter package during the examination for putting into use of the gas meter.

### *Alternative welded configuration of the gas meter*

The central meter body can be welded directly onto the flanges or to inlet and outlet pipes. The welding may not cause more than a 3% diameter step. The meter shall be installed as stated in "Installation of the gas meter". The central meter body, including welded piping or welded flanges, shall be calibrated as a meter package during the examination for putting into use of the gas meter.

## Revision history

Revision	Date	Description of the modification
Initial	6 October 2020	Initial issue
1	10 November 2022	SW update Added 153 bar max working pressure