

OIML Certificate



OIML Member State The Netherlands Number R137/2012-A-NL1-24.09 revision 0 Project number 3860134 Page 1 of 4

Issuing authority Person responsible: NMi Certin B.V. M.Ph.D. Schmidt

Applicant and Manufacturer Insight Metering Systems, LLC. 4267 Canal Ave SW Grandville, MI 49418 United States of America

Identification of the certified type

Accuracy class

A **measuring instrument** Type: iSonic

Characteristics See page 2 and further

This OIML Certificate is issued under scheme A

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):



This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1 28 November 2024

28 November 2024

Certification Board

NMi Certin B.V. Thijsseweg 11 2629 JA Delft The Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.







OIML Member State

The Netherlands

OIML Certificate

Number R137/2012-A-NL1-24.09 revision 0 Project number 3860134 Page 2 of 4

The conformity was established by the results of tests and examinations provided in the associated report(s):

- Number NMi-3860134-01, dated 28 November 2024 that includes 53 pages.
- Number NMi-3860134-02, dated 28 November 2024 that includes 16 pages.
- Number NMi-3860134-04, dated 28 November 2024 that includes 23 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented. In Table 2 the general characteristics of the family of instruments of the 6-path meters are presented. In Table 3 the general characteristics of the family of instruments of the 8-path meters are presented.

Table 1 General characteristics

Destined for t	he measuremen	it of	Gas volume
Accuracy class			0.5
Intended for t	he measuremer	nt of	Natural gas
Minimum – m	aximum pressur	e	8 – 255 bar
Ambient tem	perature range		-40 – +55 °C
Gas temperat	ure range		-40 – +55 °C
Designed for	\sim		Condensing humidity
Orientation			All orientations
Flow direction	ı		Bi-directional
Path configur	ation		Direct measuring paths in an X-shape: - 6-path meters: 4 + 2 paths - 8-path meters: 4 + 4 paths
Path angle			62,5°
Sound freque	ncy		200 kHz
Outlet pipe			5D
Power supply	voltage		18 – 30 VDC
Software ident	ification		
Part	Version	Checksum	Remarks
MCU	3.1.1.8	F2E09A6A	
APU	1.0.0.36	BE0272B7	
FPGA	0.0.1.55	DE04FF99	



OIML Member State The Netherlands

Number R137/2012-A-NL1-24.09 revision 0 Project number 3860134 Page 3 of 4

Table 2 General characteristics of the 6-path meters

Nominal Diameter	Nominal bore size	Maximum Qmax <u>Mild</u> ⁽¹⁾ disturbance	Maximum Qmax <u>Severe⁽²⁾</u> disturbance	Minimum Qt	Minimum Qmin
	[mm]	[m/s]	[m/s]	[m/s]	[m/s]
4 (100 mm)	95				
6 (150 mm)	140	36			
8 (200 mm)	185				
10 (250 mm)	235		30	1,8	0,6
12 (300 mm)	270	25			
14 (350 mm)	310	35			
16 (400 mm)	355				

Table 3 General characteristics of the 8-path meters

Nominal Diameter	Nominal bore size	Maximum Qmax <u>Mild</u> ⁽¹⁾ disturbance	Maximum Qmax <u>Severe⁽²⁾</u> disturbance	Minimum Qt	Minimum Qmin
	[mm]	[m/s]	[m/s]	[m/s]	[m/s]
4 (100 mm)	95				
6 (150 mm)	140				
8 (200 mm)	185				
10 (250 mm)	235	40	22	1,5	0,6
12 (300 mm)	270				
14 (350 mm)	310				
16 (400 mm)	355				

Notes to tables 2 and 3:

(1) In case only mild flow disturbances may occur. These meters shall be marked with the character "M" placed on the nameplate.

(2) In case of severe flow disturbances.

(3) In case it is unknown if mild or severe flow disturbances are applicable, the maximum flow velocity for severe conditions shall be used.



OIML Member State

The Netherlands

OIML Certificate

Number R137/2012-A-NL1-24.09 revision 0 Project number 3860134 Page 4 of 4

The corresponding flow rates can be calculated as follows:

 $Q = 3600 \cdot \frac{1}{4} \cdot \pi \cdot D^2 \cdot v = 900 \cdot \pi \cdot D^2 \cdot v$

Where:

Q	= flow rate	[m³/h]
v	= velocity	[m/s]
D	= nominal bore size diameter	[m]

Note regarding tables 2 and 3:

- Higher values for Qmin or Qt and/or lower values for Qmax can be chosen, under the condition that:
 - If ratio $5 \le Qmax:Qmin < 50$ then ratio $Qmax:Qt \ge 5$
 - If ratio $Qmax:Qmin \ge 50$ then ratio $Qmax:Qt \ge 10$

Installation conditions:

Installation requirements

The meter needs to be installed according the following configurations:

- 6-path meters:
 - Upstream: a minimum of 5D + FC + 5D of straight pipe. The flow conditioner (FC) shall be a CPA type 50E compliant design.
 Downstream: a minimum of 5D
 - Downstream:
- 8-path meters:
 - Upstream: a minimum of 10D of straight pipe without a flow conditioner.
 - Downstream: a minimum of 5D

Bi-directional flow measurement

- 6-path meters

During conformity assessment it is sufficient to verify a bi-directional meter in one direction only. For bi-directional flow measurement the outlet pipe and flow conditioner shall be identical to the inlet. The installation of a temperature sensor is at 2–5D from the outlet of the meter. For bidirectional applications, an additional temperature sensor can be installed 2–5D upstream of the meter. For bi-directional applications, the meter and pipe spools including the thermowell(s), shall be calibrated as a meter package during the examination for putting into use of the gas meter. - 8-path meters

During conformity assessment, the meter shall be calibrated in both directions if the meter is intended to be used for bi-directional measurements. The requirements shall be met without modification of the meter's parameter settings.

Certificate history:

Revision	Date	Description of the modification
0	28 November 2024	Initial issue.