



OIML Certificate

OIML Member StateThe Netherlands



Number R46/2012-A-NL1-22.01 revision 1 Project number 2557963 Page 1 of 3

Issuing authority NMi Certin B.V.

Person responsible: M.Ph.D. Schmidt

+

Manufacturer

Globaltronics

Address

Lot 120, CPC Industrial Park, Northen extension area

12573/48, 6 October City, Giza

Country Egypt

Identification of the

An active electrical energy meter

certified type

Type: GE300-SS

Characteristics See page 2 and further

This OIML Certificate is issued under scheme A

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 46-1/-2 (2012) "Active electrical energy meters"

Accuracy class



This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report is not permitted, although either may be reproduced in full.

Issuing Authority NMi Certin B.V., OIML Issuing Authority NL1

7 July 2023

Certification Board







This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.











OIML Certificate



Number R46/2012-A-NL1-22.01 revision 1 Project number 2557963 Page 2 of 3

The conformity was established by the results of tests and examinations provided in the associated report:



- No. NMi-2557963-01 dated 8 March 2022 that includes 56 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented. The construction of the measuring instrument is recorded in the Documentation folder no. R46-2012-A-NL1-22.01-1.

Table 1 General characteristics

General characteristics			
Meter type	static		
Connection mode (phase, wires, elements)	3p, 4w, 3e		
Direction of energy flow / registers	One-register, bi-directional.		
Terminal arrangement	DIN		
Protective class	Category 2		
Impulse voltage	8 kV		
Environmental application			
Ambient temperature range	-40 °C to +70°C and 75 °C (3k7)		
Humidity class	Н3		
IP Rating / environmental use	IP54 / outdoor		
Meter quantities			
Nominal voltage (U _{nom})	3x230/400 V		
Nominal frequency (f _{nom})	60 Hz		
Maximum current (/ _{max})	100 A		
Transitional current (I _{tr})	1 A (I _b = 10 A)		
Minimum current (I _{min})	0,25 A		
Starting current (Ist)	0,04 A		
Meter constant	1.000 imp./kWh		
Product version			
Hardware version	GE300-S_V1.0_03-2020		
Software identification	Version number: KSA_GE300-SS_V1.0-03- 20_V1.0.0_04-2021 Checksum: 70B48E8B		









Number R46/2012-A-NL1-22.01 revision 1 Project number 2557963 Page 3 of 3

Certificate history:



This revision replaces the previous version.

Revision	Date	Description of the modification	
Initial	2022-03-08	-	
1	2023-07-07	Impulse voltage level included	









