

OIML Member State
The Netherlands

Number R46/2012-A-NL1-24.08 revision 1
Project number 3789787
Page 1 of 3

Issuing authority NMI Certin B.V.
Person responsible: M.Ph.D. Schmidt

Applicant and Manufacturer Zhejiang Reallin Electron Co Ltd.
No.8 Shuangyang Rd. Renhe Town
Yuhang District 311107
Hangzhou Zhejiang
China

Identification of the certified type An **Active electrical energy meter**
Manufacturers mark: Reallin
Type: E1010

Characteristics See following page(s)

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R 46-1/-2: 2012 "Active electrical energy meters"

Accuracy class B

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

This certificate and supporting reports comply with the requirements of OIML-CS-PD-07 clause 6.2.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMI Certin B.V., OIML Issuing Authority NL1**
3 September 2024

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
the Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMI Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



The conformity was established by the results of tests and examinations provided in the associated report(s):

- No. NMI-3789787-01 dated 12 August 2024 that includes 51 pages;
- No. NMI-3789787-02 dated 3 September 2024 that includes 13 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

In Table 2 the characteristics of the family of instruments are presented.

The construction of the measuring instrument is recorded in the Documentation folder no. R46-2012-A-NL1-24.08-2.

Table 1 General characteristics

General characteristics	
Meter type	static
Connection mode (phase, wires, elements)	1p, 2w, 1e
Direction of energy flow / registers	Two-registers, bi-directional.
Terminal arrangement	BS (L-NN-L)
Protective class	Category 2
Environmental application	
Ambient temperature range	-25 °C to +55 °C (tested up to 60 °C)
Humidity class	H2
IP Rating / environmental use	IP54 / indoor
Meter quantities	
Nominal voltage (U_{nom})	220 V
Nominal frequency (f_{nom})	50 Hz
Maximum current (I_{max})	60 A
Reference current (I_b)	5 A
Transitional current (I_{tr})	0,5 A ($I_b / 10$)
Minimum current (I_{min})	0,25 A ($I_b \times 5\%$)
Starting current (I_{st})	0,02 A
Meter constant	1.000 imp./kWh
Product version	
Hardware version	Main board : DDSD-BJZ10-VA1.1_2024.03.19
Software identification	Version number: Z-BJ10VA-EM-2309-001 Checksum: 1223



OIML Member State
The Netherlands

OIML Certificate

Number R46/2012-A-NL1-24.08 revision 1
Project number 3789787
Page 3 of 3

Certificate history:

This revision replaces the previous version.

Revision	Date	Description of the modification
0	12 August 2024	Initially issued
1	3 September 2024	Editorial changes