

OIML Member State
The Netherlands

Number R49/2013-A-NL1-19.01 revision 5
Project number 3670720
Page 1 of 5

Issuing authority
Person responsible: NMI Certin B.V.
M.Ph.D. Schmidt

Applicant and
Manufacturer: Euromag International S.r.l.
Via della Tecnica 20
35035 Mestrino (PD)
Italy

Identification of the
certified type: An electromagnetic **water meter**
Type: MUT1000EL, MUT2200EL and MUT2300
with electronic converter MC406M and MC406AM

Characteristics: See page 2 and further

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

R49-1 (2013) "Water meters intended for the metering of cold potable water and hot water"

Accuracy class: 1 and 2

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

This certificate and supporting reports comply with the requirements of OIML-CS-PD-07 clause 6.2.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority: **NMI Certin B.V., OIML Issuing Authority NL1**
22 September 2023

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMI Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



OIML Member State
The Netherlands

Number R49/2013-A-NL1-19.01 revision 5
Project number 3670720
Page 2 of 5

The conformity was established by the results of tests and examinations provided in the associated reports:

- No. NMI-15200444-01 dated 31 March 2016 that includes 39 pages;
- No. 150701670/ Euromag DN 50/ MC 406 dated 30 March 2016 that includes 42 pages;
- No. NMI-16200309-01 revision 1 dated 22 March 2018 that includes 77 pages;
- No. 160600944/MUT 2200, DN 50, full bore dated 28 October 2016 that includes 31 pages;
- No. 160600948/MUT 2200, DN 65, full bore dated 28 October 2016 that includes 31 pages;
- No. 160600939/MUT 2300, DN 80, reduced bore dated 28 October 2016 that includes 34 pages;
- No. NMI-1902198-01 dated 3 December 2018 that includes 16 pages;
- No. NMI-2186686-01 dated 24 May 2019 that includes 43 pages;
- No. NMI-2186686-02 dated 24 May 2019 that includes 47 pages;
- No. NMI-2463352-01 dated 18 January 2021 that includes 27 pages;
- No. NMI-3369067-01 dated 10 May 2022 that includes 13 pages.
- No. NMI-3670720-01 dated 22 September 2023 that includes 12 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

The measurement sensor can have the following cylindrical measuring tube:

- Full bore for type MUT1000EL (without flanges) or MUT2200EL (with flanges); or
- Reduced bore for type MUT2300.

Table 2 and 3 gives an overview of the general characteristics of the family of instruments.

The construction of the measuring instrument is recorded in the Documentation folder no. T10713-8.

Table 1 General characteristics

| | |
|-----------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Measuring principle | Electromagnetic |
| Accuracy class of MUT2200EL | 2 |
| Accuracy class of MUT2300 | 1 |
| Environmental class | M1 / O (installed outdoors) |
| Electromagnetic environment | E1 for remote version of converter MC406M E2 for compact version of converter MC406M E2 for compact and remote version of converter MC406AM E1 for compact and remote version of converter MC406M/AM with Bluetooth&RS485 and/or 4-20mA output |
| Temperature range ambient | -25 °C / +55 °C |
| Water temperature class | T50 (+0,1 °C / +50 °C) |
| Maximum admissible pressure (MAP) | 1,6 MPa (16 bar) |
| Orientation | All positions (Horizontal, vertical or diagonal) |
| Flow profile sensitivity class | U0 and D0 (0 x DN upstream and 0 x DN downstream) |

| Reverse flow | The water meter is designed to measure reverse flow | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|----------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|--------------|-------|----------|-------|----------|-------|----------|-------------------|--------------|-------|----------|-------|----------|-------|----------|-------|----------|-------|----------|-------|----------|-------|----------|-------|----------|-------|----------|
| Pressure loss class of full-bore sensor types MUT1000EL or MUT2200EL | Δp 10 (0,010 MPa or 0,10 bar) for all sizes | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Pressure loss class of MUT2300 based on documentation 10713/4-03 | Δp 10 (0,010 MPa or 0,10 bar) for sizes < DN80 Δp 16 (0,016 MPa or 0,16 bar) for sizes \geq DN80 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Pressure loss class of MUT2300 based on documentation 10713/1-01 | Δp 25 (0,025 MPa or 0,25 bar) for sizes < DN80 Δp 40 (0,040 MPa or 0,40 bar) for sizes \geq DN80 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Power supply | Replaceable battery (2,9 – 3,7 V) DC mains (10 - 28 V) only for MC406AM | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Software identification | <p>Software 'Bootloader':</p> <table border="1"> <thead> <tr> <th>Software versions</th> <th>CRC Checksum</th> </tr> </thead> <tbody> <tr> <td>01.00</td> <td>63A2EDED</td> </tr> <tr> <td>01.01</td> <td>67AEA1E4</td> </tr> <tr> <td>01.02</td> <td>DE7A99AB</td> </tr> </tbody> </table> <p>Software 'Legally relevant firmware':</p> <table border="1"> <thead> <tr> <th>Software versions</th> <th>CRC Checksum</th> </tr> </thead> <tbody> <tr> <td>01.05</td> <td>CAA8A4C7</td> </tr> <tr> <td>01.15</td> <td>6AA50C55</td> </tr> <tr> <td>01.16</td> <td>E93E3A1E</td> </tr> <tr> <td>01.21</td> <td>79413617</td> </tr> <tr> <td>01.23</td> <td>E7DD52E4</td> </tr> <tr> <td>01.36</td> <td>E1A52981</td> </tr> <tr> <td>01.38</td> <td>C2641A99</td> </tr> <tr> <td>01.42</td> <td>2B6CF4C7</td> </tr> <tr> <td>01.44</td> <td>D867EC79</td> </tr> </tbody> </table> | Software versions | CRC Checksum | 01.00 | 63A2EDED | 01.01 | 67AEA1E4 | 01.02 | DE7A99AB | Software versions | CRC Checksum | 01.05 | CAA8A4C7 | 01.15 | 6AA50C55 | 01.16 | E93E3A1E | 01.21 | 79413617 | 01.23 | E7DD52E4 | 01.36 | E1A52981 | 01.38 | C2641A99 | 01.42 | 2B6CF4C7 | 01.44 | D867EC79 |
| Software versions | CRC Checksum | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.00 | 63A2EDED | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.01 | 67AEA1E4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.02 | DE7A99AB | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Software versions | CRC Checksum | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.05 | CAA8A4C7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.15 | 6AA50C55 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.16 | E93E3A1E | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.21 | 79413617 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.23 | E7DD52E4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.36 | E1A52981 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.38 | C2641A99 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.42 | 2B6CF4C7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 01.44 | D867EC79 | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

OIML Member State
The Netherlands

Number R49/2013-A-NL1-19.01 revision 5
Project number 3670720
Page 4 of 5

Table 2 General characteristics of the family of instruments – Full bore type MUT1000EL or MUT2200EL

| Meter size | Ø in- and outlet [mm] | Flow rates [m ³ /h] | | | | Ratio Q3/Q1 |
|------------|-----------------------|--------------------------------|-----------------|--------------|-------------|-------------|
| | | Minimum Q1 | Transitional Q2 | Permanent Q3 | Overload Q4 | |
| DN32 | 32 | 0,125 | 0,2 | 25 | 31,25 | 200 |
| DN40 | 40 | 0,2 | 0,32 | 40 | 50 | 200 |
| DN50 | 50 | 0,315 | 0,504 | 63 | 78,75 | 200 |
| DN65 | 65 | 0,5 | 0,8 | 100 | 125 | 200 |
| DN80 | 80 | 0,8 | 1,28 | 160 | 200 | 200 |
| DN100 | 100 | 1,25 | 2 | 250 | 312,5 | 200 |
| DN125 | 125 | 2 | 3,2 | 400 | 500 | 200 |
| DN150 | 150 | 3,15 | 5,04 | 630 | 787,5 | 200 |
| DN200 | 200 | 5 | 8 | 1000 | 1250 | 200 |
| DN250 | 250 | 8 | 12,8 | 1600 | 2000 | 200 |
| DN300 | 300 | 10 | 16 | 1600 | 2000 | 160 |

Table 3 General characteristics of the family of instruments - Reduced bore type MUT2300

| Meter size | Ø in- and outlet [mm] | Flow rates [m ³ /h] | | | | Ratio Q3/Q1 |
|------------|-----------------------|--------------------------------|-----------------|--------------|-------------|-------------|
| | | Minimum Q1 | Transitional Q2 | Permanent Q3 | Overload Q4 | |
| DN50 | 50 | 0,125 | 0,2 | 25 | 31,25 | 200 |
| DN65 | 65 | 0,2 | 0,32 | 40 | 50 | 200 |
| DN80 | 80 | 0,315 | 0,504 | 63 | 78,75 | 200 |
| DN100 | 100 | 0,5 | 0,8 | 100 | 125 | 200 |
| DN125 | 125 | 0,8 | 1,28 | 160 | 200 | 200 |
| DN150 | 150 | 1,25 | 2 | 250 | 312,5 | 200 |
| DN200 | 200 | 3,15 | 5,04 | 630 | 787,5 | 200 |
| DN250 | 250 | 5 | 8 | 1000 | 1250 | 200 |
| DN300 | 300 | 8 | 12,5 | 1000 | 1250 | 125 |

OIML Member State
The Netherlands

Number R49/2013-A-NL1-19.01 revision 5
Project number 3670720
Page 5 of 5

Table 4 General characteristics of the indicating device - Full bore type MUT1000EL or MUT2200EL

| Meter size | Indicating range (minimum value) [m ³] | Verification scale interval (minimum resolution) [m ³] |
|--------------------------------------|----------------------------------------------------------|--------------------------------------------------------------------------|
| DN32, DN40 | 9 999 999 | 0,0001 |
| DN50, DN65, DN80, DN100 | 9 999 999 | 0,001 |
| DN125, DN150, DN200, DN250, DN300 | 9 999 999 | 0,01 |

Table 5 General characteristics of the indicating device - Reduced bore type MUT2300

| Meter size | Indicating range (minimum value) [m ³] | Verification scale interval (minimum resolution) [m ³] |
|------------------------------------|----------------------------------------------------------|--------------------------------------------------------------------------|
| DN50 | 9 999 999 | 0,0001 |
| DN65, DN80, DN100, DN125, DN150 | 9 999 999 | 0,001 |
| DN200, DN250, DN300 | 9 999 999 | 0,01 |

Certificate history:

This revision replaces the previous version.

| Revision | Date | Description of the modification |
|----------|-------------------|----------------------------------------------------------------------------------------------------------------|
| Initial | 24 May 2019 | - |
| 1 | 4 February 2021 | Addition of MUT1000EL and full-bore sizes DN32 and DN40 Lowering pressure loss class of MUT2300 |
| 2 | 10 May 2022 | Addition of electronic hardware module (Bluetooth&RS485 and/or 4-20mA output). Addition of new software. |
| 3 | 7 July 2022 | Software update |
| 4 | 14 February 2023 | Software update |
| 5 | 22 September 2023 | Update of electronic hardware module. software update |