



OIML Certificate

OIML Member State

The Netherlands



Number R49/2013-A-NL1-24.02 revision 0 Project number 3499886 Page 1 of 3

Issuing authority NMi Certin B.V.

Person responsible: M.Ph.D. Schmidt

Applicant and Goldcard Water Technology Co., Ltd. Manufacturer No. 158 Jingiao Street

Qiantang District, Hangzhou

Zhejiang 310018

P.R. China

Identification of the An ultrasonic water meter

certified type Type: LXC-xxSC1

Characteristics See following page(s)

Remark 1) xx denotes the size identification (i.e. 15 for DN15)

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML Type Evaluation Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

> R 49-1: 2013 "Water meters intended for the metering of cold potable water and hot water"

Accuracy class 2

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation identified above. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1 6 June 2024

Certification Board

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic







NMi Certin B.V. Thijsseweg 11 2629 JA Delft the Netherlands T +31 88 636 2332 certin@nmi.nl www.nmi.nl

This document is digitally version of this certificate.





OIML Certificate

OIML Member StateThe Netherlands



Number R49/2013-A-NL1-24.02 revision 0 Project number 3499886 Page 2 of 3

The conformity was established by the results of tests and examinations provided in the associated report(s):

No. NMi-3499886-01 dated 6 June 2024 that includes 27 pages.

Characteristics of the measuring instrument

In Table 1 the general characteristics of the measuring instrument are presented.

In Table 2 the characteristics of the family of instruments are presented.

The construction of the measuring instrument is recorded in the Documentation folder no. T12665-1.

Table 1 General characteristics

Measuring principle	Ultrasonic
Accuracy class	2
Environmental class	M1 / O (installed outdoors)
Electromagnetic environment	E1
Temperature range ambient	-25 °C / +55 °C
Water temperature class	T50 (+0,1 °C / +50 °C)
Maximum admissible pressure (MAP)	1,6 MPa (16 bar)
Orientation (+)	Horizontal
Flow profile sensitivity class	U0 and D0 (0 x DN upstream and 0 x DN downstream)
Reverse flow	The sensor is not intended to measure reverse flow
Pressure loss class	Δp 63 (0,63 bar)
Power supply	Non-replaceable battery (2,8 – 3,6 V)
Software identification	Version number: 58506508 Checksum: 8CF979C0

Table 2 General characteristics of the family of instruments

	Ø in- and	Flow rates [m³/h]				Datia.
Meter size outlet [mm]	Minimum Q1	Transitional Q2	Permanent Q3	Overload Q4	Ratio Q3/Q1	
DN15	15	0,006	0,01	2,5	3,125	400
DN20	20	0,01	0,016	4	5	400
DN25	25	0,016	0,025	6,3	7,875	400
DN32	32	0,025	0,04	10	12,5	400

I





OIML Member State The Netherlands



Number R49/2013-A-NL1-24.02 revision 0 Project number 3499886 Page 3 of 3

OIML Certificate

Please note that the flow rates Q1, Q2, Q3 and Q4 can be freely chosen as long as:

- Values Q3 and ratio Q3/Q1 are selected from paragraph 4.1 of OIML R49-1: 2013(E);
- Values mentioned for Q1 and Q2 are minimum values and the ratio Q2/Q1 = 1,6;
- Values mentioned for Q3 and Q4 are maximum values and the ratio Q4/Q3 = 1,25;
- The ratio Q3/Q1 is at least 40.

Table 3 General characteristics of the indicating device

Meter size	Indicating range (maximum value) [m³]	Verification scale interval (minimum resolution) [m³]
DN15; DN20;	99999,99999	0,00001
DN25; DN32	999999,9999	0,00001

Certificate history:

Revision	Date	Description of the modification
0	6 June 2024	-









