

		
<b>OIML Member State</b> Denmark	<b>OIML Certificate No.</b> R51/2006-A-DK2-2023.02 Rev. 1	
<b>OIML CERTIFICATE ISSUED UNDER SCHEME A</b>		
<b>OIML Issuing Authority</b> Name: <b>FORCE Certification A/S</b> Address: <b>Park Allé 345, 2605 Brøndby, Denmark</b> Person responsible: <b>Per Rafn Crety</b>		
<b>Applicant</b> Name: <b>Shanghai Teraoka Electronic Co., Ltd.,</b> Address: <b>No. 6058 of Nanting Road, Tingling town, Jinshan District Shanghai CHINA</b>		
<b>Manufacturer: Shanghai Teraoka Electronic Co., Ltd.</b>		
<b>Identification of the certified type</b> <i>(the detailed characteristics will be defined in the additional pages)</i> <b>SCG-3000 / SCG-6000 / SCG-15000</b>		
<b>Designation of the module</b> <i>(if applicable)</i> <b>Automatic Catchweighing instrument</b>		
This OIML Certificate attests the conformity of the above identified type (represented by the sample(s) identified in the OIML type evaluation report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):  <b>OIML R 51-1, Edition (year): 2006</b>  For accuracy class (if applicable): <b>XIII or Y(a)</b>		

**OIML Certificate No.**  
**R51/2006-A-DK2-2023.02 Rev 1**

This OIML Certificate relates only to metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML Recommendation identified above.

This OIML Certificate does not bestow any form of legal international approval.

The conformity was established by the results of tests and examinations provided in the associated OIML reports:

Type examination report: No. 121-34103.10, dated 21 December 2022, that includes 90 pages

Type evaluation report: No. 121-34103.90.20, dated 07 February 2023, that includes 16 pages

The technical documentation relating to the identified type is contained in documentation file:  
121-34103

**OIML Certificate History**

<b>Revision No.</b>	<b>Date</b>	<b>Description of the modification</b>
Initial version	09 February 2023	
Static mode added	08 December 2023	

Identification, signature and stamp

**The OIML Issuing Authority**

FORCE Certification A/S

Date: 08 December 2023

Jens Hovgård Jensen

Certification Manager

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate is issued, partial quotation of the Certificate and of the associated OIML type evaluation report(s) is not permitted, although either may be reproduced in full.

## Descriptive annex

### Characteristics

- |   |                    |
|---|--------------------|
| • Accuracy class:                             | X(III), Y(a)       |
| • Weighing range:                             | Single-interval    |
| • Weighing mode:                              | Static and Dynamic |
| • Maximum capacity (Max):                     | 3, 6 and 15 kg     |
| • Minimum capacity (Min):                     | $\geq 50 \times e$ |
| • Verification scale interval ( $e$ ):        | $\geq 1$ g         |
| • Number of verification scale intervals (n): | $\leq 3000$        |
| • Belt speed:                                 | 20 m/min           |
| • Warm-up time:                               | None               |
| • Temperature range:                          | -10 °C to +40 °C   |
| • Supply voltage:                             | 230 VAC, 50/60 Hz  |
| • Electromagnetic class:                      | E2                 |
| • Humidity:                                   | Non-condensing     |

The SCG-xxxxx catchweigher uses HBM PW15AH C3 load cell.

### Software

Identification of the software version is performed during power-up.

The approved software version is v4.xx, where xx can be 00-99 and represents minor non-legal changes.

### Devices

- Power up test
- Initial zero setting device ( $\leq 20$  % of Max)
- Automatic zero setting device ( $\leq 4$  % of Max) – dynamic mode only
- Semiautomatic zero setting device ( $\leq 4$  % of Max) – static mode only
- Zero tracking device ( $\leq 4$  % of Max) – static mode only
- No motion detection and indication
- Detection of significant fault

### Interfaces

- Ethernet for communication to peripherals.
- USB (for setup of the instrument only)

The interface does not have to be secured.