



OIML Certificate

OIML Member State
The Netherlands

Number R51/2006-A-NL1-23.03 revision 1
Project number 3646854
Page 1 of 3

Issuing authority

NMi Certin B.V.
Person responsible: M.Ph.D. Schmidt

Applicant and
Manufacturer

Ishida Europe Ltd.
11 Kettles Wood Drive
Woodgate Business Park
Birmingham B32 3DB
United Kingdom

Identification of the
certified type

An **Automatic catchweighing instrument**
Type : DACS-GN-F015

Characteristics

See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R 51-1:2006 for accuracy class XIII(1)

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1
23 August 2023

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 6362332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon on top of the electronic version of this certificate.



The conformity was established by the results of tests and examinations provided in the associated reports:


- No. NMI-2409920-01 dated 10 January 2023 that includes 38 pages;
- No. NMI-2409920-02 dated 10 January 2023 that includes 10 pages;
- No. NMI-2409920-03 dated 10 January 2023 that includes 10 pages;
- No. NMI-2409910-01 dated 10 January 2023 that includes 39 pages.

Characteristics of the automatic catchweighing instrument

Destined to be used as	Checkweigher	
Accuracy class	XIII(1)	
Maximum capacity	Max $\leq 1,5$ kg	
Minimum capacity	Min ≥ 5 g	
Verification scale interval	$e \geq 0,1$ g	
Weighing range(s)	Single interval Multiple range	
Maximum number of scale intervals	$n \leq 3000$ (per weighing range)	
Maximum number of weighing ranges	3	
Preset tare (PT)	$T \leq -Max$	
Maximum load transport system speed	See below	
Dynamic setting (adjustment range referred to setpoint)	± 10 %	
Electromagnetic environment class	E2	
Climatic environment	temperature range	5 °C / +40 °C
	humidity	non-condensing
	intended location	closed
Minimum warm-up time	25 minutes	
Power supply voltage	200 – 240 V AC 50/60 Hz	

	Software module	MCU	DRV	ADC
Software identification	Version number	-	-	N52010
	Checksum	0x2263	0x8DB0	-

The identification number will be displayed at start-up or after pressing the key sequence:

- Jog Dial Settings (sprockets icon) → Program version information, or
- CTS Screen → Display Select →  (USB) Icon.

OIML Member State
The Netherlands

Number R51/2006-A-NL1-23.03 revision 1
Project number 3646854
Page 3 of 3

Maximum load transport system speed:

e ≥ 0,1 g		e ≥ 0,2 g		e ≥ 0,5 g	
Load (g)	Speed (m/min)	Load (g)	Speed (m/min)	Load (g)	Speed (m/min)
5,0 – 7,9	≤ 60	15,0 – 34,8	≤ 80	20,0 – 34,5	≤ 80
8,0 – 49,9	≤ 80	35,0 – 399,8	≤ 100	35,0 – 1500,0	≤ 120
50,0 – 99,9	≤ 100	400,0 – 600,0	≤ 120		
100,0 – 300,0	≤ 120				

Revision History

This revision replaces the previous version.

Revision	Date	Change(s)
0	2023-01-10	Initial issue.
1	2023-08-23	Changed Minimum capacity and MCU checksum.