



OIML Certificate

Number R60/2017-A-NL1-22.18 revision 0
Project number 3548307
Page 1 of 3

OIML Member State
The Netherlands

Issuing authority

NMi Certin B.V.
Person responsible: M.Ph.D. Schmidt

Applicant and
Manufacturer

PAVONE SISTEMI, S.R.L.
VIA TIBERIO BIANCHI 11/13/15
20863 – CONCOREZZO (MB)
ITALY

Identification of the
certified type

A **bending beam load cell**, with strain gauges.
Registered trade name : UTILCELL
Type : BBR; BBF

Characteristics

See next page

This OIML Certificate is issued under scheme A.

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

OIML R 60 - Edition 2017 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above identified. This Certificate does not bestow any form of legal international approval.

Important note: Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Type Evaluation Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority

NMi Certin B.V., OIML Issuing Authority NL1
1 September 2022

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 6362332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at www.oiml.org

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.



The conformity was established by the results of tests and examinations provided in the associated OIML Type Evaluation Reports:

- No. NMI-2309247-01 revision 1 dated 4 February 2020 that includes 52 pages;
- No. NMI-2309247-02 dated 4 September 2019 that includes 24 pages;
- No. NMI-2309247-03 dated 4 September 2019 that includes 24 pages.

Characteristics of the load cell:

Characterization of load cell capabilities	Analog passive load cell		
Maximum capacity (E_{max})	5 kg up to 30 kg	30 kg up to 100 kg	100 kg up to and including 500 kg
Minimum dead load	0 kg		
Accuracy Class	C		
Rated Output	2 mV/V \pm 0,1 mV/V		
Maximum number of load cell intervals (n) ⁽¹⁾	4000	3000	4000
Ratio of minimum LC Verification interval ⁽¹⁾ $Y = E_{max} / v_{min}$	20000		
Ratio of minimum dead load output return ⁽¹⁾ $Z = E_{max} / (2 * DR)$	4000		
Input impedance	400 Ω \pm 20 Ω		
Temperature range	-10 $^{\circ}$ C / + 40 $^{\circ}$ C		
Fraction p_{LC}	0,7		
Humidity Class	CH		
Safe overload	200 % of E_{max}		
Output impedance	350 Ω \pm 3 Ω		
Recommended excitation	10 V AC / DC		
Excitation maximum	15 V AC / DC		
Transducer material	Stainless steel		
Atmospheric protection	Hermetically sealed/welded		

Remark:

1. The characteristics for n_{max} , Y and Z can be reduced separately.

Each load cell produced is provided with an accompanying document with information about its characteristics.

The above identified Type (represented by the sample(s) identified in the OIML Test Report) have been found to comply with the additional national requirements established by the United States of America (NIST Handbook 44 and NCWM Publication 14), included in the Utilizer Declaration:

- R 60 OIML-CS rev.2 Additional requirements from the United States Accuracy class III L;
- R 60 OIML-CS rev.2 Additional requirements from the United States Marking requirements.



OIML Certificate

Number R60/2017-A-NL1-22.18 revision 0
Project number 3548307
Page 3 of 3

OIML Member State
The Netherlands

Revision History

Revision	Date	Change(s)
0	1 September 2022	Initial issue.