

INTERNATIONAL  
RECOMMENDATION

**OIML R 107-2**

Edition 2007 (E)

Reconfirmed in 2024

---

Discontinuous totalizing automatic weighing  
instruments (totalizing hopper weighers)

Part 2: Test report format

Instruments de pesage totalisateurs discontinus à fonctionnement automatique  
(peseuses totalisatrices à trémie)

Partie 2: Format du rapport d'essai

---





---

# Contents

Foreword .....	4
Introduction .....	5
Type evaluation report .....	6
Explanatory notes .....	6
General information concerning the type .....	8
Identification of the instrument .....	10
Test equipment .....	12
Configuration for test .....	13
Summary of type evaluation .....	14
1 Zero-setting device .....	16
2 Warm-up time .....	18
3 Stability of equilibrium for static weighing .....	19
4 Influence factors .....	20
4.1 Static temperatures .....	20
4.2 Temperature effect on no-load indication .....	30
4.3 Damp heat, steady state (non-condensing) .....	31
4.4 Mains power voltage variations test .....	37
5 Disturbances .....	39
5.1 AC mains voltage dips and short interruptions .....	39
5.2 Bursts (transients) on mains power lines and on signal and communication lines .....	41
5.3 Electrical surges on mains power lines and on I/O signal and communication lines .....	46
5.4 Electrostatic discharge .....	51
5.5 Immunity to electromagnetic fields .....	57
5.6 Electrical transient conduction for instruments powered by road vehicle batteries .....	64
6 Span stability .....	68
7 Material tests .....	74
7.1 Material testing (separate verification method) .....	74
7.2 Material testing (integral verification method) .....	76
8 Examination of the construction of the instrument .....	82
9 Checklist .....	83

---

## Foreword

The International Organization of Legal Metrology (OIML) is a worldwide, intergovernmental organization whose primary aim is to harmonize the regulations and metrological controls applied by the national metrological services, or related organizations, of its Member States. The main categories of OIML publications are:

- **International Recommendations (OIML R)**, which are model regulations that establish the metrological characteristics, required of certain measuring instruments and which specify methods and equipment for checking their conformity. OIML Member States shall implement these Recommendations to the greatest possible extent;
- **International Documents (OIML D)**, which are informative in nature and which are intended to harmonize and improve work in the field of legal metrology;
- **International Guides (OIML G)**, which are also informative in nature and which are intended to give guidelines for the application of certain requirements to legal metrology; and
- **International Basic Publications (OIML B)**, which define the operating rules of the various OIML structures and systems.

OIML Draft Recommendations, Documents and Guides are developed by Technical Committees or Subcommittees which comprise representatives from the Member States. Certain international and regional institutions also participate on a consultation basis. Cooperative agreements have been established between the OIML and certain institutions, such as ISO and the IEC, with the objective of avoiding contradictory requirements. Consequently, manufacturers and users of measuring instruments, test laboratories, etc. may simultaneously apply OIML publications and those of other institutions.

International Recommendations, Documents, Guides and Basic Publications are published in English (E) and translated into French (F) and are subject to periodic revision.

Additionally, the OIML publishes or participates in the publication of **Vocabularies (OIML V)** and periodically commissions legal metrology experts to write **Expert Reports (OIML E)**. Expert Reports are intended to provide information and advice, and are written solely from the viewpoint of their author, without the involvement of a Technical Committee or Subcommittee, nor that of the CIML. Thus, they do not necessarily represent the views of the OIML.

This publication – reference OIML R 107-2, Edition 2007 – was developed by Technical Subcommittee TC 9/SC 2. It was approved for final publication by the International Committee of Legal Metrology in 2007 and supersedes the previous edition dated 1997.

OIML Publications may be downloaded from the OIML web site in the form of PDF files. Additional information on OIML Publications may be obtained from the Organization's headquarters:

Bureau International de Métrologie Légale  
11, rue Turgot - 75009 Paris - France  
Telephone: +33 (0)1 48 78 12 82  
Fax: +33 (0)1 42 82 17 27  
E-mail: [biml@oiml.org](mailto:biml@oiml.org)  
Internet: [www.oiml.org](http://www.oiml.org)

---

## Introduction

This “Test report format” aims at presenting, in a standardized format, the results of the various tests and examinations to which a type of a totalizing automatic weighing instrument shall be submitted with a view to its approval.

The test report format consists of two parts, a “checklist” and the “test report” itself.

The checklist is a summary of the examinations carried out on the instrument. It includes the conclusions of the results of the test performed, experimental or visual checks based on the requirements of Part 1. The words or condensed sentences aim at reminding the examiner of the requirements in OIML R 107-1 without reproducing them.

The test report is a record of the results of the tests carried out on the instrument. The “test report” forms have been produced based on the tests detailed in OIML R 107-1:2007.

All metrology services or laboratories evaluating types of totalizing automatic weighing instruments according to R 107 or to national or regional regulations based on this OIML Recommendation are strongly advised to use this test report format, directly or after translation into a language other than English or French. Its direct use in English or in French, or in both languages, is even more strongly recommended whenever test results may be transmitted by the country performing these tests to the approving authorities of another country, under bi- or multilateral cooperation agreements. In the framework of the *OIML Certificate System for Measuring Instruments*, use of this test report format is mandatory.

The “information concerning the test equipment used for type evaluation” shall cover all test equipment which has been used in determining the test results given in a report. The information may be a short list containing only essential data (name, type, reference number for purpose of traceability). For example:

- Verification standards (accuracy, or accuracy class, and no.);
- Simulator for testing of modules (name, type, traceability and no.);
- Climatic test and static temperature chamber (name, type and no.);
- Electrical tests, bursts (name of the instrument, type and no.);
- Description of the procedure of field calibration for the test of immunity to radiated electromagnetic fields.

Note concerning the numbering of the following pages:

In addition to a sequential numbering: “R 107-2 page ...” at the bottom of the pages of this publication, a special place is left at the top of each page (starting with the following page) for numbering the pages of reports established following this model; in particular, some tests (e.g. metrological performance tests) shall be repeated several times, each test being reported individually on a separate page following the relevant format; in the same way, a multiple range instrument shall be tested separately for each range and a separate form (including the general information form) shall be filled out for each range. For a given report, it is advisable to complete the sequential numbering of each page by the indication of the total number of pages of the report.

**DISCONTINUOUS TOTALIZING AUTOMATIC WEIGHING INSTRUMENTS  
(TOTALIZING HOPPER WEIGHERS)**

## Type evaluation report

### Explanatory notes

The name(s) or symbol(s) of the unit(s) used to express test results shall be specified in each form.

For each test, the “summary of type evaluation” and the “checklist” shall be completed according to this example:

	Passed	Failed
When the instrument has passed the test:	X	
When the instrument has failed the test:		X
When the test is not applicable:	–	–

The white spaces in boxes in the headings of the report should always be filled according to the following example:

	At start	At end	
Temp.:	20.5	21.1	°C
Rel. h.:			%
Date:	2006-01-29	2006-01-30	yyyy-mm-dd
Time:	16:00:05	16:30:25	hh:mm:ss
Bar pres.:			hPa

“Date” in the test report refers to the date on which the test was performed.

In the disturbance tests, faults greater than  $d$  are acceptable provided that they are detected and acted upon, or that they result from circumstances such that these faults shall not be considered as significant; an appropriate explanation shall be given in the column “Yes (remarks)”.

Section numbers in brackets refer to the corresponding subclauses of R 107-1:2007.

---

<b>Symbol</b>	<b>Meaning</b>
$I$	Indication
$I_n$	$n$ th indication
$L$	Load
$\Delta L$	Additional load to next changeover point
$P$	$I + \frac{1}{2}d - \Delta L =$ Indication prior to rounding (digital indication)
$E$	$I - L$ or $P - L =$ Error
$E\%$	$(P - L)/L \%$
$E_0$	Error at zero load
$d$	Actual scale interval
$d_t$	Totalization scale interval
$p_i$	Fraction of the MPE applicable to a module of the instrument which is examined separately
mpe	Maximum permissible error
EUT	Equipment under test
sf	Significant fault
Max	Maximum capacity of the weighing instrument
Min	Minimum capacity of the weighing instrument
T	Tare capacity
$T$	Indication of the totalization device
$U_{\text{nom}}$	Nominal voltage value marked on the instrument
$U_{\text{max}}$	Highest value of a voltage range marked on the instrument
$U_{\text{min}}$	Lowest value of a voltage range marked on the instrument
$v_{\text{min}}$	Minimum operating speed
$v_{\text{max}}$	Maximum operating speed
e.m.f.	Electromotive force
I/O	Input/output ports
RF	Radio frequency
V/m	Volts per metre
kV	kilovolt
DC	Direct current
AC	Alternating current
MHz	Megahertz
$\Sigma_{\text{min}}$	Minimum totalized load

---

**General information concerning the type**

Application no.: \_\_\_\_\_ Manufacturer: \_\_\_\_\_  
 Type designation: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Instrument category: \_\_\_\_\_

Testing on:  Complete instrument  Module <sup>1</sup>  
 Accuracy class  0.2  0.5  1  2  
 Min =   $\Sigma_{\min}$  =   
 Max =   
 T+ =  T- =  d =  d<sub>t</sub> =   
 U<sub>nom</sub> =  V U<sub>min</sub> =  V U<sub>max</sub> =  V f =  Hz Battery, U =  V

Zero-setting device:

- Non-automatic  
 Semi-automatic  
 Automatic zero-setting  
 Initial zero-setting  
 Zero-tracking

Initial zero-setting range:  % of Max Temperature range:  °C

Printer:  Built in  Connected  Not present but connectable  No connection

<sup>1</sup> The test equipment (simulator or part of a complete instrument) connected to the module shall be defined in the test form(s) used.



Instrument submitted:	_____	Load sensor:	_____
Identification no.:	_____	Manufacturer:	_____
Software version:	_____	Type:	_____
Connected equipment:	_____	Capacity:	_____
	_____	Number:	_____
Interfaces (number, nature):	_____	Classification symbol:	_____
	_____	Remarks:	_____
	_____		_____
Evaluation period:	_____		_____
Date of report:	_____		_____
Observer:	_____		_____

*Use this space to indicate additional remarks and/or information: other connected equipment, interfaces and load cells, choice of the manufacturer regarding protection against disturbances, etc.*

**Identification of the instrument**

Application no.: \_\_\_\_\_ Type designation: \_\_\_\_\_  
 Identification no.: \_\_\_\_\_ Manufacturer: \_\_\_\_\_  
 Software version: \_\_\_\_\_ Report date: \_\_\_\_\_

**Manufacturing documentation**

(Record as necessary to identify the equipment under test)

System or module name	Drawing number or software reference	Issue level	Serial no.

**Simulator documentation**

System or module name	Drawing number or software reference	Issue level	Serial no.

**Simulator function (summary)**

*(Simulator description and drawings, block diagram etc should be attached to the report if available.)*

Description or other information pertaining to identification of the instrument:

*(attach photograph here if available)*



**Configuration for test**

Application no.: \_\_\_\_\_ Type designation: \_\_\_\_\_  
Report date: \_\_\_\_\_ Manufacturer: \_\_\_\_\_

*Use this space for additional information relating to equipment configuration, interfaces, data rates, load cells EMC protection options etc., for the instrument and/or simulator.*

## Summary of type evaluation

Application no.: \_\_\_\_\_

Type designation: \_\_\_\_\_

Report date: \_\_\_\_\_

Manufacturer: \_\_\_\_\_

	TESTS	Report page	Passed	Failed	Remarks
1	Zero-setting				
2	Warm-up time test				
3	Stability of equilibrium				
4	Influence factors				
4.1	Static temperatures				
4.2	Temperature effect on no load indication				
4.3	Damp heat, steady state				
4.4	Voltage variation tests				
5	Disturbances				
5.1	AC mains short-time power reductions				
5.2.1	Electrical bursts on mains voltage supply lines				
5.2.2	Electrical bursts on I/O circuits and communication lines				
5.3.1	Surges on AC mains voltage lines				
5.3.2	Surges on I/O signal and communication lines (if any)				
5.4.1	Electrostatic discharges on direct application				
5.4.2	Electrostatic discharges on indirect application (contact discharges only)				
5.5.1	Immunity to radiated electromagnetic fields				
5.5.2	Immunity to conducted radio-frequency fields				
5.6.1	Electrical transient conduction along supply lines of 12 V or 24 V road vehicle batteries				
5.6.2	Electrical transient conduction via lines other supply lines 12 V or 24 V road vehicle batteries				
6	Span stability				
7	Material tests:				
7.1	Separate verification method				
7.2	Integral verification method				
	<b>EXAMINATIONS</b>				
8	Examination of the construction				
9	Checklist				

*Use this page to detail remarks from the summary of the type evaluation.*

**1 Zero-setting device (3.8, A.5.4)**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_  
 Control scale interval, *d*: \_\_\_\_\_  
 Resolution during test: \_\_\_\_\_  
 (smaller than *d*)

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

**1.1 Modes of zero-setting (A.5.4.1)**

Mode of zero-setting	Present
Non-automatic	
Semi-automatic	
Automatic operation	

**1.2 Range of zero-setting (3.8.2, A.5.4.2)**

1.2.1 Initial zero-setting range (A.5.4.2.1)

Positive range, $L_p$		Negative range, $L_n$		Zero setting range, $(L_p + L_n)$	% of Max load

1.2.2 Zero-setting range (A.5.4.2.3)

Weight added	Zero Yes/no	Zero setting range	% of Max load

**1.3 Accuracy of zero-setting (A.5.4.3)**

$E = I + \frac{1}{2}d - \Delta L$

$E = I - L$  or  $P - L = \text{Error}$

Zero-setting mode:	Add. load, $\Delta L$	$E = I + \frac{1}{2}d - \Delta L$	$E/d$

Passed

Failed

Remarks:



**1.4 Zero offset interlock (3.8.3, A.6.8)**

Method of zero-setting:

Non-automatic

Semi-automatic

Automatic operation

**Positive offset:**

Load applied after zeroing:		
Automatic operation	Inhibited	
	Not inhibited	

**Negative offset:**

Load removed after zeroing:		
Automatic operation	Inhibited	
	Not inhibited	

Passed

Failed

Remarks:

**2 Warm-up time (4.2.5, A.5.3)**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_  
 Control scale interval, *d*: \_\_\_\_\_  
 Resolution during test: \_\_\_\_\_  
 (smaller than *d*)

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

Duration of disconnection before test: \_\_\_\_\_ hours

Automatic zero-setting device is:

Non-existent     Not in operation     Out of working range     In operation<sup>2</sup>

$$E = I + \frac{1}{2} d - \Delta L - L$$

$E_0$  = error calculated prior to each measurement at zero or near zero (unloaded)

$E_L$  = error calculated at load (loaded)

	Time*	Load, <i>L</i>	Indication, <i>I</i>	Add. load, $\Delta L$	Error	$E_L - E_0$
Unloaded	0 min				$E_{01} =$	
Loaded					$E_L =$	
Unloaded	5 min				$E_0 =$	
Loaded					$E_L =$	
Unloaded	15 min				$E_0 =$	
Loaded					$E_L =$	
Unloaded	30 min				$E_0 =$	
Loaded					$E_L =$	

\* Counted from the moment an indication has first appeared.

	Error	MPE	R 107-1 clause
	a) Initial zero-setting error, $E_{01}$	$\leq 0.25 d_t$	
Check if:	b) Maximum value of error unloaded, $E_0$	$\leq 0.25 d_t$	A.5.4
	c) Maximum value of zero variation, $E_0 - E_{01}$	$\leq 0.25 d_t \times p_i$	
	d) Maximum value of error loaded, $E_L - E_0$	$\leq 0.25 d_t \times p_i$	

Passed     Failed

Remarks:

<sup>2</sup> In operation only if zero operates as part of every automatic weighing cycle

### 3 Stability of equilibrium for static weighing (3.2.10, A.6.1)

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, $d$ :	_____	Time:			hh:mm:ss
Resolution during test: (smaller than $d$ )	_____	Bar. pres.:			hPa

#### In the case of printing or data storage:

Load =

Printing or data storage			
Number	First recorded or printed value after manual disturbance and command	Reading during 5 seconds after print-out or storage	
		Minimum	Maximum
1			
2			
3			
4			
5			

Check separately for each of the five tests if only two adjacent figures appear, one being the printed value.

#### In the case of zero-setting:

$$E = I + \frac{1}{2}d - \Delta L - L = \text{zero or near zero}$$

Zero-setting				
Number	Load, $L$	Indication, $I$	Add. load, $\Delta L$	Error, $E$
1				
2				
3				
4				
5				

Check the accuracy according to A.5.4.3 for zero-setting.

Passed

Failed

Remarks:

**4 Influence factors (2.7, A.7.3)**

**4.1 Static temperatures (2.7.1.1, A.7.3.1)**

**4.1.1 Reference of 20 °C**

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, <i>d</i> :	_____	Time:			hh:mm:ss
Resolution during test: (smaller than <i>d</i> )	_____	Bar. pres.:			hPa

Automatic zero-setting device is:

Non-existent     
  Not in operation     
  Out of working range     
  In operation

$E = I + \frac{1}{2} d - \Delta L - L$ ,       $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, <i>L</i>	Indication, <i>I</i>		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

**Result sheet C**

*Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error*

Static load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

**4.1.2 Static temperatures, specified high of: ..... °C**

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$        $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, $L$	Indication, $I$		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)



**4.1.3 Static temperatures, specified low of: ..... °C**

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$        $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, <i>L</i>	Indication, <i>I</i>		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)



**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Static load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

**4.1.4 Static temperatures, 5 °C (if applicable)**

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$        $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, $L$	Indication, $I$		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)



**4.1.5 Static temperatures, reference of 20 °C**

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$E = I + \frac{1}{2} d - \Delta L - L,$        $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, $L$	Indication, $I$		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)



**4.2 Temperature effect on no-load indication (2.7.1.2, A.7.3.2)**

Application no.: \_\_\_\_\_

Type designation: \_\_\_\_\_

Observer: \_\_\_\_\_

Control scale interval,  $d$ : \_\_\_\_\_

Totalization scale interval,  $d_t$ : \_\_\_\_\_

Automatic zero-setting device is:

Non-existent       Not in operation       Out of working range       In operation

$P = I + \frac{1}{2}d - \Delta L$

Report page <sup>3</sup>	Date	Time	Temp (°C)	Zero indication, $I$	Add. load, $\Delta L$	$P$	$\Delta P$	$\Delta$ Temp	Zero-change per ..... °C

$\Delta P$  = difference of  $P$  for two consecutive tests at different temperatures

$\Delta$ Temp = difference of temperature for two consecutive tests at different temperatures

Check if the zero-change per 5 °C is smaller than  $d$ .

Passed       Failed

Remarks:

<sup>3</sup> Give the report page of the relevant weighing test where weighing tests and temperature effect on no-load indication test are conducted together.

**4.3 Damp heat, steady state (non-condensing) (4.2.3, A.7.3.3)**

**4.3.1 Reference temperature of 20 °C at 50 % humidity**

Application no.:	_____	Temp.:	At start	After 3 h	At end	°C
Type designation:	_____	Rel. h.:				%
Observer:	_____	Date:				yyyy-mm-dd
Scale interval, $d$ :	_____	Time:				hh:mm:ss
Totalization scale interval, $d_t$ :	_____	Bar. pres.:				hPa

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

$E = I + \frac{1}{2} d - \Delta L - L$ ,      $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, $L$	Indication, $I$		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

**Result sheet C**

*Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error*

Static load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:



**4.3.2 Damp heat, steady state, upper limit temperature of: .....°C and 85 % humidity**

	At start	After 3 h	At end	
Temp.:				°C
Rel. h.:				%
Date:				yyyy-mm-dd
Time:				hh:mm:ss
Bar. pres.:				hPa

$E = I + \frac{1}{2} d - \Delta L - L,$        $E_c = E - E_0$  with  $E_0$  = error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, $L$	Indication, $I$		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)

**Result sheet C**

*Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error*

Static load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$

Passed

Failed

Remarks:

**4.3.3 Damp heat, steady state, reference temperature of 20 °C and 50 % humidity**

	At start	After 3 h	At end	
Temp.:				°C
Rel. h.:				%
Date:				yyyy-mm-dd
Time:				hh:mm:ss
Bar. pres.:				hPa

$E = I + \frac{1}{2} d - \Delta L - L,$        $E_c = E - E_0$  with  $E_0 =$  error calculated at or near zero\*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Load, <i>L</i>	Indication, <i>I</i>		Add. load, $\Delta L$		Error		Corrected error, $E_c$		mpe
	↓	↑	↓	↑	↓	↑	↓	↑	
*					*				

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Totalization indication		
At start of test	At end of test	Max deviation observed (except for non-recordable transients)



#### 4.4 Mains power voltage variations test (2.7.2, A.7.3)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	<table border="1" style="border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 2px 10px;"></th> <th style="padding: 2px 10px;">At start</th> <th style="padding: 2px 10px;">At end</th> <th style="padding: 2px 10px;"></th> </tr> </thead> <tbody> <tr> <td style="padding: 2px 10px;">Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">°C</td> </tr> <tr> <td style="padding: 2px 10px;">Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">%</td> </tr> <tr> <td style="padding: 2px 10px;">Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">yyyy-mm-dd</td> </tr> <tr> <td style="padding: 2px 10px;">Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">hh:mm:ss</td> </tr> <tr> <td style="padding: 2px 10px;">Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td style="padding: 2px 10px;">hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

- AC mains voltage variations, A.7.3.4
- DC mains voltage variations, A.7.3.5
- Battery power supply (DC), A.7.3.6
- 12 V or 24 V road vehicle battery voltage variations, A.7.3.7

Supply voltage<sup>4</sup>:  $U_{\text{nom}} =$   V  $U_{\text{min}} =$   V  $U_{\text{max}} =$   V

Automatic zero-setting device is:

- Non-existent   
  Not in operation   
  Out of working range   
  In operation

<sup>4</sup> a) Calculate the lower and upper limits of applied voltages according to 2.7.2. If a voltage range ( $U_{\text{min}} / U_{\text{max}}$ ) is marked, use the average value as the reference value.

b) For a road vehicle battery, the  $U_{\text{nom}}$  of the vehicle's electrical system is usually 12 V or 24 V. However, the practical voltage at the battery terminals of a road vehicle can vary considerably.

Category of power supply: \_\_\_\_\_

Note: Reproduce this form if an instrument has more than one power supply

$$E = I + \frac{1}{2} d - \Delta L - L, \quad E_c = E - E_0 \text{ with } E_0 = \text{error calculated at or near zero}$$

**Result sheet A**

Used in conjunction with result sheet B when the integral control device is used to determine the error

Voltage conditions	$U$ (V)	Load, $L$	Indication, $I$	Add. load, $\Delta L$	Error	Corrected error, $E_c$
$U_{nom}$						
Lower limit						
Upper limit						

**Result sheet B**

Used in conjunction with result sheet A to record the retained totalization

Voltage conditions	$U$ (V)	Totalization indication		
		At start of test	At end of test	Max deviation observed (except for non-recordable transients)
$U_{nom}$				
Lower limit				
Upper limit				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage conditions	$U$ (V)	Static load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Error, $T_c - T_i$
$U_{nom}$							
Lower limit							
Upper limit							

Passed

Failed

Remarks:

## 5 Disturbances (4.1.2, A.7.4)

### 5.1 AC mains voltage dips and short interruptions (A.7.4.1)

Application no.:	_____	Temp.:	At start	At end	_____	°C
Type designation:	_____	Rel. h.:	_____	_____	_____	%
Observer:	_____	Date:	_____	_____	_____	yyyy-mm-dd
Control scale interval, $d$ :	_____	Time:	_____	_____	_____	hh:mm:ss
Totalization scale interval, $d_t$ :	_____	Bar. pres.:	_____	_____	_____	hPa

Automatic zero-setting device is:

<input type="checkbox"/> Non-existent	<input type="checkbox"/> Not in operation	<input type="checkbox"/> Out of working range	<input type="checkbox"/> In operation
---------------------------------------	---	---	---------------------------------------

 Supply voltage<sup>5</sup>:  $U_{nom} =$   V  $U_{min} =$   V  $U_{max} =$   V

#### Pre-test information

Disturbance parameters			
Amplitude (% of $U_{nom}$ )	Duration (cycles)	Number of disturbances	Repetition interval (s)
0	0.5	10	
0	1	10	
40	10	10	
70	25	10	
80	250 / 300*	10	
0	250 / 300*	10	

\* These values are for 50 Hz / 60 Hz respectively

#### Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Disturbance  Amplitude (% of $U_{nom}$ ) (other pre-test information)	Result			
	Load	Indication, $I$	Significant fault (>1 $d_t$ )	
			No	Yes (remarks)
without disturbance				
0				
0				
40				
70				
80				
0				

<sup>5</sup> Calculate the lower and upper limits of applied voltages according to 2.7.2. If a voltage-range ( $U_{min} / U_{max}$ ) is marked, use the average value as the reference value.

**Result sheet B**

Used in conjunction with result sheet A to record the retained totalization

Disturbance  Amplitude % of $U_{nom}$ (other pre-test information)	Result			
	Totalization indication		Significant fault ( $>1 d_t$ )	
	At start of test	At end of test	No	Yes (remarks)
without disturbance				
0				
0				
40				
70				
80				
0				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbance  Amplitude (% of $U_{nom}$ ) (other pre-test information)	Result						
	Load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ( $T_c - T_i$ ) or detection and reaction	
						No	Yes (remarks)
without disturbance							
0 %							
0 %							
40 %							
70 %							
80 %							
0 %							

Passed

Failed

Remarks:



**5.2 Bursts (transients) on mains power lines and on signal and communication lines (A.7.4.2)**

**5.2.1 Mains power lines**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	Temp.: _____ °C Rel. h.: _____ % Date: _____ yyyy-mm-dd Time: _____ hh:mm:ss Bar. pres.: _____ hPa
---	--

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

*Mains power lines: test voltage 1.0 kV (peak), duration of the test > 1 minute at each amplitude and polarity*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Connection	Polarity	Result			
		Load	Indication, $I$	Significant fault (>1 $d_t$ )	
				No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

**Result sheet B**

Used in conjunction with result sheet A to record the retained totalization

Connection	Polarity	Result			
		Totalization indication		Significant fault ( $> 1 d_t$ )	
		At start of test	At end of test	No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Connection	Polarity	Result						
		Load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ( $T_c - T_i$ )	
							No	Yes (remarks)
without disturbance								
Live ↓ ground	pos							
	neg							
without disturbance								
Neutral ↓ ground	pos							
	neg							
without disturbance								
Protective earth ↓ ground	pos							
	neg							

Passed

Failed

Remarks:

**5.2.2 Signal and communication lines**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	<table border="1" style="border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 15%;">At start</th> <th style="width: 15%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

*Signal and communication lines: test voltage 0.5 kV (peak), duration of the test > 1 minute at each amplitude and polarity*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Cable/interface	Polarity	Result			
		Load	Indication, $I$	Significant fault ( $>1 d_t$ )	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

- Notes:*
- 1) Explain or make a sketch indicating where the clamp is located on the cable; if necessary, add additional page.
  - 2) The cell references C/1,1 to C/1,6 should be used to cross-reference the cable or interface between Tables A and B.

**Result sheet B***Used in conjunction with result sheet A to record the retained totalization*

Cable/interface	Polarity	Result			
		At start of test	At end of test	Significant fault ( $>1 d_t$ )	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

**Result sheet C**

*Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error*

Cable/interface	Polarity	Result						Significant fault ( $T_c - T_i$ )	
		Load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ( $T_c - T_i$ )		
							No	Yes (remarks)	
without disturbance									
C/1,1	pos								
	neg								
without disturbance									
C/1,2	pos								
	neg								
without disturbance									
C/1,3	pos								
	neg								
without disturbance									
C/1,4	pos								
	neg								
without disturbance									
C/1,5	pos								
	neg								
without disturbance									
C/1,6	pos								
	neg								

Passed

Failed

Remarks:

**5.3 Electrical surges on mains power lines and on I/O signal and communication lines (if any) (A.7.4.3)**

**5.3.1 Mains power lines**

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, $d_c$ :	_____	Time:			hh:mm:ss
Totalization scale interval, $d_t$ :	_____	Bar. pres.:			hPa

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

*Mains power lines: test voltage 1.0 kV, duration of the test > 1 minute at each amplitude and polarity*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Connection	Polarity	Result			
		Load	Indication, $I$	Significant fault (>1 $d_t$ )	
				No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

**Result sheet B**

Used in conjunction with result sheet A to record the retained totalization

Connection	Polarity	Result			
		Totalization indication		Significant fault (>1 $d_t$ )	
		At start of test	At end of test	No	Yes (remarks)
without disturbance					
Live ↓ ground	pos				
	neg				
without disturbance					
Neutral ↓ ground	pos				
	neg				
without disturbance					
Protective earth ↓ ground	pos				
	neg				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Connection	Polarity	Result						
		Load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	Significant fault ( $T_c - T_i$ )	
							No	Yes (remarks)
without disturbance								
Live ↓ ground	pos							
	neg							
without disturbance								
Neutral ↓ ground	pos							
	neg							
without disturbance								
Protective earth ↓ ground	pos							
	neg							

Passed

Failed

Remarks (including additional test setup information):

**5.3.2 Electrical surges on I/O signal and communication lines (if any)**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d_c$ : _____ Totalization scale interval, $d_t$ : _____	Temp.: _____ °C Rel. h.: _____ % Date: _____ yyyy-mm-dd Time: _____ hh:mm:ss Bar. pres.: _____ hPa
---	--

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

*I/O signal and communication lines (if any): test voltage 0.5 kV, duration of the test 1 minute at each amplitude and polarity*

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Cable/interface	Polarity	Result			
		Load	Indication, $I$	Significant fault (>1 $d_t$ )	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

- Notes:
- 1) Explain or make a sketch indicating where the clamp is located on the cable; if necessary, add additional page.
  - 2) The cell references C/1,1 to C/1,6 should be used to cross-reference the cable or interface between Tables A and B.



**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Cable/interface	Polarity	Result			
		At start of test	At end of test	Significant fault ( $>1 d_t$ )	
				No	Yes (remarks)
without disturbance					
C/1,1	pos				
	neg				
without disturbance					
C/1,2	pos				
	neg				
without disturbance					
C/1,3	pos				
	neg				
without disturbance					
C/1,4	pos				
	neg				
without disturbance					
C/1,5	pos				
	neg				
without disturbance					
C/1,6	pos				
	neg				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Cable/ interface	Polarity	Result						Significant fault ( $T_c - T_i$ )	
		Load	Calculated change in totalization, $T_c$	Totalization before adding load, $T_b$	Totalization after adding load, $T_a$	Indicated change in totalization, $T_i = T_a - T_b$	No	Yes (remarks)	
without disturbance									
C/1,1	pos								
	neg								
without disturbance									
C/1,2	pos								
	neg								
without disturbance									
C/1,3	pos								
	neg								
without disturbance									
C/1,4	pos								
	neg								
without disturbance									
C/1,5	pos								
	neg								
without disturbance									
C/1,6	pos								
	neg								

Passed

Failed

Remarks:

**5.4 Electrostatic discharge (A.7.4.4)**

**5.4.1 Direct application**

Application no.:	_____	Temp.:	At start	At end	°C
Type designation:	_____	Rel. h.:			%
Observer:	_____	Date:			yyyy-mm-dd
Control scale interval, $d_t$ :	_____	Time:			hh:mm:ss
Totalization scale interval, $d_t$ :	_____	Bar. pres.:			hPa

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

Contact discharges    
  Paint penetration  
 Air discharges    
 Polarity<sup>6</sup>:    
 pos    
 neg

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Discharges			Result			
Test voltage (kV)	Number of discharges (≥ 10)	Repetition interval (s)	Load	Indication, $I$	Significant fault (>1 $d_t$ )	
					No	Yes (remarks)
without disturbance						
2						
4						
6						
8 (air discharges)						

<sup>6</sup> IEC 61000-4-2 specifies that the test shall be conducted with the most sensitive polarity.

**Result sheet B**

Used in conjunction with result sheet A to record the retained totalization

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	At start of test	At end of test	Significant fault ( $>1 d_t$ )	
					No	Yes (remarks)
without disturbance						
2						
4						
6						
8 (air discharges)						

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Discharges			Result						
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change $T_i = T_a - T_b$	Significant fault ( $T_c - T_i$ )	
								No	Yes (remarks)
without disturbance									
2									
4									
6									
8 (air discharges)									

Note: If the EUT fails, the test point at which this occurs shall be recorded.

Passed

Failed

Remarks:

**5.4.2 Indirect application (contact discharges only)**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval $d_t$ : _____ Totalization scale interval $d_t$ : _____	Temp.: _____ °C Rel. h.: _____ % Date: _____ yyyy-mm-dd Time: _____ hh:mm:ss Bar. pres.: _____ hPa
---	--

Automatic zero-setting device is:

Non-existent    
  Not in operation    
  Out of working range    
  In operation

Polarity<sup>7</sup>:      pos      neg

**Result sheet A**

Used in conjunction with result sheet B when the integral control device is used to determine the error

**Horizontal coupling plane**

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load	Indication, $I$	Significant fault ( $>1 d_t$ )	
					No	Yes (remarks)
without disturbance						
2						
4						
6						

**Vertical coupling plane**

Discharges			Result			
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Load	Indication, $I$	Significant fault ( $>1 d_t$ )	
					No	Yes (remarks)
without disturbance						
2						
4						
6						

<sup>7</sup> IEC 61000-4-2 specifies that the test shall be conducted with the most sensitive polarity.

**Result sheet B***Used in conjunction with result sheet A to record the retained totalization***Horizontal coupling plane**

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Totalization		Significant fault (>1 $d_t$ )	
			At start of test	At end of test	No	Yes (remarks)
without disturbance						
2						
4						
6						

**Vertical coupling plane**

Discharges			Result			
Test voltage (kV)	Number of discharges ≥ 10	Repetition interval (s)	Totalization		Significant fault (>1 $d_t$ )	
			At start of test	At end of test	No	Yes (remarks)
without disturbance						
2						
4						
6						

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

**Horizontal coupling plane**

Discharges			Result						
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Totalization					Significant fault ( $T_c - T_i$ )	
			Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
without disturbance									
2									
4									
6									

**Vertical coupling plane**

Discharges			Result						
Test voltage (kV)	Number of discharges $\geq 10$	Repetition interval (s)	Totalization					Significant fault ( $T_c - T_i$ )	
			Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
without disturbance									
2									
4									
6									

Note: If the EUT fails, the test point at which this occurs shall be recorded.

Passed

Failed

Remarks:

**5.4 Electrostatic discharge test (A.7.4.4) (continued)**

Specification of test points of EUT (direct application), e.g. by photos or sketches

**a) Direct application**

Contact discharges:

Air discharges:

**b) Indirect application**



**5.5 Immunity to electromagnetic fields (A.7.4.5)**

**5.5.1 Immunity to radiated electromagnetic fields (A.7.4.5.1)**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;"></th> <th style="width: 40%;">At start</th> <th style="width: 40%;">At end</th> <th style="width: 10%;"></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

Rate of sweep:

Test severity;

Frequency range: 80 MHz<sup>1</sup> to 2000 MHz

RF amplitude (50 ohms): 10 V/m

Modulation: 80 % AM, 1 kHz, sine wave

<sup>1</sup> Lower limit is 26 MHz if the test according to A.7.4.5.2 cannot be applied due to lack of mains or I/O ports.

*Note:* If the EUT fails, the frequency and field strength at which this occurs must be recorded.

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	EUT facing	Load	Indication, $I$	Significant fault (>1 $d_t$ )	
						No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				

Passed       Failed

Remarks:

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	EUT facing	Totalization indication		Significant fault (>1 $d_t$ )	
				At start of test	At end of test	No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbances				Result						
Antenna	Frequency range (MHz)	Polarization	EUT facing	Totalization					Significant fault ( $T_c - T_i$ )	
				Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
without disturbance										
		Vertical	Front							
			Right							
			Left							
			Rear							
without disturbance										
		Horizontal	Front							
			Right							
			Left							
			Rear							
without disturbance										
		Vertical	Front							
			Right							
			Left							
			Rear							
without disturbance										
		Horizontal	Front							
			Right							
			Left							
			Rear							

Passed

Failed

Remarks:

**5.5.2 Immunity to conducted electromagnetic fields (A.7.4.5.2)**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	Temp.: _____ °C Rel. h.: _____ % Date: _____ yyyy-mm-dd Time: _____ hh:mm:ss Bar. pres.: _____ hPa
---	--

Rate of sweep:

Test severity;  
 Frequency range: 0.15 MHz – 80 MHz  
 RF amplitude (50 ohms): 10 V (e.m.f.)  
 Modulation: 80 % AM, 1 kHz, sine wave

*Note:* If EUT fails, the frequency and field strength at which this occurs must be recorded.

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	Level (volts e.m.f)	Load	Indication, $I$	Significant fault (>1 $d_t$ )	
						No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				
		Vertical	Front				
			Right				
			Left				
			Rear				
		Horizontal	Front				
			Right				
			Left				
			Rear				

Passed       Failed

Remarks:

**Result sheet B**

*Used in conjunction with result sheet A to record the retained totalization*

Disturbances				Result			
Antenna	Frequency range (MHz)	Polarization	Level (volts e.m.f)	Totalization indication		Significant fault (>1 $d_t$ )	
				At start of test	At end of test	No	Yes (remarks)
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Vertical	Front				
			Right				
			Left				
			Rear				
without disturbance							
		Horizontal	Front				
			Right				
			Left				
			Rear				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Disturbances				Result							
Antenna	Frequency range (MHz)	Polarization	Level (volts e.m.f)	Totalization					Significant fault ( $T_c - T_i$ )		
				Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)	
without disturbance											
		Vertical	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Horizontal	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Vertical	Front								
			Right								
			Left								
			Rear								
without disturbance											
		Horizontal	Front								
			Right								
			Left								
			Rear								

Passed

Failed

Remarks:

Include a description of the setup of the EUT, e.g. by photos or sketches.

Radiated:

Conducted:

**5.6 Electrical transient conduction for instruments powered by road vehicle batteries (A.7.4.6)**

**5.6.1 Conduction along supply lines of 12 V or 24 V road vehicle batteries (A.7.4.6.1)**

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	<table border="1"> <tr> <td></td> <td style="text-align: center;">At start</td> <td style="text-align: center;">At end</td> <td></td> </tr> <tr> <td>Temp.:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

12 V battery voltage     
  24 V battery voltage

**Result sheet A**

*Used in conjunction with result sheet B when the integral control device is used to determine the error*

Voltage conditions, $U_{nom}$	Test pulse	Pulse voltage, $U_s$	Result			
			Load	Indication, $I$	Significant fault ( $>1 d_t$ )	
					No	Yes (remarks) <sup>8</sup>
12 V	2a	+ 50 V				
	2b <sup>9</sup>	+10 V				
	3a	-150 V				
	3b	+100 V				
	4	-7 V				
24 V	2a	+50 V				
	2b	+20 V				
	3a	-200 V				
	3b	+200 V				
	4	-16 V				

<sup>8</sup> Functional status of the instrument during and after exposure to test pulses.

<sup>9</sup> Test pulse 2b is only applicable if the instrument is connected to the battery via the main (ignition) switch of the car, i.e. if the manufacturer has not specified that the instrument is to be connected directly (or by its own main switch) to the battery.



**Result sheet B**

Used in conjunction with result sheet A to record the retained totalization

Voltage conditions, $U_{nom}$	Test pulse	Pulse voltage, $U_s$	Result			
			Totalization indication		Significant fault ( $>1 d_t$ )	
			At start of test	At end of test	No	Yes (remarks)
12 V	2a	+50 V				
	2b	+10 V				
	3a	-150 V				
	3b	+100 V				
	4	-7 V				
24 V	2a	+50 V				
	2b	+20 V				
	3a	-200 V				
	3b	+200 V				
	4	-16 V				

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage conditions, $U_{nom}$	Test pulse	Pulse voltage, $U_s$	Result						
			Totalization indication				Significant fault ( $T_c - T_i$ )		
			Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
12 V	2a	+50 V							
	2b	+10 V							
	3a	-150 V							
	3b	+100 V							
	4	-7 V							
24 V	2a	+50 V							
	2b	+20 V							
	3a	-200 V							
	3b	+200 V							
	4	-16 V							

 Passed

 Failed

Remarks:

### 5.6.2 Electrical transient conduction via lines other than supply lines, for external 12 V or 24 V road vehicle batteries (A.7.4.6.2)

Application no.: _____ Type designation: _____ Observer: _____ Control scale interval, $d$ : _____ Totalization scale interval, $d_t$ : _____	<table border="1" style="border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">At start</th> <th style="text-align: center;">At end</th> <th></th> </tr> </thead> <tbody> <tr> <td>Temp.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>°C</td> </tr> <tr> <td>Rel. h.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>%</td> </tr> <tr> <td>Date:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>yyyy-mm-dd</td> </tr> <tr> <td>Time:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hh:mm:ss</td> </tr> <tr> <td>Bar. pres.:</td> <td style="background-color: #cccccc;"></td> <td style="background-color: #cccccc;"></td> <td>hPa</td> </tr> </tbody> </table>		At start	At end		Temp.:			°C	Rel. h.:			%	Date:			yyyy-mm-dd	Time:			hh:mm:ss	Bar. pres.:			hPa
	At start	At end																							
Temp.:			°C																						
Rel. h.:			%																						
Date:			yyyy-mm-dd																						
Time:			hh:mm:ss																						
Bar. pres.:			hPa																						

 12 V battery voltage

 24 V battery voltage

#### Result sheet A

Used in conjunction with result sheet B when the integral control device is used to determine the error

Voltage conditions, $U_{nom}$	Test pulse	Pulse voltage, $U_s$	Result			
			Load	Indication, $I$	Significant fault ( $>1 d_t$ )	
					No	Yes (remarks) <sup>10</sup>
12 V	a	-60 V				
	b	+40 V				
24 V	a	-80 V				
	b	+80 V				

#### Result sheet B

Used in conjunction with result sheet A to record the retained totalization

Voltage conditions, $U_{nom}$	Test pulse	Pulse voltage, $U_s$	Result			
			Totalization indication		Significant fault ( $>1 d_t$ )	
			At start of test	At end of test	No	Yes (remarks)
12 V	a	-60 V				
	b	+40 V				
24 V	a	-80 V				
	b	+80 V				

<sup>10</sup> Functional status of the instrument during and after exposure to test pulses.

**Result sheet C**

Used where the total is being increased by continually adding the result of weighing a static load and the totalization indicator is used to determine the error

Voltage conditions, $U_{nom}$	Test pulse	Pulse voltage, $U_s$	Result						
			Totalization indication					Significant fault ( $T_c - T_i$ )	
			Load	Calculated change, $T_c$	Before adding load, $T_b$	After adding load, $T_a$	Indicated change, $T_i = T_a - T_b$	No	Yes (remarks)
12 V	a	-60 V							
	b	+40 V							
24 V	a	-80 V							
	b	+80 V							

 Passed

 Failed

Remarks:

## 6 Span stability (6.7.3, A.8)

Application no.: \_\_\_\_\_

Type designation: \_\_\_\_\_

Control scale interval,  $d$ : \_\_\_\_\_

Resolution during test (smaller than  $d$ ): \_\_\_\_\_

Automatic zero-setting and zero-tracking device is:

Non-existent       Not in operation       Out of working range

Zero load =

Test load =

Automatic span adjustment device:

Non-existent       In operation

### Measurement no. 1: Initial measurement

Application no.: \_\_\_\_\_

Type designation: \_\_\_\_\_

Observer: \_\_\_\_\_

	At start	At end	
Temp.:	<input type="text"/>	<input type="text"/>	°C
Rel. h.:	<input type="text"/>	<input type="text"/>	%
Date:	<input type="text"/>	<input type="text"/>	yyyy-mm-dd
Time:	<input type="text"/>	<input type="text"/>	hh:mm:ss
Bar. pres.:	<input type="text"/>	<input type="text"/>	Pa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value*
1	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
2	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
3	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
4	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
5	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

Average error = average ( $E_L - E_0$ )

$(E_L - E_0)_{\max} - (E_L - E_0)_{\min} =$

$0.1 d =$

If  $|(E_L - E_0)_{\max} - (E_L - E_0)_{\min}| \leq 0.1 d$ , one loading and reading will be sufficient for each of the subsequent measurements. If not, five loadings and readings shall be performed at each measurement.

Remarks:

For each of the subsequent measurements (at least seven), indicate under “Remarks”, as appropriate, if the measurement has been performed after:

- the temperature test, the EUT having been stabilized for at least 16 h
- the damp heat test, the EUT having been stabilized for at least 16 h
- the EUT has been disconnected from the mains for at least 8 h and then stabilized for at least 5 h
- any change in the test location
- any other specific condition: \_\_\_\_\_

**Measurement no. 2**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value*
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:

**Measurement no. 3**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value*
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:

**Measurement no. 4**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value*
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:

**Measurement no. 5**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:

**Measurement no. 6**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:

**Measurement no. 7**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:

**Measurement no. 8**

Application no.: \_\_\_\_\_  
 Type designation: \_\_\_\_\_  
 Observer: \_\_\_\_\_

	At start	At end	
Temp.:			°C
Rel. h.:			%
Date:			yyyy-mm-dd
Time:			hh:mm:ss
Bar. pres.:			hPa

$$E_0 = I_0 + \frac{1}{2} d - \Delta L_0 - L_0, \quad E_L = I_L + \frac{1}{2} d - \Delta L - L$$

No.	Indication of zero, $I_0$	Add. load, $\Delta L_0$	$E_0$	Indication of load, $I_L$	Add. load, $\Delta L$	$E_L$	$E_L - E_0$	Corrected value
1								
2								
3								
4								
5								

\* When applicable, necessary corrections resulting from variations of temperature, pressure, etc. See remarks.

If five loadings and readings have been performed: Average error = average ( $E_L - E_0$ )

Remarks:




**5 SPAN STABILITY (A.8)**

Application no.:

Type designation:

Plot on the diagram the indication of temperature test, T, damp heat test, D and disconnections from the mains power supply, P



Maximum allowable variation:

Passed  Failed

**7 Material tests (6.1, A.5.1)****7.1 Material testing (separate verification method) (6.2.1, A.5.1.1, A.9.2.3)****Test 1**

	At start	At end	
Application no.: _____	Temp.:		°C
Type designation: _____	Rel. h.:		%
Observer: _____	Date:		yyyy-mm-dd
Control scale interval, $d$ : _____	Time:		hh:mm:ss
Totalization scale interval, $d_t$ : _____	Bar. pres.:		hPa
Material: _____			
Condition of material: _____			
Nominal load: _____			

Parameter	Results
Number of loads	
Indicated total at start, $T_S$	
Indicated total at end, $T_F$	
$I = T_F - T_S$	
Control instrument indication for total load, $L$	
Error = $(I - L) / L \times 100 \%$	

Remarks:

**Test 2**

	At start	At end	
Application no.: _____	Temp.:		°C
Type designation: _____	Rel. h.:		%
Observer: _____	Date:		yyyy-mm-dd
Control scale interval, $d$ : _____	Time:		hh:mm:ss
Totalization scale interval, $d_t$ : _____	Bar. pres.:		hPa
Material: _____			
Condition of material: _____			
Nominal load: _____			

Parameter	Results
Number of loads	
Indicated total at start, $T_S$	
Indicated total at end, $T_F$	
$I = T_F - T_S$	
Control instrument indication for total load, $L$	
Error = $(I - L) / L \times 100 \%$	

Remarks:

**Test 3**

		At start	At end	
Application no.: _____	Temp.:			°C
Type designation: _____	Rel. h.:			%
Observer: _____	Date:			yyyy-mm-dd
Control scale interval, <i>d</i> : _____	Time:			hh:mm:ss
Totalization scale interval, <i>d</i> <sub>t</sub> : _____	Bar. pres.:			hPa
Material: _____				
Condition of material: _____				
Nominal load: _____				

Parameter	Results
Number of loads	
Indicated total at start, $T_S$	
Indicated total at end, $T_F$	
$I = T_F - T_S$	
Control instrument indication for total load, $L$	
Error = $(I - L) / L \times 100 \%$	

Remarks:

**Additional test**

		At start	At end	
Application no.: _____	Temp.:			°C
Type designation: _____	Rel. h.:			%
Observer: _____	Date:			yyyy-mm-dd
Control scale interval, <i>d</i> : _____	Time:			hh:mm:ss
Totalization scale interval, <i>d</i> <sub>t</sub> : _____	Bar. pres.:			hPa
Material: _____				
Condition of material: _____				
Nominal load: _____				

Parameter	Results
Number of loads	
Indicated total at start, $T_S$	
Indicated total at end, $T_F$	
$I = T_F - T_S$	
Control instrument indication for total load, $L$	
Error = $(I - L) / L \times 100 \%$	

Remarks:

*Note:* Reproduce this page for additional tests as necessary.















## **8 Examination of the construction of the instrument**

*Use this page to indicate any description or information pertaining to the instrument, additional to that already contained in this report and in the accompanying OIML certificate. This may include a picture of the complete instrument, a description of its main components, and any remark which could be useful for authorities responsible for the initial or subsequent verifications of individual instruments built according to the type. It may also include references to the manufacturer's description.*

Description:

Remarks:

## 9 Checklist

This checklist is intended to serve as a summary of the results of examinations to be performed and not as a procedure. The items on this checklist are provided to recall the requirements specified in R 107-1:2007 and shall not be considered as a substitution for these requirements.

For non-mandatory devices, the checklist provides space to indicate whether or not the device exists and, if appropriate, its type. A cross in the box for “present” indicates that the device exists and that it complies with the definition given in the terminology; when indicating that a device is “not present”, also check the boxes to indicate that the tests are not applicable (see page 6).

If appropriate, the results stated in this checklist may be supplemented by remarks given on additional pages.

Application no.: \_\_\_\_\_ Type designation: \_\_\_\_\_

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
		<b>Metrological requirements</b>			
2.2.1	A.5.1	<b>Maximum permissible errors</b>			
		Maximum permissible errors for automatic weighing for each class for loads not less than $\Sigma_{\min}$ : <ul style="list-style-type: none"> <li>▪ do not exceed values in Table 1 rounded to the nearest <math>d_t</math></li> </ul>			
2.2.2	A.7	Maximum permissible errors for influence factor tests:			
		<ul style="list-style-type: none"> <li>▪ do not exceed values in Table 2,</li> <li>▪ accuracy of rounding errors at least <math>0.2 d_t</math></li> </ul>			
2.3	Observe	Form of the scale interval: $1 \times 10^k$ , $2 \times 10^k$ or $5 \times 10^k$	Note		
2.4	Observe	Totalization scale interval: $0.01 \% \leq d_t \leq 0.1 \% \text{ of Max}$	Note		
2.5	Observe	Minimum totalized load: $\Sigma_{\min} \geq \text{Min}$ $\Sigma_{\min} \geq 1000 d_t$ for class 0.2, or $400 d_t$ for class 0.5, or $200 d_t$ for class 1, or $100 d_t$ for class 2			
2.6	A.6.2	<b>Agreement between multiple indicating devices</b>			
		For a given load, the difference between the weighing results from any two devices having same scale interval is:			
	Observe	<ul style="list-style-type: none"> <li>▪ not greater than the absolute value of the maximum permissible errors for automatic weighing for analog devices.</li> <li>▪ zero for digital displaying and printing devices.</li> </ul>			
2.7	A.7.3	<b>Influence factors</b>			
2.7.1.1	A.7.3.1	Static temperatures			
2.7.1.2		Temperature effect on no-load indication			
2.7.2		Mains power:			
	A.7.3.4	AC mains voltage variations			
	A.7.3.5	DC mains voltage variations			
	A.7.3.6	Battery voltage variations (DC)			
	A.7.3.7	12 V or 24 V road vehicle battery voltage variations			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
2.8	Observe	Units of measurement: gram (g), kilogram (kg), tonne (t)			
<b>3</b>		<b>Technical requirements</b>			
3.1	Observe	Suitability for use: design to suit intended materials and usage, and robust construction to maintain its metrological characteristics			
3.2	Observe	<b>Security of operation</b>			
3.2.1		No characteristics likely to facilitate fraudulent use			
3.2.2		Effect of accidental breakdown or maladjustment is evident			
3.2.3		Operation unaffected by incomplete discharge			
3.2.4		Effects of variation in the quantity of the load $\geq$ Lim is evident			
3.2.5		Inhibition of usage at loads: > Max; < Min;			
3.2.6	Observe	<b>Use as a non-automatic weighing instrument:</b>			
		Complies with the requirements of OIML R 76-1:2006 <i>Non-automatic weighing instruments</i>			
3.2.7	A.6.3	<b>Operational adjustments</b>			
		Adjustment prevented in automatic mode, except during tests in accordance with 3.2.5 and 6.3 of R 107-1			
3.2.8	Observe	<b>Controls</b>			
		Controls come to rest in intended positions and unambiguously marked keys			
3.2.9	Observe	<b>Dust extraction</b>			
		Shall not affect measurement			
3.2.10	A.6.1	<b>Stable equilibrium</b>			
		Under continuous or temporary disturbance of stable equilibrium:			
		▪ printed or stored weighing values show no more than two adjacent; with one of them being the final weight value;			
		▪ for zero operations, correct operation according to 3.8.1 of R 107-1 is achievable			
3.2.11	Observe	<b>Interlocks</b>			
		Prevent or indicate operation outside specified working conditions for:			
		▪ minimum operating voltage (2.7.2)			
		▪ maximum safe load (3.2.4)			
		▪ zero-setting (3.8.3)			
		▪ automatic operation (3.2.5)			
3.3	A.6.4	<b>Securing of components and pre-set controls</b>			
3.3.1	Observe	Instrument, modules, devices and controls:			
		Fitted with a securing means, or			
		Enclosed;			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks		
3.3.2	Observe	If enclosed, the enclosure is sealed					
		Seals are easily accessible					
		Legally relevant parameters protected by hardware or software means					
		Securing provided on all parts of the measuring system which cannot be materially protected in any other way against operations liable to affect the measurement accuracy					
		National regulations may specify the securing that is needed					
		<b>Means of security:</b>					
		Hardware and/or software means of security to restrict access to authorised persons only					
		Records of interventions including the date and a means of identifying the authorised person making the intervention (see a) above): <ul style="list-style-type: none"> <li>▪ can be memorised, accessed and displayed;</li> <li>▪ traceability of the interventions is assured for at least the period of time in between periodical verifications depending on national regulations</li> </ul>					
		Records may not be overwritten, and if the storage capacities for records is exhausted, no further intervention shall be possible without breaking a physical seal					
		Software functions secured against intentional, unintentional and accidental changes in accordance with 3.6 of R 107-1					
		Transmission of legally relevant data via interfaces secured against intentional, unintentional and accidental changes according to 4.2.6.2 of R 107-1					
		3.4	A.6.5 Observe	Securing possibilities available in an instrument shall be such that separate securing of the settings may be possible			
Stored measurement data is secured against intentional, unintentional and accidental changes in accordance with 3.5 of R 107-1							
<b>Indication and recording of weighing results</b>							
<b>Devices included with the instruments</b>							
Principal totalization indicating device	Present [ ]			Not present [ ]			
Supplementary totalization indicating device	Present [ ]			Not present [ ]			
Partial totalization indicating device	Present [ ]			Not present [ ]			
Data storage device	Present [ ]			Not present [ ]			
Printer	Present [ ]			Not present [ ]			
3.4.1	Observe			<b>Quality of indication</b>			
				Reliable, easy and unambiguous under normal conditions			
				Overall inaccuracy of an analogue device $< 0.2 d_t$			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.4.2	A.6.5	The scales, numbering and printing shall permit the figures which form the results to be read by simple juxtaposition			
3.4.2.1	Observe	<b>Form of the indication</b>			
		<b>Units of mass</b>			
		Results contain names and symbols of the units of mass			
		for any one indication, only one unit of mass			
		Units of mass written in small letters (lower case) in accordance with 2.8 of R 107-1.			
3.4.2.2	Observe	<b>Digital indication</b>			
		Digital zero indication includes the display of a zero for all places that are displayed to the right of a decimal point and at least one place to the left			
		When no decimal values are displayed, a zero shall be displayed for each place of the displayed division			
		Decimal fraction is separated from its integer by a decimal sign (comma or dot) with the indication showing at least one figure to the left of the sign and all figures to the right			
		Decimal sign on one line with the bottom of the figures (e.g. 0.305 kg) to separate integer and decimal fraction			
3.4.2.3	Observe	<b>Scale interval</b>			
		All devices (except supplementary devices) shall have the same scale interval.			
		Form of the scale interval is in accordance with requirements in 2.3 of R 107-1			
		Decimal sign maintains its position in the display where the scale interval is changed automatically			
3.4.3	Observe	<b>Totalization indicating devices</b>			
		Allow reliable, clear and unambiguous reading of the results by simple juxtaposition and bear the symbol of the appropriate unit of mass.			
		Printing is clear and permanent for the intended use. Printed figures are at least 2 mm high			
		It is not possible to reset the principle totalization device to zero an automatic operation.			
		On interruption of automatic operation, it is not possible to reset the partial totalization indicating device to zero unless the last total indicated before resetting to zero is automatically recorded			
		Control indicating device is to a higher resolution than that of the principal totalization indicating device.			
		During static weighing in non-automatic operations, printing is inhibited if the stability criteria in 3.2.10 of R 107-1 are not fulfilled			
3.4.4	Observe	<b>Combined indicating devices</b>			
		Combined indication on demand clearly identified			
3.4.5		Instruments that tare weigh			
		For instruments used to receive (weigh in), the no-load reference value shall be determined and recorded only at the beginning of each weighing cycle			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.5	Observe	For instruments used to deliver (weigh out), the no-load reference value shall be determined and recorded only after the gross load reference value for each weighing cycle has been indicated and recorded			
		<b>Data storage device</b>			
		Memory of the instrument (hard drive)	Present [ ]		Not present [ ]
		Removable external storage	Present [ ]		Not present [ ]
		Stored data is adequately protected against intentional and unintentional changes during storage process and contains all relevant information necessary to reconstruct an earlier measurement			
		<b>Data storage security</b>			
		Stored data is secured in accordance with the appropriate requirements in 3.5 of R 107-1			
		If software realizing the data storage can be transmitted to or downloaded into the instrument these processes shall be secured in accordance with requirements in 3.6 of R 107-1			
		External storage devices identification and security attributes are automatically verified to ensure integrity and authenticity			
		Exchangeable storage media for storing measurement data need not be sealed provided that the stored data is secured by a specific checksum or key code			
3.6	A.1.1	Replacement of old data with new data is only possible when the owner of the old data has given authority to overwrite the old data			
		<b>Software</b>			
3.6.1	Observe	Legally relevant software (T.2.7.7.1) of the instrument is identified by the manufacturer			
		<b>Software information submitted with software controlled instruments</b>			
3.6.2	A.1.1	Description of the legally relevant software			
		Description of the accuracy of the measuring algorithms (e.g. programming modes)			
		Description of the user interface, menus and dialogues			
		The unambiguous software identification			
		Description of the embedded software			
		Overview of the system hardware, e.g. block diagram, type of computer(s), software source code, etc, if not described in the operating manual			
		Means of securing software			
		Operating manual			
		<b>Security of legally relevant software</b>			
		Appropriate requirements for securing given in 3.3 and 3.6 of R 107-1			
Assignment of appropriate software identification to legally relevant software, which is adapted in the case of every software change that may affect the functions and accuracy of the instrument					

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.7		Functions performed or initiated via connected interfaces, i.e., transmission of legally relevant software, shall comply with the securing requirements for interfaces in 4.2.6 in R 107-1			
		National regulation may specify the requirements for security of software controlled instruments			
		<b>Instruments with control indicating devices</b>			
	A.5.4	Load receptor shall have the facility to support a quantity of standard weights in accordance with Table 3 of R 107-1			
		<b>Zero-setting devices</b>			
		The types and modes of zero-setting required on an instrument are specified in accordance with national regulations	enter in remarks		
	Observe	Zero-setting modes:			
		Automatic zero-setting	Present [ ]	Not present [ ]	
		Semi-automatic zero-setting	Present [ ]	Not present [ ]	
		Non-automatic zero-setting	Present [ ]	Not present [ ]	
3.8.1	A.5.4.3	<b>Accuracy of zero-setting:</b> $\leq 0.25 d_t$			
3.8.2	Observe	<b>Maximum effect</b>			
		Effect of zero-setting device does not alter the maximum weighing capacity			
		Overall effect of:			
		Zero-setting range < 4 % =	%		
		Initial zero-setting < 20 % =	%		
3.8.3	A.6.8.1	<b>Control of the zero-setting device</b>			
		Operation of the zero-setting device shall be possible only when the instrument is in stable equilibrium (3.2.10), and			
		Rate of correction of zero-tracking shall not be more than 0.5 $d$ per second			
	Observe	Interlock prevents automatic operation:			
		▪ if the zero indication varies by or more than:			
		– 1 $d_t$ on instruments with an automatic zero-setting device, or			
		– 0.5 $d_t$ on instruments with a semi-automatic or non-automatic zero-setting device			
		▪ if the instrument is not zeroed automatically following an automatic weighing cycle			
		A description of the operation of the automatic zero-setting device (e.g. the maximum programmable time interval) is specified by the manufacturer			
		The programmable interval specified by the manufacturer is sufficient to maintain zero within 0.5 $d_t$			
		Non-automatic or semi-automatic zero-setting device inoperable during automatic operation			



Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.8.4	Observe	Digital indicating device:			
		<ul style="list-style-type: none"> <li>▪ provides an indication of when the deviation from zero is not more than <math>0.25 d_t</math>, or</li> <li>▪ automatically maintains a "center of zero" condition to <math>\pm 1/4 d_t</math> or less</li> </ul>			
3.9	A.1.4	<b>Descriptive markings, variable according to national regulation:</b>			
3.9.1	Observe	<b>Markings shown in full:</b>			
		Identification mark or name of the manufacturer			
		Identification mark or name of the importer (if applicable)			
		Serial number of the instrument			
		Product description			
		Control scale interval (if applicable) (g, kg or t)			
		Electrical supply voltage (V)			
		Electrical supply frequency, (if applicable) (Hz)			
		Pneumatic/hydraulic pressure (if applicable) (kPa or bar)			
		Software identification (if applicable)			
3.9.2	Observe	<b>Markings shown in code:</b>			
		Type approval sign			
		Indication of the class of accuracy: 0.2, 0.5, 1 or 2			
		Maximum capacity, Max (g, kg or t)			
		Minimum capacity, Min (g, kg or t)			
		Minimum totalized load, $\Sigma_{min}$ (g, kg or t)			
		Totalization scale interval, $d_t$ (g, kg or t)			
3.9.3	Observe	Supplementary markings:			
		Any additional markings		enter in remarks	
3.9.4	Observe	Presentation of descriptive markings:			
		Indelible and of size, shape and clarity that allows easy reading			
		Shown in accordance with national language or in form of adequate, internationally agreed and published pictograms or signs			
		Grouped together in a clearly visible place either on a descriptive plate or sticker fixed permanently near the indicating device, or on a non removable part of the instrument itself			
		In case of a plate or sticker which is not destroyed when removed, a means of securing shall be provided			
		Shown on a programmable display, and:			
		At least Max, Min and $d_t$ shall be displayed as long as the instrument is switched on			
		The other marking may be shown on manual command			
	Described in the type approval certificate				

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
3.9.4	Observe	Markings (device-specific parameters) comply with the securing requirements in 3.3 and 3.6			
		Markings on a data plate for software controlled display include:			
		Max, Min and $d_t$ shown near the display			
		Type and designation of the instrument			
		Type approval number or sign			
		Name or identification mark of the manufacturer			
		Electrical supply voltage (V)			
		Electrical supply frequency (Hz)			
		Pneumatic/hydraulic pressure, (if applicable) (kPa or bar)			
3.10	A.1.4	<b>Verification marks</b>			
3.10.1	Observe	<b>Position of verification marks:</b>			
		Cannot be removed without damaging the marks			
		Allows easy application of marks			
3.10.2	Observe	Visible without the instrument having to be removed			
		<b>Mounting</b>			
		Verification mark support ensures conservation of the marks			
4		The type and method of sealing shall be determined by national prescription.			
		<b>General requirements</b>			
4.1.1		Rated operating conditions: errors do not exceed mpe			
4.1.2		<b>Disturbances</b>			
		Electronic instruments designed and manufactured so that:			
		Significant faults do not occur, or			
		Significant faults are detected and acted upon			
4.2	A.1.5	<b>Functional requirements</b>			
4.2.1	Observe	<b>Acting upon significant faults:</b>	Note below		
		Instrument is made inoperative automatically, or			
		Visual or audible indication is provided automatically and continuous until the user takes action or the fault disappears			
		Totalized load information is retained when a significant fault occurs			
4.2.2	Observe	<b>Indicator display test:</b> Upon switch-on of displays on which failures become evident, all relevant signs of indicating device are active and non-active for sufficient time to be checked by operator			
4.2.5	A.5.3 Observe	<b>Warm-up time:</b>			
		No indication or transmission of weighing results			
		Automatic operation is inhibited			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
4.2.6	A.7.2.2	<b>Interfaces</b>			
		When fitted: Instrument shall continue to function correctly and its metrological functions shall not be influenced			
4.2.6.1	Observe	Interface information submitted with instrument:			
	A.7.2.3	<ul style="list-style-type: none"> <li>▪ list of all commands (e.g. menu items)</li> <li>▪ description of the software interface</li> <li>▪ list of all commands together</li> <li>▪ brief description of their meaning and their effect on the functions and data of the instrument</li> <li>▪ other interface description</li> </ul>			
4.2.6.2	Observe	<b>Interface security:</b>			
		<ul style="list-style-type: none"> <li>▪ legally relevant software, measurement data and functions of the instrument are not adversely affected or influenced by other interconnected instruments, or by disturbances acting on the interface</li> <li>▪ protective interface protects data against accidental or deliberate interference during the transfer</li> <li>▪ hardware and software functions comply with the appropriate securing requirements in 3.3 and 3.6 respectively</li> <li>▪ it shall be easily possible to verify the authenticity and integrity of data transmitted to and from the instrument</li> </ul>			
		Other instruments required by national regulation to be connected to the interfaces of an instrument shall be secured to automatically inhibit the operation of the instrument for reasons of the non-presence or improper functioning of the required device			
4.2.7	A.6.6	<b>AC mains voltage supply failure:</b>			
	Observe	Metrological information retained for at least 24 hours			
		Switch-over to emergency power supply shall not cause significant fault			
4.2.8	A.6.7	<b>External or plug-in (AC or DC) battery voltage supply:</b>			
		When battery voltage is below the specified voltage value, the instrument:			
		Continues to function correctly, or			
		Is automatically put out of service			
<b>5</b>		<b>Type approval</b>			
5.1.1	A.1.1	<b>Documentation submitted for type approval includes:</b>			
		Metrological characteristics of the instrument			
		Standard set of specifications for the instrument			
		Functional description of the components and devices			
		Drawings, diagrams and general software information explaining the construction and operation			
		Details of fractions $p_i$ (modules tested separately)			

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks	
5.1.1	A.1.1	Indicating devices (3.4.3)				
		Data storage device (3.5)				
		Zero-setting device (3.8)				
		<b>Documentation submitted for type approval includes:</b>				
		Interfaces (types, intended use, immunity to external influences instructions (4.2.6)				
		For software controlled instruments detailed software information (3.6)				
		Description of the stable equilibrium function of the instrument (3.2.11)				
		Drawing or photo of the instrument showing the principle and the location of control marks, securing marks, descriptive and verification marks (3.9, 3.10)				
		Operating instructions, operating manual				
		Any document or other evidence that the design and construction of the instrument complies with the requirements of the Recommendation				
5.1.2.1		<b>General requirements</b>				
		Instruments available for tests as follows:				
		<ul style="list-style-type: none"> <li>▪ fully operational at a typical site</li> </ul>	Confirm			
5.1.2.2		<ul style="list-style-type: none"> <li>▪ for laboratory simulation testing</li> </ul>	Confirm			
		<b>Type evaluation tests</b>				
5.1.2.3	A.5.1	Documents examined and tests carried out to verify that instrument complies with:				
		<ul style="list-style-type: none"> <li>▪ metrological requirements in Clause 2</li> </ul>				
		<ul style="list-style-type: none"> <li>▪ technical requirements in Clause 3</li> </ul>				
		<ul style="list-style-type: none"> <li>▪ requirements in Clause 4 for electronic instruments</li> </ul>				
		Acceptance of test report from another metrological authority	Note			
		Instruments used in static weighing shall comply with the requirements of 3.2.6	Note			
		<b>Material tests</b>				
		Instruments subjected to in-site material tests in accordance with:				
		<ul style="list-style-type: none"> <li>▪ Separate verification method as in A.5.1.1</li> </ul>				
		<ul style="list-style-type: none"> <li>▪ Integral verification method as in A.5.1.2</li> </ul>				
5.1.2.4		<b>Simulation tests</b>				
		Influence quantities shall be applied during simulation tests in a manner that will reveal an alteration in accordance with:				
		<ul style="list-style-type: none"> <li>▪ R 107-1, 2.7 for all instruments; and</li> </ul>				
		<ul style="list-style-type: none"> <li>▪ R 107-1, 4, for electronic instruments</li> </ul>				
5.1.4		<b>Modules</b>				
		Examination and separate test of modules of an instrument or system according to:				
		Modules to be examined separately defined and submitted by the manufacturer				

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
5.2		The error limits applicable to a module which is examined separately apportioned in accordance with requirements in 5.1.4.1 of R 107-1			
		<b>Initial verification</b>			
5.2.1		Instruments shall comply with R 107-1, 2 (except 2.7) and 3 for any product(s) for which they are intended and when operated under normal weighing conditions	Confirm		
		<b>General requirements</b>			
5.2.2		Tests shall be carried out, in-situ, with the instrument fully assembled and fixed in the position in which it is intended to be used. Instrument installed such that the weighing operation will be the same whether for the purposes of testing or for normal weighing operation	Confirm		
		<b>Operational tests</b>			
5.2.3		Instruments subjected to in-site material tests in accordance with:			
		Separate verification method as in A.5.1.1			
		Integral verification method as in A.5.1.2			
		Instruments used in static weighing in accordance with the integral verification method in A.5.1.2 shall comply with the requirements of 3.2.6			
		<b>Conformity</b>			
		Conformity to the approved type and/or this Recommendation shall cover:			
		compliance with the appropriate maximum permissible errors in 2.2.1	Confirm		
		correct functioning of all devices, e.g. interlocks, indicating and recording devices	Confirm		
		construction material and design, as far as they are of metrological relevance	Confirm		
		if appropriate a list of the tests performed	Confirm		
6 6.1		<b>Test methods</b>			
		<b>General test procedure</b>			
		In-situ material tests shall be carried out as follows:			
		In accordance with the descriptive markings	Confirm		
		Under the rated operating conditions for the instrument	Confirm		
		Not less than three material tests shall be conducted, one at maximum capacity, Max, one at minimum capacity, Min, and one close to the minimum totalized load, $\Sigma_{min}$ , marked on the instrument	Confirm		
		With test load(s) that is representative of the range and type of products for which the instrument is likely to be used or product(s) for which the instrument is intended	Confirm		
		Each test shall be conducted at the maximum rate of weighing cycles per hour	Confirm		
		Minimum of five weighing cycles per material test shall be conducted	Note		

Requirement (R 107-1)	Test procedure	Totalizing hopper weigher checklist	Passed	Failed	Remarks
6.2	A.5.1.1	Equipment near the instrument, including conveyors, dust collection systems, etc. that are in use when the instrument is in normal operation, shall be in use during the tests	Note		
		If the instrument can divert weighed material through alternative discharge facilities the test program shall be performed for each alternative unless weigh hopper is not affected, for example, by different air flow	Note		
6.2.1	A.5.1.1	<b>Control instruments and test standards</b>			
		<b>Separate control instrument</b>			
6.2.2	A.5.1.2	Error and uncertainty of a separate control instrument verified at any time other than immediately prior to the weighing tests shall be less than one-fifth of the maximum permissible error for automatic weighing in 2.2.1			
		<b>Integral control instrument</b>			
		Combined error and uncertainty of the integral control instrument shall be less than one-third of the maximum permissible error in 2.2.1	Note mpe		
		Integral control instrument provided with an appropriate scale interval, and complies with the requirements of 3.2.6 and A.5.1.2	Confirm		
6.2.4	A.5.1.2	When load receptor cannot be loaded with sufficient standard weights, instrument shall be subjected to material tests by the separate verification method. In which case an appropriate control instrument shall be available	Note method		
		<b>Standard weights</b>			
		Reference standard weights or masses used for type examination or verification comply with the metrological requirements of OIML R 111:2004 Error of the additional weights used to determine the rounding error of the control instrument shall not exceed one-fifth of the maximum permissible errors of the instrument to be verified for the load, as specified in R 107-1, 2.2.2 for initial verification	Confirm		
6.3	A.5.1.2.3	<b>Interruption of the automatic operation</b>			
		Integral control instrument uses a test-stop program as part of the automatic weighing program to automatically interrupt automatic weighing operation twice as specified in R 107-1, A.5.1.2.3 during each weighing cycle in order to weigh and discharge a subdivision of the test load  If the integral control instrument is installed as an air-enclosed system interruption of the automatic operation during consecutive weighing cycles may not be possible and tests shall be conducted as specified in R 107-1, A.5.1.2.7	Confirm		

*Use this space to detail remarks from the checklist*